



# **CCF Parameter Estimations 2009**

U.S. Nuclear Regulatory Commission, "CCF Parameter Estimations, 2009 Update"

This report documents the quantitative results of the common-cause failure (CCF) data collection effort and summarizes the results of the parameter estimation quantification process, performed on CCF data in the U.S. NRC CCF database.

# CCF Parameter Estimations 2009

This report documents the quantitative results of the common-cause failure (CCF) data collection effort and summarizes the results of the parameter estimation quantification process, performed on CCF data in the U.S. NRC CCF database.

These results are appropriate for use in Probabilistic Risk Assessment studies of commercial nuclear power plants in the U.S.

Included in these results are the applications to be used in the SPAR Version greater than 3.45 models. This is the 2009 update to NUREG/CR-5496, updating data and parameter estimations.

This release, CCF Parameter Estimation for 2009, reflects the CCF data contained within the CCF database, Version 4.5.2009. This version of the CCF database contains data from 1997 to 2009.

The applications contained within were created with a starting date of 1/1/1997. This date was selected in order to use as much of the CCF data as possible, but to avoid using the large number of CCF events in the 1980 to 1996 period since the trend is decreasing significantly from 1980 to 1996.

The way to provide a reference for this update is:

U.S. Nuclear Regulatory Commission, "CCF Parameter Estimations, 2009 Update",  
<http://nrccoe.inl.gov/results/CCF/ParamEst2009/ccfparamest.htm>, January 2011.

## TABLE OF CONTENTS

1 INDUSTRY COMPONENT CCF DISTRIBUTIONS.....	6
1.1 Motor Driven Pumps.....	7
1.1.1 Pooled Motor Driven Pump Distributions .....	7
1.1.2 Pooled Pump Volutes.....	13
1.1.3 Pooled Clean System Motor Driven Pump Distributions.....	15
1.1.4 PWR Containment Spray Pumps.....	19
1.1.5 BWR Residual Heat Removal Pumps .....	22
1.1.6 AFW Motor-Driven Pumps.....	27
1.1.7 AFW Pump Volutes .....	31
1.1.8 Emergency Service Water Pump .....	33
1.1.9 PWR High Pressure Safety Injection Pump.....	43
1.1.10 PWR Residual Heat Removal Pump .....	47
1.1.11 BWR Standby Liquid Control Pump .....	52
1.1.12 Component Cooling Water Pumps .....	54
1.1.13 RHR Service Water.....	55
1.2 Turbine Driven Pumps.....	56
1.2.1 Pooled Turbine Driven Pumps .....	56
1.2.2 AFW Turbine-Driven Pumps .....	59
1.2.3 BWR High Pressure Coolant Injection and Reactor Core Isolation Cooling Pumps .....	64
1.3 Motor Operated Valves.....	68
1.3.1 Pooled Motor Operated Valve Distributions .....	68
1.3.2 PWR Containment Spray Motor Operated Valves.....	76

1.3.3	BWR Residual Heat Removal Motor-Operated Valves .....	80
1.3.4	BWR Isolation Condenser Motor-Operated Valves .....	84
1.3.5	PWR Auxiliary Feedwater Motor-Operated Valves .....	88
1.3.6	PWR High Pressure Safety Injection Motor-Operated Valves .....	95
1.3.7	PWR Residual Heat Removal Motor-Operated Valves .....	99
1.3.8	BWR High Pressure Coolant Injection and Reactor Core Isolation Cooling Motor-Operated Valves	104
1.3.9	Pressurizer PORV Motor-Operated Block Valves.....	107
1.4	Air Operated Valves .....	110
1.4.1	Pooled Air Operated Valves.....	110
1.4.2	BWR Isolation Condenser Air-Operated Valves.....	117
1.4.3	PWR Auxiliary Feedwater Air-Operated Valves.....	120
1.4.4	High Pressure Coolant Injection and Reactor Core Isolation Cooling Air Operated Valves	125
1.5	Check Valves.....	129
1.5.1	Pooled Check Valves .....	129
1.5.2	BWR Residual Heat Removal Check Valves .....	138
1.5.3	PWR Auxiliary Feedwater Check Valves .....	143
1.5.4	PWR High Pressure Safety Injection Check Valves .....	147
1.5.5	PWR Residual Heat Removal Check Valves.....	151
1.5.6	BWR High Pressure Coolant Injection/Reactor Core Isolation Cooling Check Valves	156
1.6	Strainers, Trash Racks, and Filters.....	160
1.6.1	Pooled Strainers (Non-ESW) .....	160
1.6.2	Emergency Service Water Strainers.....	162
1.6.3	Pooled Sump Strainers.....	168
1.6.4	PWR Containment Sump Strainers .....	170
1.6.5	BWR Suppression Pool Strainers .....	171
1.6.6	Extreme Environmental Event CCF Distributions .....	173
1.7	Heat Exchangers.....	181
1.7.1	PWR HEAT EXCHANGER LOSS OF HEAT TRANSFER .....	181
1.7.2	Pooled Heat Exchanger Plugged or Failure to Transfer Heat .....	182
1.7.3	Containment Spray Heat Exchanger .....	183
1.7.4	BWR Residual Heat Removal Heat Exchanger .....	184
1.7.5	BWR Isolation Condenser Heat Exchanger .....	186
1.7.6	Component Cooling Heat Exchanger .....	187
1.8	Safety and Relief Valves .....	189
1.8.1	Pooled Safety Valves.....	189
1.8.2	PWR Steam Generator Safety Valves .....	193
1.8.3	BWR Safety Relief Valves .....	197
1.8.4	PWR Pressurizer Safety Valve .....	202
1.9	PORVs.....	206
1.9.1	Pooled PORVs .....	206

1.9.2	PWR Steam Generator PORV.....	210
1.9.3	PWR Pressurizer Power Operated Relief Valves.....	215
1.10	Main Steam Isolation Valves .....	218
1.10.1	PWR Main Steam Isolation Valves .....	218
1.10.2	BWR Main Steam Isolation Valves.....	222
1.11	Generators.....	228
1.11.1	Emergency Diesel Generators .....	228
1.12	Vacuum Breakers.....	232
1.12.1	BWR Pressure Suppression Vacuum Breakers.....	232
1.13	AC Power Distribution Breakers.....	234
1.13.1	480 Vac Circuit Breakers .....	234
1.13.2	4160 vac and 6.9Kva Distribution Circuit Breakers.....	241
1.14	DC Power System - Batteries, Chargers, and Breakers.....	248
1.14.1	Batteries.....	248
1.14.2	Battery Chargers .....	250
1.14.3	DC Power Distribution Circuit Breakers.....	253
1.15	Reactor Protection System, Reactor Trip Breakers .....	261
1.15.1	Reactor Trip Breakers .....	261
2	NO DATA (PRIOR ONLY) .....	264
2.1	Generic Distributions .....	265
2.1.1	Generic Demand CCF Distribution .....	265
2.1.2	Generic Rate CCF Distribution .....	267
2.1.3	CCF Prior Distribution .....	268
3	GLOSSARY .....	271

### General CCF Information

A general conclusion from probabilistic risk assessments (PRAs) of commercial nuclear power plants is that common cause failures (CCFs) are significant contributors to the unavailability of safety systems. A CCF event consists of component failures that meet the following four criteria: (1) two or more components fail or are degraded at the same plant and in the same system, (2) component failures occur within a selected period of time such that success of the PRA mission would be uncertain, (3) the component failures result from a single shared cause and are linked by a coupling mechanism such that other components in the group are susceptible to the same cause and failure mode and, (4) the equipment failures are not caused by the failure of equipment outside the established component boundary.

In response to these deficiencies, the Idaho National Laboratory (INL) staff and the Nuclear Regulatory Commission's (NRC) Office of Nuclear Regulatory Research have developed a CCF data collection and analysis system that includes a method for identifying CCF events, coding, and classifying those events for use in CCF studies, and a computer system for storing and analyzing the data. The system is based, in part, on previous CCF methods and models and is designed to run on a personal computer (PC). The data collection effort has collected CCF events from 1980 through 2009 for use in CCF analyses. The

current data collection effort has separated the data by system. The principal products of this CCF data collection and analysis system (CCF database) are the method for identifying and classifying CCF events, the CCF database containing both CCF events and independent failure counts, and the CCF parameter estimation software.

Three data sources are used to select equipment failure reports to be reviewed for CCF event identification: the Nuclear Plant Reliability Data System (NPRDS), which contained component failure information prior to 1997; the Equipment Performance and Information Exchange (EPIX), which contains component failure information since 1997; and the Sequence Coding and Search System (SCSS), which contains Licensee Event Reports (LERs). All events that meet the above criteria are identified as CCF events and included in the CCF database.

# 1 Industry Component CCF Distributions

This section contains CCF applications created for components pooled at various levels. The first level presented is the industry-wide component specific pooled distribution. The pooled distribution represents the pooling of the more specific distributions shown under the pooled distribution. Typically, the pooling takes place across systems.

It is up to the user to decide the level of pooling that is appropriate to the intended use. If data exist at the system/component level most appropriate to the intended use, and are not sparse, it is recommended to use the more specific data. Otherwise, it is recommended to use the industry level pooled component data. If no pooled components are listed that are similar to the intended use, the use of the No Data (Prior Only) pooled distribution may be appropriate.

## 1.1 Motor Driven Pumps

### 1.1.1 Pooled Motor Driven Pump Distributions

#### 1.1.1.1 MOTOR DRIVEN PUMP FAIL TO RUN >1H ALL SYSTEMS

Component : Motor Driven Pump  
Failure Mode : Fail to run  
Start Date : 1997/01/01  
Data Version : 2009/12/31

Total Number of Independent Failure Events: 396.90

Total Number of Common-Cause Failure Events: 19

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9536190	0.9721570	0.9733550	0.9865990	0.9727060	2.5323E+02	7.2525E+00
$\alpha_2$	1.34E-02	2.78E-02	2.66E-02	4.64E-02	2.73E-02	7.2525E+00	2.5323E+02

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9547500	0.9699750	0.9707530	0.9825410	0.9704650	3.8789E+02	1.2007E+01
$\alpha_2$	9.96E-03	1.99E-02	1.91E-02	3.26E-02	1.93E-02	7.9653E+00	3.9193E+02
$\alpha_3$	3.49E-03	1.01E-02	9.30E-03	1.95E-02	1.02E-02	4.0414E+00	3.9586E+02

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9577010	0.9706080	0.9711940	0.9815200	0.9715190	5.1994E+02	1.5745E+01
$\alpha_2$	8.12E-03	1.58E-02	1.52E-02	2.56E-02	1.49E-02	8.4882E+00	5.2720E+02
$\alpha_3$	4.02E-03	9.86E-03	9.26E-03	1.78E-02	1.00E-02	5.2813E+00	5.3040E+02
$\alpha_4$	6.47E-04	3.69E-03	3.09E-03	8.77E-03	3.59E-03	1.9755E+00	5.3371E+02

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9620780	0.9728390	0.9732830	0.9820800	0.9742100	6.8625E+02	1.9159E+01
$\alpha_2$	6.34E-03	1.23E-02	1.18E-02	1.98E-02	1.08E-02	8.6636E+00	6.9675E+02
$\alpha_3$	3.51E-03	8.20E-03	7.74E-03	1.45E-02	7.93E-03	5.7817E+00	6.9963E+02
$\alpha_4$	1.75E-03	5.34E-03	4.88E-03	1.05E-02	5.60E-03	3.7664E+00	7.0164E+02
$\alpha_5$	6.01E-05	1.34E-03	9.12E-04	4.10E-03	1.45E-03	9.4768E-01	7.0446E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9650740	0.9745740	0.9749500	0.9827930	0.9762280	8.2316E+02	2.1476E+01
$\alpha_2$	5.09E-03	9.98E-03	9.60E-03	1.62E-02	8.56E-03	8.4320E+00	8.3620E+02
$\alpha_3$	2.90E-03	6.79E-03	6.41E-03	1.20E-02	6.35E-03	5.7385E+00	8.3890E+02
$\alpha_4$	1.86E-03	5.14E-03	4.75E-03	9.73E-03	5.18E-03	4.3392E+00	8.4030E+02
$\alpha_5$	6.49E-04	2.89E-03	2.51E-03	6.45E-03	3.07E-03	2.4452E+00	8.4219E+02
$\alpha_6$	3.00E-06	6.17E-04	2.91E-04	2.33E-03	6.05E-04	5.2084E-01	8.4411E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9727060	0.9704650	0.9715190	0.9742100	0.9762280
$\alpha_2$	2.73E-02	1.93E-02	1.49E-02	1.08E-02	8.56E-03
$\alpha_3$		1.02E-02	1.00E-02	7.93E-03	6.35E-03
$\alpha_4$			3.59E-03	5.60E-03	5.18E-03
$\alpha_5$				1.45E-03	3.07E-03
$\alpha_6$					6.05E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.73E-01	9.70E-01	9.72E-01	9.74E-01	9.76E-01
Beta	2.73E-02	2.95E-02	2.85E-02	2.58E-02	2.38E-02
Gamma		3.46E-01	4.77E-01	5.81E-01	6.40E-01
Delta			2.64E-01	4.70E-01	5.82E-01
Epsilon				2.05E-01	4.15E-01
Mu					1.64E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	232.11	348.16	464.21	580.26	696.32
$N_1$	10.8740	10.1795	9.5936	9.8282	9.9024
$N_2$	6.8180	7.1316	7.2601	6.5494	6.1928
$N_3$		3.7742	4.8770	4.8043	4.5967
$N_4$			1.7528	3.3920	3.7470
$N_5$				0.8754	2.2230
$N_6$					0.4376

**1.1.1.2 MOTOR DRIVEN PUMP FAIL TO START ALL SYSTEMS SPAR: MDP-FS**

Component :

Motor Driven Pump

Failure Mode :

Fail to start

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 529.80

Total Number of Common-Cause Failure Events: 22

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9621550	0.9764360	0.9772950	0.9877860	0.9769470	3.5996E+02	8.6868E+00
$\alpha_2$	1.22E-02	2.36E-02	2.27E-02	3.78E-02	2.31E-02	8.6868E+00	3.5996E+02

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9654570	0.9767740	0.9773400	0.9861720	0.9775060	5.4859E+02	1.3045E+01
$\alpha_2$	7.59E-03	1.49E-02	1.43E-02	2.42E-02	1.42E-02	8.3706E+00	5.5326E+02
$\alpha_3$	3.16E-03	8.32E-03	7.75E-03	1.55E-02	8.30E-03	4.6739E+00	5.5696E+02

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9666910	0.9764500	0.9768700	0.9847690	0.9774830	7.3301E+02	1.7678E+01
$\alpha_2$	7.74E-03	1.40E-02	1.36E-02	2.17E-02	1.32E-02	1.0495E+01	7.4019E+02
$\alpha_3$	2.44E-03	6.35E-03	5.92E-03	1.17E-02	6.21E-03	4.7679E+00	7.4592E+02
$\alpha_4$	7.13E-04	3.22E-03	2.79E-03	7.19E-03	3.12E-03	2.4155E+00	7.4827E+02

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9707900	0.9788840	0.9792140	0.9858630	0.9805240	9.5325E+02	2.0563E+01
$\alpha_2$	5.12E-03	9.63E-03	9.29E-03	1.53E-02	8.31E-03	9.3749E+00	9.6444E+02
$\alpha_3$	2.97E-03	6.58E-03	6.24E-03	1.13E-02	6.21E-03	6.4046E+00	9.6741E+02
$\alpha_4$	1.18E-03	3.71E-03	3.38E-03	7.39E-03	3.71E-03	3.6161E+00	9.7020E+02
$\alpha_5$	8.78E-05	1.20E-03	8.79E-04	3.40E-03	1.25E-03	1.1670E+00	9.7265E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9737230	0.9807670	0.9810390	0.9868760	0.9826300	1.1441E+03	2.2435E+01
$\alpha_2$	3.65E-03	7.18E-03	6.90E-03	1.17E-02	5.87E-03	8.3787E+00	1.1582E+03
$\alpha_3$	2.53E-03	5.57E-03	5.29E-03	9.56E-03	5.12E-03	6.4957E+00	1.1600E+03
$\alpha_4$	1.45E-03	3.90E-03	3.62E-03	7.30E-03	3.78E-03	4.5476E+00	1.1620E+03
$\alpha_5$	4.46E-04	2.04E-03	1.77E-03	4.59E-03	2.07E-03	2.3832E+00	1.1642E+03
$\alpha_6$	6.26E-06	5.40E-04	2.94E-04	1.91E-03	5.23E-04	6.3024E-01	1.1659E+03

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9769470	0.9775060	0.9774830	0.9805240	0.9826300
$\alpha_2$	2.31E-02	1.42E-02	1.32E-02	8.31E-03	5.87E-03
$\alpha_3$		8.30E-03	6.21E-03	6.21E-03	5.12E-03
$\alpha_4$			3.12E-03	3.71E-03	3.78E-03
$\alpha_5$				1.25E-03	2.07E-03
$\alpha_6$					5.23E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.77E-01	9.78E-01	9.77E-01	9.81E-01	9.83E-01
Beta	2.31E-02	2.25E-02	2.25E-02	1.95E-02	1.74E-02
Gamma		3.69E-01	4.14E-01	5.74E-01	6.62E-01
Delta			3.34E-01	4.44E-01	5.54E-01
Epsilon				2.52E-01	4.06E-01
Mu					2.02E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	337.45	506.18	674.90	843.63	1012.36
N <sub>1</sub>	12.2620	12.8561	11.9692	13.4597	14.7926
N <sub>2</sub>	8.2523	7.5369	9.2664	7.2607	6.1395
N <sub>3</sub>		4.4067	4.3636	5.4272	5.3539
N <sub>4</sub>			2.1928	3.2417	3.9554
N <sub>5</sub>				1.0947	2.1610
N <sub>6</sub>					0.5470

### 1.1.1.3 MOTOR DRIVEN PUMP FTR LESS THAN 1H ALL SYSTEMS

Component :

Motor Driven Pump

Failure Mode :

Fail to Run less than 1 Hour

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 48.50

Total Number of Common-Cause Failure Events: 5

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8895190	0.9505100	0.9569410	0.9894700	0.9478340	4.3556E+01	2.2678E+00
$\alpha_2$	1.05E-02	4.95E-02	4.31E-02	1.10E-01	5.22E-02	2.2678E+00	4.3556E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8965980	0.9436340	0.9472350	0.9783620	0.9313320	7.7025E+01	4.6009E+00
$\alpha_2$	1.59E-02	4.70E-02	4.33E-02	9.05E-02	5.89E-02	3.8337E+00	7.7792E+01
$\alpha_3$	2.27E-04	9.40E-03	5.81E-03	3.08E-02	9.81E-03	7.6722E-01	8.0859E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9026540	0.9422510	0.9448150	0.9730790	0.9284420	1.0777E+02	6.6051E+00
$\alpha_2$	1.53E-02	4.02E-02	3.76E-02	7.42E-02	5.08E-02	4.6031E+00	1.0977E+02
$\alpha_3$	1.64E-03	1.34E-02	1.07E-02	3.44E-02	1.69E-02	1.5293E+00	1.1285E+02
$\alpha_4$	1.20E-05	4.13E-03	1.80E-03	1.62E-02	3.77E-03	4.7267E-01	1.1390E+02

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9246090	0.9529350	0.9545910	0.9755960	0.9388120	1.7288E+02	8.5384E+00
$\alpha_2$	9.40E-03	2.50E-02	2.33E-02	4.66E-02	2.97E-02	4.5413E+00	1.7688E+02
$\alpha_3$	3.90E-03	1.53E-02	1.35E-02	3.26E-02	2.19E-02	2.7691E+00	1.7865E+02
$\alpha_4$	3.16E-04	5.68E-03	4.00E-03	1.68E-02	8.03E-03	1.0307E+00	1.8039E+02
$\alpha_5$	9.16E-10	1.09E-03	1.09E-04	5.63E-03	1.53E-03	1.9728E-01	1.8122E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9315910	0.9564090	0.9577960	0.9764850	0.9460470	2.0872E+02	9.5130E+00
$\alpha_2$	6.55E-03	1.87E-02	1.73E-02	3.59E-02	1.91E-02	4.0890E+00	2.1414E+02
$\alpha_3$	3.83E-03	1.39E-02	1.24E-02	2.89E-02	1.94E-02	3.0229E+00	2.1521E+02
$\alpha_4$	1.04E-03	7.56E-03	6.12E-03	1.90E-02	1.09E-02	1.6504E+00	2.1658E+02
$\alpha_5$	2.71E-05	2.77E-03	1.47E-03	9.93E-03	3.95E-03	6.0500E-01	2.1763E+02
$\alpha_6$	3.41E-12	6.68E-04	2.49E-05	3.70E-03	6.44E-04	1.4574E-01	2.1809E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9478340	0.9313320	0.9284420	0.9388120	0.9460470
$\alpha_2$	5.22E-02	5.89E-02	5.08E-02	2.97E-02	1.91E-02
$\alpha_3$		9.81E-03	1.69E-02	2.19E-02	1.94E-02
$\alpha_4$			3.77E-03	8.03E-03	1.09E-02
$\alpha_5$				1.53E-03	3.95E-03
$\alpha_6$					6.44E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>1-Beta</b>	9.48E-01	9.31E-01	9.28E-01	9.39E-01	9.46E-01
<b>Beta</b>	5.22E-02	6.87E-02	7.16E-02	6.12E-02	5.40E-02
<b>Gamma</b>		1.43E-01	2.89E-01	5.15E-01	6.47E-01
<b>Delta</b>			1.82E-01	3.04E-01	4.44E-01
<b>Epsilon</b>				1.60E-01	2.96E-01
<b>Mu</b>					1.40E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>Adj. Ind. Events</b>	30.31	45.47	60.63	75.78	90.94
<b>N<sub>1</sub></b>	3.0000	2.0000	1.0000	0.9375	0.8438
<b>N<sub>2</sub></b>	1.8333	3.0000	3.3750	2.4271	1.8498
<b>N<sub>3</sub></b>		0.5000	1.1250	1.7917	1.8811
<b>N<sub>4</sub></b>			0.2500	0.6563	1.0582
<b>N<sub>5</sub></b>				0.1250	0.3828
<b>N<sub>6</sub></b>					0.0625

**1.1.1.4 MOTOR DRIVEN PUMP FAIL TO RUN ALL SYSTEMS SPAR: MDP-FR**

**Component :** Motor Driven Pump  
**Failure Mode :** Fail to run  
**Start Date :** Fail to Run less than 1 Hour  
**Data Version :** 1997/01/01  
**2009/12/31**

Total Number of Independent Failure Events: 445.40

Total Number of Common-Cause Failure Events: 24

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9513570	0.9693830	0.9704350	0.9838250	0.9697590	2.8767E+02	9.0858E+00
$\alpha_2$	1.62E-02	3.06E-02	2.96E-02	4.86E-02	3.02E-02	9.0858E+00	2.8767E+02

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9506120	0.9657370	0.9664240	0.9785220	0.9658560	4.3706E+02	1.5506E+01
$\alpha_2$	1.37E-02	2.42E-02	2.35E-02	3.72E-02	2.40E-02	1.0965E+01	4.4160E+02
$\alpha_3$	3.74E-03	1.00E-02	9.32E-03	1.88E-02	1.01E-02	4.5414E+00	4.4802E+02

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9531700	0.9660860	0.9666030	0.9772530	0.9664950	5.8383E+02	2.0495E+01
$\alpha_2$	1.13E-02	1.96E-02	1.91E-02	2.97E-02	1.91E-02	1.1863E+01	5.9246E+02
$\alpha_3$	4.79E-03	1.06E-02	1.01E-02	1.82E-02	1.08E-02	6.4063E+00	5.9792E+02
$\alpha_4$	7.45E-04	3.68E-03	3.15E-03	8.43E-03	3.60E-03	2.2255E+00	6.0210E+02

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9587190	0.9694170	0.9698090	0.9787650	0.9701260	7.6581E+02	2.4160E+01
$\alpha_2$	7.93E-03	1.40E-02	1.36E-02	2.15E-02	1.30E-02	1.1091E+01	7.7888E+02
$\alpha_3$	4.67E-03	9.59E-03	9.18E-03	1.59E-02	9.56E-03	7.5733E+00	7.8240E+02
$\alpha_4$	2.05E-03	5.60E-03	5.19E-03	1.06E-02	5.86E-03	4.4226E+00	7.8555E+02
$\alpha_5$	8.26E-05	1.36E-03	9.68E-04	3.97E-03	1.45E-03	1.0727E+00	7.8890E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9623400	0.9717360	0.9720720	0.9799940	0.9727710	9.1834E+02	2.6710E+01
$\alpha_2$	5.98E-03	1.09E-02	1.05E-02	1.70E-02	9.76E-03	1.0282E+01	9.3477E+02
$\alpha_3$	3.94E-03	8.06E-03	7.72E-03	1.34E-02	7.86E-03	7.6196E+00	9.3743E+02
$\alpha_4$	2.36E-03	5.71E-03	5.37E-03	1.02E-02	5.83E-03	5.3974E+00	9.3965E+02
$\alpha_5$	7.75E-04	2.99E-03	2.65E-03	6.38E-03	3.16E-03	2.8281E+00	9.4222E+02
$\alpha_6$	5.14E-06	6.17E-04	3.18E-04	2.24E-03	6.07E-04	5.8334E-01	9.4447E+02

#### **ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9697590	0.9658560	0.9664950	0.9701260	0.9727710
$\alpha_2$	3.02E-02	2.40E-02	1.91E-02	1.30E-02	9.76E-03
$\alpha_3$		1.01E-02	1.08E-02	9.56E-03	7.86E-03
$\alpha_4$			3.60E-03	5.86E-03	5.83E-03
$\alpha_5$				1.45E-03	3.16E-03
$\alpha_6$					6.07E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.70E-01	9.66E-01	9.66E-01	9.70E-01	9.73E-01
Beta	3.02E-02	3.41E-02	3.35E-02	2.99E-02	2.72E-02
Gamma		2.97E-01	4.29E-01	5.65E-01	6.41E-01
Delta			2.50E-01	4.34E-01	5.50E-01
Epsilon				1.98E-01	3.93E-01
Mu					1.61E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	263.55	395.33	527.10	658.88	790.65
$N_1$	13.8740	12.1795	10.5936	10.7657	10.7462
$N_2$	8.6513	10.1316	10.6351	8.9764	8.0427
$N_3$		4.2742	6.0020	6.5959	6.4778
$N_4$			2.0028	4.0482	4.8052
$N_5$				1.0004	2.6059
$N_6$					0.5001

### **1.1.2 Pooled Pump Volutes**

#### **1.1.2.1 CLEAN SYSTEM PUMP VOLUTES FAIL TO RUN SPAR: PMP-FR**

<b>System :</b>	Chemical and volume control Component cooling water Auxiliary feedwater Containment spray recirculation Low pressure core spray Residual Heat Removal (LCI in BWRs, LPI in PWRs) Standby liquid control
<b>Component :</b>	Motor Driven Pump
<b>Failure Mode :</b>	Fail to run Fail to Run less than 1 Hour
<b>Subcomponent :</b>	Pump
<b>Start Date :</b>	1997/01/01
<b>Data Version :</b>	2009/12/31

Total Number of Independent Failure Events: 93.50

Total Number of Common-Cause Failure Events: 3

### ALPHA FACTOR DISTRIBUTIONS

#### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9561580	0.9812630	0.9841340	0.9965600	0.9836570	1.0655E+02	2.0345E+00
$\alpha_2$	3.44E-03	1.87E-02	1.59E-02	4.38E-02	1.63E-02	2.0345E+00	1.0655E+02

#### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9613840	0.9808310	0.9826170	0.9941700	0.9843520	1.7299E+02	3.3809E+00
$\alpha_2$	2.89E-03	1.33E-02	1.16E-02	2.99E-02	1.04E-02	2.3537E+00	1.7402E+02
$\alpha_3$	3.21E-04	5.82E-03	4.09E-03	1.72E-02	5.22E-03	1.0272E+00	1.7534E+02

#### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9637160	0.9803030	0.9816130	0.9924100	0.9850090	2.3655E+02	4.7531E+00
$\alpha_2$	2.81E-03	1.12E-02	9.93E-03	2.42E-02	7.69E-03	2.7141E+00	2.3859E+02
$\alpha_3$	6.57E-04	5.97E-03	4.67E-03	1.57E-02	5.36E-03	1.4403E+00	2.3986E+02
$\alpha_4$	2.32E-05	2.48E-03	1.31E-03	8.92E-03	1.95E-03	5.9867E-01	2.4070E+02

### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9836570	0.9843520	0.9850090
$\alpha_2$	1.63E-02	1.04E-02	7.69E-03
$\alpha_3$		5.22E-03	5.36E-03
$\alpha_4$			1.95E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.84E-01	9.84E-01	9.85E-01
Beta	1.63E-02	1.56E-02	1.50E-02
Gamma		3.33E-01	4.87E-01
Delta			2.66E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	93.50	140.25	187.00
$N_1$	2.8000	3.1800	3.4160
$N_2$	1.6000	1.5200	1.4860
$N_3$		0.7600	1.0360
$N_4$			0.3760

### 1.1.3 Pooled Clean System Motor Driven Pump Distributions

#### 1.1.3.1 CLEAN SYSTEM MOTOR DRIVEN PUMPS FAIL TO RUN SPAR: MDP-FR

System :

Chemical and volume control  
 Component cooling water  
 Auxiliary feedwater  
 Containment spray recirculation  
 High pressure core spray  
 High pressure coolant injection  
 High pressure injection  
 Low pressure core spray  
 Reactor core isolation  
 Residual Heat Removal (LCI in BWRs, LPI in PWRs)  
 Standby liquid control

Component :

Motor Driven Pump

Failure Mode :

Fail to run

Fail to Run less than 1 Hour

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 230.60

Total Number of Common-Cause Failure Events: 11

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9501720	0.9723860	0.9740710	0.9888460	0.9731850	1.8023E+02	5.1182E+00
$\alpha_2$	1.12E-02	2.76E-02	2.59E-02	4.98E-02	2.68E-02	5.1182E+00	1.8023E+02

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9520280	0.9701200	0.9711970	0.9845260	0.9708360	2.8025E+02	8.6319E+00
$\alpha_2$	9.36E-03	2.11E-02	2.00E-02	3.67E-02	2.04E-02	6.1047E+00	2.8278E+02
$\alpha_3$	2.04E-03	8.75E-03	7.64E-03	1.92E-02	8.75E-03	2.5272E+00	2.8635E+02

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9569570	0.9719430	0.9727510	0.9841870	0.9734330	3.7835E+02	1.0922E+01
$\alpha_2$	6.69E-03	1.53E-02	1.45E-02	2.68E-02	1.39E-02	5.9661E+00	3.8331E+02
$\alpha_3$	2.95E-03	9.27E-03	8.44E-03	1.84E-02	9.38E-03	3.6070E+00	3.8566E+02
$\alpha_4$	3.39E-04	3.46E-03	2.66E-03	9.34E-03	3.30E-03	1.3487E+00	3.8792E+02

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9620040	0.9742990	0.9749030	0.9845460	0.9766000	5.1036E+02	1.3463E+01
$\alpha_2$	4.95E-03	1.14E-02	1.07E-02	1.99E-02	9.05E-03	5.9530E+00	5.1787E+02
$\alpha_3$	3.04E-03	8.36E-03	7.74E-03	1.58E-02	8.02E-03	4.3779E+00	5.1944E+02
$\alpha_4$	1.09E-03	4.77E-03	4.15E-03	1.05E-02	5.00E-03	2.4970E+00	5.2133E+02
$\alpha_5$	1.45E-05	1.21E-03	6.64E-04	4.27E-03	1.33E-03	6.3488E-01	5.2319E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9653440	0.9761380	0.9766390	0.9852180	0.9788730	6.1304E+02	1.4986E+01
$\alpha_2$	3.78E-03	8.95E-03	8.43E-03	1.59E-02	6.67E-03	5.6206E+00	6.2241E+02
$\alpha_3$	2.41E-03	6.76E-03	6.24E-03	1.29E-02	6.12E-03	4.2444E+00	6.2378E+02
$\alpha_4$	1.47E-03	5.10E-03	4.58E-03	1.05E-02	5.15E-03	3.2027E+00	6.2482E+02
$\alpha_5$	3.08E-04	2.47E-03	1.97E-03	6.36E-03	2.63E-03	1.5538E+00	6.2647E+02
$\alpha_6$	3.12E-07	5.80E-04	1.88E-04	2.49E-03	5.55E-04	3.6454E-01	6.2766E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9731850	0.9708360	0.9734330	0.9766000	0.9788730
$\alpha_2$	2.68E-02	2.04E-02	1.39E-02	9.05E-03	6.67E-03
$\alpha_3$		8.75E-03	9.38E-03	8.02E-03	6.12E-03
$\alpha_4$			3.30E-03	5.00E-03	5.15E-03
$\alpha_5$				1.33E-03	2.63E-03
$\alpha_6$					5.55E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.73E-01	9.71E-01	9.73E-01	9.77E-01	9.79E-01
Beta	2.68E-02	2.92E-02	2.66E-02	2.34E-02	2.11E-02
Gamma		3.00E-01	4.77E-01	6.13E-01	6.84E-01
Delta			2.60E-01	4.41E-01	5.76E-01
Epsilon				2.10E-01	3.82E-01
Mu					1.74E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	163.55	245.32	327.09	408.87	490.64
$N_1$	6.4327	5.3780	5.1231	5.3317	5.4585
$N_2$	4.6837	5.2710	4.7380	3.8388	3.3814
$N_3$		2.2600	3.2027	3.4005	3.1026
$N_4$			1.1260	2.1226	2.6105
$N_5$				0.5626	1.3316
$N_6$					0.2813

**1.1.3.2 CLEAN SYSTEM MOTOR DRIVEN PUMPS FAIL TO START SPAR: MDP-FS**

System :

Chemical and volume control  
 Component cooling water  
 Auxiliary feedwater  
 Containment spray recirculation  
 High pressure core spray  
 High pressure coolant injection  
 High pressure injection  
 Low pressure core spray  
 Reactor core isolation  
 Residual Heat Removal (LCI in BWRs, LPI in PWRs)  
 Standby liquid control

Component :

Motor Driven Pump

Failure Mode :

Fail to start

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 364.50

Total Number of Common-Cause Failure Events: 14

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9580120	0.9745110	0.9755580	0.9874440	0.9750700	2.9303E+02	7.6645E+00
$\alpha_2$	1.26E-02	2.55E-02	2.44E-02	4.20E-02	2.49E-02	7.6645E+00	2.9303E+02

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9654940	0.9778190	0.9785100	0.9877930	0.9787970	4.5087E+02	1.0228E+01
$\alpha_2$	5.24E-03	1.23E-02	1.16E-02	2.18E-02	1.13E-02	5.6787E+00	4.5542E+02
$\alpha_3$	3.69E-03	9.87E-03	9.17E-03	1.84E-02	9.95E-03	4.5489E+00	4.5655E+02

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9679760	0.9783860	0.9789030	0.9870420	0.9798210	6.0472E+02	1.3359E+01
$\alpha_2$	5.32E-03	1.13E-02	1.08E-02	1.91E-02	1.01E-02	6.9894E+00	6.1109E+02
$\alpha_3$	2.23E-03	6.50E-03	5.97E-03	1.26E-02	6.34E-03	4.0167E+00	6.1406E+02
$\alpha_4$	8.20E-04	3.81E-03	3.29E-03	8.57E-03	3.74E-03	2.3530E+00	6.1573E+02

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9717650	0.9803920	0.9807840	0.9876770	0.9826230	7.9337E+02	1.5868E+01
$\alpha_2$	3.80E-03	8.26E-03	7.86E-03	1.41E-02	6.44E-03	6.6839E+00	8.0255E+02
$\alpha_3$	2.32E-03	5.98E-03	5.58E-03	1.10E-02	5.44E-03	4.8384E+00	8.0440E+02
$\alpha_4$	1.15E-03	3.97E-03	3.57E-03	8.15E-03	4.00E-03	3.2099E+00	8.0603E+02
$\alpha_5$	9.70E-05	1.40E-03	1.02E-03	4.02E-03	1.50E-03	1.1357E+00	8.0810E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9745530	0.9820770	0.9824050	0.9884700	0.9845580	9.5265E+02	1.7386E+01
$\alpha_2$	2.81E-03	6.35E-03	6.01E-03	1.10E-02	4.62E-03	6.1598E+00	9.6388E+02
$\alpha_3$	1.87E-03	4.89E-03	4.56E-03	9.06E-03	4.24E-03	4.7449E+00	9.6529E+02
$\alpha_4$	1.24E-03	3.82E-03	3.48E-03	7.54E-03	3.66E-03	3.7019E+00	9.6633E+02
$\alpha_5$	4.37E-04	2.23E-03	1.90E-03	5.16E-03	2.29E-03	2.1645E+00	9.6787E+02
$\alpha_6$	6.61E-06	6.34E-04	3.39E-04	2.26E-03	6.26E-04	6.1464E-01	9.6942E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9750700	0.9787970	0.9798210	0.9826230	0.9845580
$\alpha_2$	2.49E-02	1.13E-02	1.01E-02	6.44E-03	4.62E-03
$\alpha_3$		9.95E-03	6.34E-03	5.44E-03	4.24E-03
$\alpha_4$			3.74E-03	4.00E-03	3.66E-03
$\alpha_5$				1.50E-03	2.29E-03
$\alpha_6$					6.26E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.75E-01	9.79E-01	9.80E-01	9.83E-01	9.85E-01
Beta	2.49E-02	2.12E-02	2.02E-02	1.74E-02	1.54E-02
Gamma		4.69E-01	4.99E-01	6.29E-01	7.01E-01
Delta			3.71E-01	5.02E-01	6.08E-01
Epsilon				2.73E-01	4.43E-01
Mu					2.15E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	276.14	414.20	552.27	690.34	828.41
$N_1$	6.6400	7.1150	6.3171	6.8643	7.3041
$N_2$	7.2300	4.8450	5.7613	4.5697	3.9206
$N_3$		4.2817	3.6124	3.8610	3.6031
$N_4$			2.1303	2.8355	3.1097
$N_5$				1.0634	1.9423
$N_6$					0.5314

### 1.1.4 PWR Containment Spray Pumps

#### 1.1.4.1 CONTAINMENT SPRAY MDP-FS

System :	Containment spray recirculation
Component :	Motor Driven Pump
Failure Mode :	Fail to start
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 27.00

Total Number of Common-Cause Failure Events: 3

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8709140	0.9403200	0.9472680	0.9859180	0.9337640	3.9146E+01	2.4845E+00
$\alpha_2$	1.41E-02	5.97E-02	5.27E-02	1.29E-01	6.62E-02	2.4845E+00	3.9146E+01

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
$\alpha_1$	0.9337640
$\alpha_2$	6.62E-02

MGL Parameter	CCCG=2
1-Beta	9.34E-01
Beta	6.62E-02

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	27.00
N <sub>1</sub>	1.9000
N <sub>2</sub>	2.0500

#### 1.1.4.2 CONTAINMENT SPRAY FTR LESS THAN 1H MDP-FH

System :	Containment spray recirculation
Component :	Motor Driven Pump
Failure Mode :	Fail to Run less than 1 Hour
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 7.00

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9017830	0.9754240	0.9898730	0.9999510	1.0000000	1.7246E+01	4.3452E-01
$\alpha_2$	4.52E-05	2.46E-02	1.01E-02	9.82E-02	0.00E+00	4.3452E-01	1.7246E+01

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
$\alpha_1$	1.0000000
$\alpha_2$	0.00E+00

MGL Parameter	CCCG=2
1-Beta	1.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	7.00
N <sub>1</sub>	0.0000
N <sub>2</sub>	0.0000

#### **1.1.4.3 CONTAINMENT SPRAY >1H MDP-FR**

System : Containment spray recirculation  
 Component : Motor Driven Pump  
 Failure Mode : Fail to run  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 7.20

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9028690	0.9756990	0.9899910	0.9999520	1.0000000	1.7446E+01	4.3452E-01
$\alpha_2$	4.47E-05	2.43E-02	1.00E-02	9.71E-02	0.00E+00	4.3452E-01	1.7446E+01

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
$\alpha_1$	1.0000000
$\alpha_2$	0.00E+00

<b>MGL Parameter</b>	<b>CCCG=2</b>
<b>1-Beta</b>	1.00E+00
<b>Beta</b>	0.00E+00

<b>Avg. Impact Vector</b>	<b>CCCG=2</b>
<b>Adj. Ind. Events</b>	7.20
<b>N<sub>1</sub></b>	0.0000
<b>N<sub>2</sub></b>	0.0000

#### 1.1.4.4 CONTAINMENT SPRAY MDP-FTR LESS THAN AND > 1 HOUR

**System :** Containment spray recirculation  
**Component :** Motor Driven Pump  
**Failure Mode :**  
Fail to run  
Fail to Run less than 1 Hour  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 14.20

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9299850	0.9825360	0.9928840	0.9999650	1.0000000	2.4446E+01	4.3452E-01
$\alpha_2$	3.18E-05	1.75E-02	7.12E-03	7.00E-02	0.00E+00	4.3452E-01	2.4446E+01

#### ALPHA FACTOR and MGL PARAMETERS

<b>Alpha Factor</b>	<b>CCCG=2</b>
$\alpha_1$	1.0000000
$\alpha_2$	0.00E+00

<b>MGL Parameter</b>	<b>CCCG=2</b>
<b>1-Beta</b>	1.00E+00
<b>Beta</b>	0.00E+00

<b>Avg. Impact Vector</b>	<b>CCCG=2</b>
<b>Adj. Ind. Events</b>	14.20
<b>N<sub>1</sub></b>	0.0000
<b>N<sub>2</sub></b>	0.0000

## 1.1.5 BWR Residual Heat Removal Pumps

### 1.1.5.1 BWR RHR MDP FAIL TO RUN >1H

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Driven Pump
Failure Mode :	Fail to run
Op. Mode :	CCF Event Can Only Happen During Power Operation CCF Event May Occur During Both Power Operation & Shutdown
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 6.50

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8989610	0.9747090	0.9895680	0.9999500	1.0000000	1.6746E+01	4.3452E-01
$\alpha_2$	4.66E-05	2.53E-02	1.04E-02	1.01E-01	0.00E+00	4.3452E-01	1.6746E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9154810	0.9703710	0.9783290	0.9980400	1.0000000	3.6055E+01	1.1009E+00
$\alpha_2$	7.15E-04	2.24E-02	1.46E-02	7.09E-02	0.00E+00	8.3366E-01	3.6322E+01
$\alpha_3$	2.53E-07	7.19E-03	1.45E-03	3.41E-02	0.00E+00	2.6722E-01	3.6889E+01

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9185670	0.9659560	0.9714920	0.9943870	1.0000000	5.2636E+01	1.8551E+00
$\alpha_2$	1.87E-03	2.25E-02	1.70E-02	6.21E-02	0.00E+00	1.2281E+00	5.3263E+01
$\alpha_3$	8.37E-06	7.42E-03	2.76E-03	3.06E-02	0.00E+00	4.0431E-01	5.4087E+01
$\alpha_4$	1.77E-08	4.09E-03	5.60E-04	2.05E-02	0.00E+00	2.2267E-01	5.4268E+01

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	6.50	6.50	6.50
N <sub>1</sub>	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000
N <sub>4</sub>			0.0000

### 1.1.5.2 BWR RHR MDP FAIL TO START

**System :** Residual Heat Removal (LCI in BWRs, LPI in PWRs)  
**Component :** Motor Driven Pump  
**Failure Mode :** Fail to start  
**Op. Mode :** CCF Event Can Only Happen During Power Operation  
                   CCF Event May Occur During Both Power Operation & Shutdown  
**Plant Type :** BWR  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 29.00

Total Number of Common-Cause Failure Events: 2

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9072350	0.9714000	0.9820270	0.9992880	0.9793830	2.6079E+01	7.6782E-01
$\alpha_2$	7.09E-04	2.86E-02	1.80E-02	9.28E-02	2.06E-02	7.6782E-01	2.6079E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9113340	0.9613840	0.9669040	0.9925270	0.9578950	5.2305E+01	2.1009E+00
$\alpha_2$	5.47E-03	3.37E-02	2.82E-02	8.09E-02	4.21E-02	1.8337E+00	5.2572E+01
$\alpha_3$	1.72E-07	4.91E-03	9.88E-04	2.33E-02	0.00E+00	2.6722E-01	5.4139E+01

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9061160	0.9511960	0.9549680	0.9833790	0.9354840	7.5136E+01	3.8551E+00
$\alpha_2$	1.21E-02	4.09E-02	3.70E-02	8.27E-02	6.45E-02	3.2281E+00	7.5763E+01
$\alpha_3$	5.75E-06	5.12E-03	1.89E-03	2.12E-02	0.00E+00	4.0431E-01	7.8587E+01
$\alpha_4$	1.21E-08	2.82E-03	3.85E-04	1.41E-02	0.00E+00	2.2267E-01	7.8768E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9793830	0.9578950	0.9354840
$\alpha_2$	2.06E-02	4.21E-02	6.45E-02
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.79E-01	9.58E-01	9.35E-01
Beta	2.06E-02	4.21E-02	6.45E-02
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	14.50	21.75	29.00
$N_1$	1.3333	1.0000	0.0000
$N_2$	0.3333	1.0000	2.0000
$N_3$		0.0000	0.0000
$N_4$			0.0000

### 1.1.5.3 BWR RHR MDP FTR LESS THAN 1H

**System :** Residual Heat Removal (LCI in BWRs, LPI in PWRs)  
**Component :** Motor Driven Pump  
**Failure Mode :** Fail to Run less than 1 Hour  
**Op. Mode :**  
**Plant Type :** BWR  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 1.00

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS**

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8522320	0.9628000	0.9843830	0.9999320	1.0000000	1.1246E+01	4.3452E-01
$\alpha_2$	7.00E-05	3.72E-02	1.56E-02	1.48E-01	0.00E+00	4.3452E-01	1.1246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9010680	0.9652240	0.9744830	0.9976820	1.0000000	3.0555E+01	1.1009E+00
$\alpha_2$	8.43E-04	2.63E-02	1.72E-02	8.30E-02	0.00E+00	8.3366E-01	3.0822E+01
$\alpha_3$	2.98E-07	8.44E-03	1.71E-03	4.00E-02	0.00E+00	2.6722E-01	3.1389E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9095820	0.9621340	0.9682530	0.9937390	1.0000000	4.7136E+01	1.8551E+00
$\alpha_2$	2.09E-03	2.51E-02	1.89E-02	6.90E-02	0.00E+00	1.2281E+00	4.7763E+01
$\alpha_3$	9.32E-06	8.25E-03	3.07E-03	3.41E-02	0.00E+00	4.0431E-01	4.8587E+01
$\alpha_4$	1.97E-08	4.55E-03	6.24E-04	2.28E-02	0.00E+00	2.2267E-01	4.8768E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	1.00	1.00	1.00
N <sub>1</sub>	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000
N <sub>4</sub>			0.0000

#### 1.1.5.4 BWR RHR MDP FAIL TO RUN

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Driven Pump
Failure Mode :	Fail to run
Op. Mode :	Fail to Run less than 1 Hour CCF Event Can Only Happen During Power Operation CCF Event May Occur During Both Power Operation & Shutdown
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 7.50

Total Number of Common-Cause Failure Events: 0

### ALPHA FACTOR DISTRIBUTIONS

#### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9044540	0.9761000	0.9901620	0.9999520	1.0000000	1.7746E+01	4.3452E-01
$\alpha_2$	4.39E-05	2.39E-02	9.84E-03	9.55E-02	0.00E+00	4.3452E-01	1.7746E+01

#### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9176630	0.9711480	0.9789060	0.9980930	1.0000000	3.7055E+01	1.1009E+00
$\alpha_2$	6.96E-04	2.18E-02	1.42E-02	6.91E-02	0.00E+00	8.3366E-01	3.7322E+01
$\alpha_3$	2.46E-07	7.00E-03	1.42E-03	3.32E-02	0.00E+00	2.6722E-01	3.7889E+01

#### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9200060	0.9665700	0.9720120	0.9944910	1.0000000	5.3636E+01	1.8551E+00
$\alpha_2$	1.84E-03	2.21E-02	1.67E-02	6.10E-02	0.00E+00	1.2281E+00	5.4263E+01
$\alpha_3$	8.22E-06	7.29E-03	2.71E-03	3.01E-02	0.00E+00	4.0431E-01	5.5087E+01
$\alpha_4$	1.73E-08	4.01E-03	5.50E-04	2.01E-02	0.00E+00	2.2267E-01	5.5268E+01

### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	7.50	7.50	7.50
$N_1$	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000
$N_4$			0.0000

## 1.1.6 AFW Motor-Driven Pumps

### 1.1.6.1 AFW MOTOR DRIVEN PUMP FAIL TO RUN >1H SPAR: AFW-MDP-FR

System : Auxiliary feedwater  
 Component : Motor Driven Pump  
 Failure Mode : Fail to run  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 10.70

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9148040	0.9770400	0.9886290	0.9998640	0.9920630	2.2746E+01	5.3452E-01
$\alpha_2$	1.31E-04	2.30E-02	1.14E-02	8.52E-02	7.94E-03	5.3452E-01	2.2746E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9261640	0.9720550	0.9781480	0.9970940	0.9850750	4.8035E+01	1.3809E+00
$\alpha_2$	1.48E-03	2.23E-02	1.63E-02	6.39E-02	1.44E-02	1.1037E+00	4.8312E+01
$\alpha_3$	2.86E-07	5.61E-03	1.21E-03	2.63E-02	5.33E-04	2.7722E-01	4.9139E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9276090	0.9673480	0.9715320	0.9927630	0.9789440	7.0452E+01	2.3781E+00
$\alpha_2$	3.45E-03	2.35E-02	1.93E-02	5.80E-02	1.96E-02	1.7141E+00	7.1116E+01
$\alpha_3$	1.17E-05	6.05E-03	2.46E-03	2.42E-02	1.45E-03	4.4031E-01	7.2390E+01
$\alpha_4$	1.40E-08	3.07E-03	4.24E-04	1.54E-02	4.03E-05	2.2367E-01	7.2606E+01

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9920630	0.9850750	0.9789440
$\alpha_2$	7.94E-03	1.44E-02	1.96E-02
$\alpha_3$		5.33E-04	1.45E-03
$\alpha_4$			4.03E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.92E-01	9.85E-01	9.79E-01
Beta	7.94E-03	1.49E-02	2.11E-02
Gamma		3.57E-02	7.07E-02
Delta			2.70E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	10.70	16.05	21.40
N <sub>1</sub>	1.8000	2.4300	2.9160
N <sub>2</sub>	0.1000	0.2700	0.4860
N <sub>3</sub>		0.0100	0.0360
N <sub>4</sub>			0.0010

### 1.1.6.2 AFW MOTOR DRIVEN PUMP FAIL TO START SPAR: AFW-MDP-FS

System : Auxiliary feedwater  
 Component : Motor Driven Pump  
 Failure Mode : Fail to start  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 32.70

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9367870	0.9791780	0.9857590	0.9990810	0.9853800	4.3946E+01	9.3452E-01
$\alpha_2$	9.16E-04	2.08E-02	1.42E-02	6.32E-02	1.46E-02	9.3452E-01	4.3946E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9404360	0.9742080	0.9779890	0.9950520	0.9803150	7.9355E+01	2.1009E+00
$\alpha_2$	2.53E-03	1.94E-02	1.57E-02	4.93E-02	1.48E-02	1.5837E+00	7.9872E+01
$\alpha_3$	3.00E-05	6.35E-03	3.00E-03	2.40E-02	4.92E-03	5.1722E-01	8.0939E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9430200	0.9719780	0.9746670	0.9917490	0.9795620	1.1204E+02	3.2301E+00
$\alpha_2$	3.04E-03	1.72E-02	1.45E-02	4.05E-02	1.11E-02	1.9781E+00	1.1329E+02
$\alpha_3$	3.11E-04	7.85E-03	5.24E-03	2.43E-02	7.43E-03	9.0431E-01	1.1437E+02
$\alpha_4$	1.14E-06	3.02E-03	9.22E-04	1.31E-02	1.86E-03	3.4767E-01	1.1492E+02

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9853800	0.9803150	0.9795620
$\alpha_2$	1.46E-02	1.48E-02	1.11E-02
$\alpha_3$		4.92E-03	7.43E-03
$\alpha_4$			1.86E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.85E-01	9.80E-01	9.80E-01
Beta	1.46E-02	1.97E-02	2.04E-02
Gamma		2.50E-01	4.55E-01
Delta			2.00E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	32.70	49.05	65.40
N <sub>1</sub>	1.0000	0.7500	0.5000
N <sub>2</sub>	0.5000	0.7500	0.7500
N <sub>3</sub>		0.2500	0.5000
N <sub>4</sub>			0.1250

### 1.1.6.3 AFW MOTOR DRIVEN PUMP FTR LESS THAN 1H SPAR: AFW-MDP-FH

System :

Auxiliary feedwater

Component :

Motor Driven Pump

Failure Mode :

Fail to Run less than 1 Hour

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 4.50

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8464560	0.9563200	0.9758650	0.9995580	0.9459360	1.3163E+01	6.0122E-01
$\alpha_2$	4.40E-04	4.37E-02	2.41E-02	1.54E-01	5.41E-02	6.0122E-01	1.3163E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8860440	0.9543060	0.9626900	0.9938400	0.8858450	3.3435E+01	1.6009E+00
$\alpha_2$	3.75E-03	3.81E-02	2.96E-02	1.01E-01	1.14E-01	1.3337E+00	3.3702E+01
$\alpha_3$	2.68E-07	7.63E-03	1.54E-03	3.62E-02	0.00E+00	2.6722E-01	3.4769E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8887760	0.9466250	0.9521160	0.9856650	0.8181820	5.0636E+01	2.8551E+00
$\alpha_2$	8.65E-03	4.17E-02	3.61E-02	9.38E-02	1.82E-01	2.2281E+00	5.1263E+01
$\alpha_3$	8.53E-06	7.56E-03	2.81E-03	3.12E-02	0.00E+00	4.0431E-01	5.3087E+01
$\alpha_4$	1.80E-08	4.16E-03	5.71E-04	2.09E-02	0.00E+00	2.2267E-01	5.3268E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9459360	0.8858450	0.8181820
$\alpha_2$	5.41E-02	1.14E-01	1.82E-01
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.46E-01	8.86E-01	8.18E-01
Beta	5.41E-02	1.14E-01	1.82E-01
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	2.25	3.38	4.50
N <sub>1</sub>	0.6667	0.5000	0.0000
N <sub>2</sub>	0.1667	0.5000	1.0000
N <sub>3</sub>		0.0000	0.0000
N <sub>4</sub>			0.0000

#### 1.1.6.4 AFW MOTOR DRIVEN PUMP FAIL TO RUN

**System :** Auxiliary feedwater  
**Component :** Motor Driven Pump  
**Failure Mode :** Fail to run  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31  
**Total Number of Independent Failure Events:** 15.20  
**Total Number of Common-Cause Failure Events:** 2

**ALPHA FACTOR DISTRIBUTIONS**

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9002390	0.9702170	0.9821610	0.9994570	0.9792670	2.2843E+01	7.0122E-01
$\alpha_2$	5.40E-04	2.98E-02	1.78E-02	9.98E-02	2.07E-02	7.0122E-01	2.2843E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9097840	0.9620520	0.9681020	0.9936090	0.9587520	4.7685E+01	1.8809E+00
$\alpha_2$	4.33E-03	3.24E-02	2.63E-02	8.12E-02	4.07E-02	1.6037E+00	4.7962E+01
$\alpha_3$	2.85E-07	5.59E-03	1.21E-03	2.62E-02	5.29E-04	2.7722E-01	4.9289E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9073350	0.9535340	0.9576410	0.9856740	0.9383630	6.9322E+01	3.3781E+00
$\alpha_2$	9.48E-03	3.73E-02	3.32E-02	7.95E-02	6.01E-02	2.7141E+00	6.9986E+01
$\alpha_3$	1.17E-05	6.06E-03	2.46E-03	2.43E-02	1.46E-03	4.4031E-01	7.2260E+01
$\alpha_4$	1.40E-08	3.08E-03	4.25E-04	1.54E-02	4.05E-05	2.2367E-01	7.2476E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9792670	0.9587520	0.9383630
$\alpha_2$	2.07E-02	4.07E-02	6.01E-02
$\alpha_3$		5.29E-04	1.46E-03
$\alpha_4$			4.05E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.79E-01	9.59E-01	9.38E-01
Beta	2.07E-02	4.12E-02	6.16E-02
Gamma		1.28E-02	2.43E-02
Delta			2.70E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	10.13	15.20	20.27
N <sub>1</sub>	2.4667	2.9300	2.9160
N <sub>2</sub>	0.2667	0.7700	1.4860
N <sub>3</sub>		0.0100	0.0360
N <sub>4</sub>			0.0010

**1.1.7 AFW Pump Volutes****1.1.7.1 AFW PUMP VOLUTES (MDP,TDP,EDP) FAIL TO RUN SPAR: AFW-PMP-FR**

System :

Auxiliary feedwater

Component :

Motor Driven Pump

Turbine Driven Pump

Failure Mode :

Fail to run

Fail to Run less than 1 Hour

Subcomponent :

Pump

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 18.60

Total Number of Common-Cause Failure Events: 1

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9362050	0.9828570	0.9915700	0.9999050	0.9951220	3.0646E+01	5.3452E-01
$\alpha_2$	9.71E-05	1.71E-02	8.43E-03	6.38E-02	4.88E-03	5.3452E-01	3.0646E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9402880	0.9774600	0.9824210	0.9976660	0.9908530	5.9885E+01	1.3809E+00
$\alpha_2$	1.19E-03	1.80E-02	1.31E-02	5.17E-02	8.82E-03	1.1037E+00	6.0162E+01
$\alpha_3$	2.30E-07	4.52E-03	9.73E-04	2.12E-02	3.27E-04	2.7722E-01	6.0989E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9403620	0.9731680	0.9766490	0.9940690	0.9871310	8.6252E+01	2.3781E+00
$\alpha_2$	2.83E-03	1.93E-02	1.59E-02	4.78E-02	1.20E-02	1.7141E+00	8.6916E+01
$\alpha_3$	9.59E-06	4.97E-03	2.02E-03	1.99E-02	8.86E-04	4.4031E-01	8.8190E+01
$\alpha_4$	1.15E-08	2.52E-03	3.48E-04	1.26E-02	2.46E-05	2.2367E-01	8.8406E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9951220	0.9908530	0.9871310
$\alpha_2$	4.88E-03	8.82E-03	1.20E-02
$\alpha_3$		3.27E-04	8.86E-04
$\alpha_4$			2.46E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.95E-01	9.91E-01	9.87E-01
Beta	4.88E-03	9.15E-03	1.29E-02
Gamma		3.57E-02	7.07E-02
Delta			2.70E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	18.60	27.90	37.20
$N_1$	1.8000	2.4300	2.9160
$N_2$	0.1000	0.2700	0.4860
$N_3$		0.0100	0.0360
$N_4$			0.0010

## 1.1.8 Emergency Service Water Pump

### 1.1.8.1 NORMALLY RUNNING SERVICE WATER MDP FAIL TO RUN

**System :** Normally operating service water  
**Component :** Motor Driven Pump  
**Failure Mode :** Fail to run  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 96.20

Total Number of Common-Cause Failure Events: 5

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9282020	0.9709400	0.9761610	0.9958060	0.9735560	5.6449E+01	1.6895E+00
$\alpha_2$	4.19E-03	2.91E-02	2.38E-02	7.18E-02	2.64E-02	1.6895E+00	5.6449E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9405340	0.9717670	0.9748280	0.9925370	0.9751150	9.8113E+01	2.8505E+00
$\alpha_2$	2.00E-03	1.56E-02	1.25E-02	3.97E-02	1.06E-02	1.5755E+00	9.9388E+01
$\alpha_3$	1.12E-03	1.26E-02	9.59E-03	3.45E-02	1.43E-02	1.2750E+00	9.9688E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9447950	0.9710890	0.9732920	0.9898610	0.9761180	1.3691E+02	4.0761E+00
$\alpha_2$	3.44E-03	1.63E-02	1.41E-02	3.67E-02	1.15E-02	2.2961E+00	1.3869E+02
$\alpha_3$	4.42E-04	7.49E-03	5.33E-03	2.19E-02	7.01E-03	1.0563E+00	1.3993E+02
$\alpha_4$	1.01E-04	5.13E-03	3.06E-03	1.72E-02	5.39E-03	7.2367E-01	1.4026E+02

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9499370	0.9708930	0.9723370	0.9869090	0.9763980	2.0901E+02	6.2661E+00
$\alpha_2$	5.05E-03	1.62E-02	1.47E-02	3.24E-02	1.19E-02	3.4915E+00	2.1178E+02
$\alpha_3$	8.82E-04	7.16E-03	5.70E-03	1.84E-02	4.88E-03	1.5410E+00	2.1374E+02
$\alpha_4$	1.71E-04	4.23E-03	2.83E-03	1.31E-02	4.64E-03	9.1109E-01	2.1436E+02
$\alpha_5$	3.04E-07	1.50E-03	4.10E-04	6.69E-03	2.16E-03	3.2248E-01	2.1495E+02

##### CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9519930	0.9709340	0.9721350	0.9857690	0.9764050	2.5172E+02	7.5355E+00
$\alpha_2$	5.11E-03	1.51E-02	1.39E-02	2.93E-02	1.21E-02	3.9110E+00	2.5534E+02
$\alpha_3$	9.96E-04	6.72E-03	5.50E-03	1.66E-02	4.35E-03	1.7418E+00	2.5751E+02
$\alpha_4$	2.49E-04	4.12E-03	2.94E-03	1.20E-02	3.45E-03	1.0684E+00	2.5819E+02
$\alpha_5$	2.30E-05	2.34E-03	1.24E-03	8.37E-03	2.78E-03	6.0610E-01	2.5865E+02
$\alpha_6$	1.43E-09	8.03E-04	9.28E-05	4.10E-03	9.06E-04	2.0824E-01	2.5905E+02

#### **ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9735560	0.9751150	0.9761180	0.9763980	0.9764050
$\alpha_2$	2.64E-02	1.06E-02	1.15E-02	1.19E-02	1.21E-02
$\alpha_3$		1.43E-02	7.01E-03	4.88E-03	4.35E-03
$\alpha_4$			5.39E-03	4.64E-03	3.45E-03
$\alpha_5$				2.16E-03	2.78E-03
$\alpha_6$					9.06E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.74E-01	9.75E-01	9.76E-01	9.76E-01	9.76E-01
Beta	2.64E-02	2.49E-02	2.39E-02	2.36E-02	2.36E-02
Gamma		5.76E-01	5.19E-01	4.95E-01	4.87E-01
Delta			4.35E-01	5.83E-01	6.21E-01
Epsilon				3.18E-01	5.17E-01
Mu					2.46E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	43.73	65.59	87.45	109.32	131.18
$N_1$	2.4733	2.9683	3.3290	3.5279	3.5985
$N_2$	1.2550	0.7418	1.0680	1.3773	1.6718
$N_3$		1.0078	0.6520	0.5636	0.6000
$N_4$			0.5010	0.5367	0.4762
$N_5$				0.2502	0.3839
$N_6$					0.1250

#### **1.1.8.2 NORMALLY RUNNING SERVICE WATER MDP FAIL TO START**

System : Normally operating service water  
 Component : Motor Driven Pump  
 Failure Mode : Fail to start  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 67.60

Total Number of Common-Cause Failure Events: 5

#### **ALPHA FACTOR DISTRIBUTIONS**

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9474230	0.9825890	0.9880190	0.9991930	0.9882290	5.3802E+01	9.5332E-01
$\alpha_2$	8.04E-04	1.74E-02	1.20E-02	5.26E-02	1.18E-02	9.5332E-01	5.3802E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9444980	0.9749570	0.9781790	0.9944040	0.9800470	9.3717E+01	2.4072E+00
$\alpha_2$	3.81E-03	2.10E-02	1.77E-02	4.91E-02	1.80E-02	2.0150E+00	9.4109E+01
$\alpha_3$	3.73E-06	4.08E-03	1.46E-03	1.70E-02	1.91E-03	3.9222E-01	9.5732E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9413690	0.9691280	0.9714240	0.9890260	0.9734450	1.3036E+02	4.1527E+00
$\alpha_2$	6.99E-03	2.39E-02	2.16E-02	4.87E-02	2.29E-02	3.2119E+00	1.3130E+02
$\alpha_3$	6.65E-05	4.87E-03	2.74E-03	1.69E-02	2.90E-03	6.5561E-01	1.3386E+02
$\alpha_4$	1.41E-07	2.12E-03	4.77E-04	9.85E-03	7.22E-04	2.8517E-01	1.3423E+02

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9484360	0.9700880	0.9715870	0.9866160	0.9752610	2.0099E+02	6.1974E+00
$\alpha_2$	6.24E-03	1.86E-02	1.71E-02	3.62E-02	1.62E-02	3.8528E+00	2.0333E+02
$\alpha_3$	1.19E-03	8.25E-03	6.73E-03	2.05E-02	6.82E-03	1.7103E+00	2.0548E+02
$\alpha_4$	1.37E-05	2.56E-03	1.23E-03	9.62E-03	1.45E-03	5.3069E-01	2.0666E+02
$\alpha_5$	8.10E-16	5.00E-04	3.66E-06	2.90E-03	2.91E-04	1.0358E-01	2.0708E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9515000	0.9708550	0.9721020	0.9859480	0.9766630	2.4233E+02	7.2748E+00
$\alpha_2$	5.13E-03	1.54E-02	1.41E-02	3.00E-02	1.24E-02	3.8351E+00	2.4577E+02
$\alpha_3$	1.55E-03	8.31E-03	7.03E-03	1.94E-02	7.25E-03	2.0731E+00	2.4753E+02
$\alpha_4$	1.73E-04	3.81E-03	2.60E-03	1.16E-02	2.80E-03	9.5172E-01	2.4865E+02
$\alpha_5$	2.16E-07	1.27E-03	3.36E-04	5.69E-03	7.31E-04	3.1600E-01	2.4929E+02
$\alpha_6$	1.67E-16	3.96E-04	2.19E-06	2.30E-03	1.22E-04	9.8837E-02	2.4951E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9882290	0.9800470	0.9734450	0.9752610	0.9766630
$\alpha_2$	1.18E-02	1.80E-02	2.29E-02	1.62E-02	1.24E-02
$\alpha_3$		1.91E-03	2.90E-03	6.82E-03	7.25E-03
$\alpha_4$			7.22E-04	1.45E-03	2.80E-03
$\alpha_5$				2.91E-04	7.31E-04
$\alpha_6$					1.22E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>1-Beta</b>	9.88E-01	9.80E-01	9.73E-01	9.75E-01	9.77E-01
<b>Beta</b>	1.18E-02	2.00E-02	2.66E-02	2.47E-02	2.33E-02
<b>Gamma</b>		9.57E-02	1.37E-01	3.46E-01	4.67E-01
<b>Delta</b>			1.99E-01	2.04E-01	3.35E-01
<b>Epsilon</b>				1.67E-01	2.33E-01
<b>Mu</b>					1.43E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>Adj. Ind. Events</b>	39.76	59.65	79.53	99.41	119.29
<b>N<sub>1</sub></b>	3.7958	4.5125	4.6950	5.4168	6.0957
<b>N<sub>2</sub></b>	0.5188	1.1813	1.9838	1.7386	1.5959
<b>N<sub>3</sub></b>		0.1250	0.2513	0.7329	0.9313
<b>N<sub>4</sub></b>			0.0625	0.1563	0.3595
<b>N<sub>5</sub></b>				0.0313	0.0938
<b>N<sub>6</sub></b>					0.0156

### 1.1.8.3 STANDBY SERVICE WATER MDP FAIL TO RUN

**System :** Standby service water  
**Component :** Motor Driven Pump  
**Failure Mode :** Fail to run  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 38.60

Total Number of Common-Cause Failure Events: 4

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8904930	0.9589700	0.9681340	0.9960600	0.9587970	3.0707E+01	1.3138E+00
$\alpha_2$	3.94E-03	4.10E-02	3.19E-02	1.10E-01	4.12E-02	1.3138E+00	3.0707E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8944970	0.9476400	0.9524300	0.9843920	0.9313530	5.8388E+01	3.2261E+00
$\alpha_2$	1.11E-02	4.39E-02	3.90E-02	9.32E-02	6.04E-02	2.7025E+00	5.8912E+01
$\alpha_3$	4.29E-05	8.50E-03	4.07E-03	3.20E-02	8.28E-03	5.2362E-01	6.1090E+01

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8968450	0.9423710	0.9456960	0.9765290	0.9197190	8.3107E+01	5.0823E+00
$\alpha_2$	1.21E-02	3.89E-02	3.55E-02	7.75E-02	5.48E-02	3.4322E+00	8.4757E+01
$\alpha_3$	1.77E-03	1.62E-02	1.27E-02	4.25E-02	2.54E-02	1.4266E+00	8.6763E+01
$\alpha_4$	1.14E-08	2.53E-03	3.49E-04	1.27E-02	1.99E-05	2.2347E-01	8.7966E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9226360	0.9538460	0.9558670	0.9781610	0.9323230	1.4223E+02	6.8822E+00
$\alpha_2$	8.26E-03	2.51E-02	2.30E-02	4.91E-02	3.29E-02	3.7391E+00	1.4537E+02
$\alpha_3$	2.48E-03	1.36E-02	1.15E-02	3.19E-02	2.12E-02	2.0260E+00	1.4709E+02
$\alpha_4$	4.02E-04	7.01E-03	4.96E-03	2.06E-02	1.36E-02	1.0447E+00	1.4807E+02
$\alpha_5$	4.23E-21	4.85E-04	2.77E-07	2.81E-03	2.02E-06	7.2377E-02	1.4904E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9296400	0.9570110	0.9586990	0.9786190	0.9410970	1.7209E+02	7.7303E+00
$\alpha_2$	6.02E-03	1.94E-02	1.76E-02	3.87E-02	2.12E-02	3.4796E+00	1.7634E+02
$\alpha_3$	2.53E-03	1.24E-02	1.06E-02	2.83E-02	1.86E-02	2.2303E+00	1.7759E+02
$\alpha_4$	6.18E-04	7.06E-03	5.34E-03	1.94E-02	1.16E-02	1.2699E+00	1.7855E+02
$\alpha_5$	5.41E-05	3.71E-03	2.10E-03	1.28E-02	7.60E-03	6.6730E-01	1.7915E+02
$\alpha_6$	7.83E-19	4.63E-04	8.09E-07	2.70E-03	0.00E+00	8.3237E-02	1.7974E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9587970	0.9313530	0.9197190	0.9323230	0.9410970
$\alpha_2$	4.12E-02	6.04E-02	5.48E-02	3.29E-02	2.12E-02
$\alpha_3$		8.28E-03	2.54E-02	2.12E-02	1.86E-02
$\alpha_4$			1.99E-05	1.36E-02	1.16E-02
$\alpha_5$				2.02E-06	7.60E-03
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>1-Beta</b>	9.59E-01	9.31E-01	9.20E-01	9.32E-01	9.41E-01
<b>Beta</b>	4.12E-02	6.86E-02	8.03E-02	6.77E-02	5.89E-02
<b>Gamma</b>		1.21E-01	3.17E-01	5.14E-01	6.41E-01
<b>Delta</b>			7.82E-04	3.90E-01	5.08E-01
<b>Epsilon</b>				1.49E-04	3.96E-01
<b>Mu</b>					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>Adj. Ind. Events</b>	18.16	27.25	36.33	45.41	54.49
<b>N<sub>1</sub></b>	2.3013	1.5832	0.6415	0.6561	0.6580
<b>N<sub>2</sub></b>	0.8793	1.8688	2.2041	1.6249	1.2404
<b>N<sub>3</sub></b>		0.2564	1.0223	1.0486	1.0885
<b>N<sub>4</sub></b>			0.0008	0.6703	0.6777
<b>N<sub>5</sub></b>				0.0001	0.4451
<b>N<sub>6</sub></b>					0.0000

### 1.1.8.4 STANDBY SERVICE WATER MDP FAIL TO START

System : Standby service water  
 Component : Motor Driven Pump  
 Failure Mode : Fail to start  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 68.20

Total Number of Common-Cause Failure Events: 3

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9295020	0.9767160	0.9840230	0.9989600	0.9829920	3.9352E+01	9.3812E-01
$\alpha_2$	1.04E-03	2.33E-02	1.60E-02	7.05E-02	1.70E-02	9.3812E-01	3.9352E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9243000	0.9648580	0.9689530	0.9914150	0.9653980	7.1704E+01	2.6116E+00
$\alpha_2$	6.88E-03	3.15E-02	2.74E-02	7.03E-02	3.46E-02	2.3444E+00	7.1971E+01
$\alpha_3$	1.25E-07	3.60E-03	7.21E-04	1.71E-02	0.00E+00	2.6722E-01	7.4048E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9291230	0.9632650	0.9661560	0.9875120	0.9648690	1.0165E+02	3.8765E+00
$\alpha_2$	6.65E-03	2.61E-02	2.31E-02	5.55E-02	2.64E-02	2.7495E+00	1.0278E+02
$\alpha_3$	3.40E-04	8.57E-03	5.73E-03	2.65E-02	8.69E-03	9.0431E-01	1.0462E+02
$\alpha_4$	9.07E-09	2.11E-03	2.88E-04	1.06E-02	0.00E+00	2.2267E-01	1.0530E+02

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9424990	0.9674250	0.9692300	0.9861850	0.9714950	1.6554E+02	5.5740E+00
$\alpha_2$	5.03E-03	1.79E-02	1.61E-02	3.71E-02	1.33E-02	3.0666E+00	1.6805E+02
$\alpha_3$	1.66E-03	1.06E-02	8.74E-03	2.58E-02	1.17E-02	1.8107E+00	1.6930E+02
$\alpha_4$	4.08E-05	3.65E-03	1.98E-03	1.29E-02	3.50E-03	6.2439E-01	1.7049E+02
$\alpha_5$	3.48E-21	4.22E-04	2.38E-07	2.44E-03	0.00E+00	7.2277E-02	1.7104E+02

##### CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9474090	0.9693360	0.9708380	0.9861240	0.9759220	2.0017E+02	6.3321E+00
$\alpha_2$	3.65E-03	1.39E-02	1.23E-02	2.93E-02	7.30E-03	2.8622E+00	2.0364E+02
$\alpha_3$	1.66E-03	9.50E-03	7.97E-03	2.26E-02	9.61E-03	1.9612E+00	2.0454E+02
$\alpha_4$	3.23E-04	5.22E-03	3.74E-03	1.52E-02	5.70E-03	1.0783E+00	2.0542E+02
$\alpha_5$	6.25E-07	1.68E-03	5.12E-04	7.33E-03	1.47E-03	3.4720E-01	2.0615E+02
$\alpha_6$	6.82E-19	4.03E-04	7.04E-07	2.35E-03	0.00E+00	8.3237E-02	2.0642E+02

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9829920	0.9653980	0.9648690	0.9714950	0.9759220
$\alpha_2$	1.70E-02	3.46E-02	2.64E-02	1.33E-02	7.30E-03
$\alpha_3$		0.00E+00	8.69E-03	1.17E-02	9.61E-03
$\alpha_4$			0.00E+00	3.50E-03	5.70E-03
$\alpha_5$				0.00E+00	1.47E-03
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.83E-01	9.65E-01	9.65E-01	9.71E-01	9.76E-01
Beta	1.70E-02	3.46E-02	3.51E-02	2.85E-02	2.41E-02
Gamma		0.00E+00	2.47E-01	5.32E-01	6.97E-01
Delta			0.00E+00	2.31E-01	4.27E-01
Epsilon				0.00E+00	2.05E-01
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	27.28	40.92	54.56	68.20	81.84
$N_1$	1.8262	1.2286	0.9571	1.1786	1.3929
$N_2$	0.5036	1.5107	1.5214	0.9524	0.6230
$N_3$		0.0000	0.5000	0.8333	0.8194
$N_4$			0.0000	0.2500	0.4861
$N_5$				0.0000	0.1250
$N_6$					0.0000

#### **1.1.8.5 SERVICE WATER MDP FAIL TO RUN SPAR:ESW-MDP-FR**

**System :** Normally operating service water  
Standby service water

**Component :** Motor Driven Pump

**Failure Mode :** Fail to run

**Start Date :** 1997/01/01

**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 134.80

Total Number of Common-Cause Failure Events: 9

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9302750	0.9678300	0.9716560	0.9922770	0.9691440	7.7281E+01	2.5688E+00
$\alpha_2$	7.72E-03	3.22E-02	2.83E-02	6.97E-02	3.09E-02	2.5688E+00	7.7281E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9319800	0.9624410	0.9647460	0.9850180	0.9619430	1.2750E+02	4.9757E+00
$\alpha_2$	8.05E-03	2.60E-02	2.36E-02	5.20E-02	2.56E-02	3.4443E+00	1.2903E+02
$\alpha_3$	1.42E-03	1.16E-02	9.21E-03	2.97E-02	1.24E-02	1.5314E+00	1.3094E+02

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9334560	0.9598600	0.9615330	0.9805360	0.9593260	1.7464E+02	7.3033E+00
$\alpha_2$	9.24E-03	2.47E-02	2.30E-02	4.61E-02	2.44E-02	4.5002E+00	1.7744E+02
$\alpha_3$	2.14E-03	1.14E-02	9.69E-03	2.66E-02	1.25E-02	2.0786E+00	1.7986E+02
$\alpha_4$	7.86E-05	3.98E-03	2.37E-03	1.34E-02	3.75E-03	7.2447E-01	1.8122E+02

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9432340	0.9638210	0.9649780	0.9804540	0.9634050	2.5601E+02	9.6100E+00
$\alpha_2$	7.75E-03	1.93E-02	1.81E-02	3.49E-02	1.81E-02	5.1165E+00	2.6050E+02
$\alpha_3$	2.33E-03	9.75E-03	8.55E-03	2.13E-02	9.72E-03	2.5896E+00	2.6303E+02
$\alpha_4$	7.64E-04	5.95E-03	4.77E-03	1.52E-02	7.27E-03	1.5813E+00	2.6404E+02
$\alpha_5$	2.47E-07	1.21E-03	3.32E-04	5.42E-03	1.51E-03	3.2258E-01	2.6530E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9472870	0.9655550	0.9665220	0.9805090	0.9660770	3.0799E+02	1.0987E+01
$\alpha_2$	6.52E-03	1.61E-02	1.51E-02	2.92E-02	1.47E-02	5.1513E+00	3.1383E+02
$\alpha_3$	2.31E-03	8.87E-03	7.87E-03	1.89E-02	8.54E-03	2.8303E+00	3.1615E+02
$\alpha_4$	8.14E-04	5.47E-03	4.48E-03	1.35E-02	5.83E-03	1.7460E+00	3.1723E+02
$\alpha_5$	1.91E-04	3.30E-03	2.33E-03	9.68E-03	4.19E-03	1.0512E+00	3.1793E+02
$\alpha_6$	1.17E-09	6.53E-04	7.54E-05	3.33E-03	6.32E-04	2.0824E-01	3.1877E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9691440	0.9619430	0.9593260	0.9634050	0.9660770
$\alpha_2$	3.09E-02	2.56E-02	2.44E-02	1.81E-02	1.47E-02
$\alpha_3$		1.24E-02	1.25E-02	9.72E-03	8.54E-03
$\alpha_4$			3.75E-03	7.27E-03	5.83E-03
$\alpha_5$				1.51E-03	4.19E-03
$\alpha_6$					6.32E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>1-Beta</b>	9.69E-01	9.62E-01	9.59E-01	9.63E-01	9.66E-01
<b>Beta</b>	3.09E-02	3.81E-02	4.07E-02	3.66E-02	3.39E-02
<b>Gamma</b>		3.26E-01	3.99E-01	5.06E-01	5.66E-01
<b>Delta</b>			2.31E-01	4.75E-01	5.55E-01
<b>Epsilon</b>				1.72E-01	4.53E-01
<b>Mu</b>					1.31E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>Adj. Ind. Events</b>	62.26	93.39	124.53	155.66	186.79
<b>N<sub>1</sub></b>	4.7747	4.5515	3.9705	4.1840	4.2564
<b>N<sub>2</sub></b>	2.1343	2.6106	3.2721	3.0023	2.9121
<b>N<sub>3</sub></b>		1.2642	1.6743	1.6122	1.6885
<b>N<sub>4</sub></b>			0.5018	1.2069	1.1538
<b>N<sub>5</sub></b>				0.2503	0.8290
<b>N<sub>6</sub></b>					0.1250

### 1.1.8.6 SERVICE WATER MDP FAIL TO RUN SPAR:ESW-MDP-FS

System :

Normally operating service water

Standby service water

Component :

Motor Driven Pump

Failure Mode :

Fail to start

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 135.80

Total Number of Common-Cause Failure Events: 8

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9554040	0.9829060	0.9865170	0.9980620	0.9862860	8.3768E+01	1.4568E+00
$\alpha_2$	1.93E-03	1.71E-02	1.35E-02	4.46E-02	1.37E-02	1.4568E+00	8.3768E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9463910	0.9722270	0.9744320	0.9905270	0.9744860	1.3715E+02	3.9179E+00
$\alpha_2$	7.88E-03	2.50E-02	2.28E-02	4.97E-02	2.44E-02	3.5257E+00	1.3754E+02
$\alpha_3$	2.53E-06	2.78E-03	9.90E-04	1.16E-02	1.13E-03	3.9222E-01	1.4068E+02

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9450510	0.9681360	0.9697330	0.9857540	0.9703710	1.8759E+02	6.1741E+00
$\alpha_2$	9.41E-03	2.44E-02	2.28E-02	4.50E-02	2.40E-02	4.7333E+00	1.8903E+02
$\alpha_3$	4.30E-04	5.96E-03	4.37E-03	1.69E-02	5.15E-03	1.1556E+00	1.9261E+02
$\alpha_4$	9.80E-08	1.47E-03	3.30E-04	6.84E-03	4.29E-04	2.8517E-01	1.9348E+02

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9524580	0.9706740	0.9717830	0.9850990	0.9740680	2.7251E+02	8.2331E+00
$\alpha_2$	6.63E-03	1.71E-02	1.60E-02	3.15E-02	1.49E-02	4.8052E+00	2.7594E+02
$\alpha_3$	2.12E-03	9.06E-03	7.92E-03	1.99E-02	8.65E-03	2.5436E+00	2.7820E+02
$\alpha_4$	7.06E-05	2.78E-03	1.72E-03	9.09E-03	2.24E-03	7.8069E-01	2.7996E+02
$\alpha_5$	5.98E-16	3.69E-04	2.70E-06	2.14E-03	1.73E-04	1.0358E-01	2.8064E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9562830	0.9723570	0.9732830	0.9852590	0.9766480	3.2813E+02	9.3283E+00
$\alpha_2$	4.88E-03	1.32E-02	1.23E-02	2.48E-02	1.03E-02	4.4581E+00	3.3300E+02
$\alpha_3$	2.27E-03	8.57E-03	7.62E-03	1.81E-02	8.10E-03	2.8926E+00	3.3457E+02
$\alpha_4$	4.67E-04	4.26E-03	3.33E-03	1.12E-02	3.91E-03	1.4378E+00	3.3602E+02
$\alpha_5$	2.53E-06	1.31E-03	5.28E-04	5.25E-03	1.01E-03	4.4100E-01	3.3702E+02
$\alpha_6$	1.24E-16	2.93E-04	1.62E-06	1.70E-03	7.21E-05	9.8837E-02	3.3736E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9862860	0.9744860	0.9703710	0.9740680	0.9766480
$\alpha_2$	1.37E-02	2.44E-02	2.40E-02	1.49E-02	1.03E-02
$\alpha_3$		1.13E-03	5.15E-03	8.65E-03	8.10E-03
$\alpha_4$			4.29E-04	2.24E-03	3.91E-03
$\alpha_5$				1.73E-04	1.01E-03
$\alpha_6$					7.21E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>1-Beta</b>	9.86E-01	9.74E-01	9.70E-01	9.74E-01	9.77E-01
<b>Beta</b>	1.37E-02	2.55E-02	2.96E-02	2.59E-02	2.34E-02
<b>Gamma</b>		4.44E-02	1.88E-01	4.27E-01	5.61E-01
<b>Delta</b>			7.68E-02	2.18E-01	3.82E-01
<b>Epsilon</b>				7.15E-02	2.17E-01
<b>Mu</b>					6.66E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>Adj. Ind. Events</b>	67.90	101.85	135.80	169.75	203.70
<b>N<sub>1</sub></b>	5.6220	5.7411	5.6521	6.5954	7.4886
<b>N<sub>2</sub></b>	1.0223	2.6920	3.5052	2.6910	2.2189
<b>N<sub>3</sub></b>		0.1250	0.7513	1.5662	1.7508
<b>N<sub>4</sub></b>			0.0625	0.4063	0.8456
<b>N<sub>5</sub></b>				0.0313	0.2188
<b>N<sub>6</sub></b>					0.0156

### 1.1.9 PWR High Pressure Safety Injection Pump

#### 1.1.9.1 HIGH PRESSURE INJECTION MOTOR DRIVEN PUMP FAIL TO RUN >1H

System :

Chemical and volume control

High pressure injection

Component :

Motor Driven Pump

Failure Mode :

Fail to run

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 112.40

Total Number of Common-Cause Failure Events: 4

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9532550	0.9798070	0.9827980	0.9961400	0.9821490	1.0197E+02	2.1015E+00
$\alpha_2$	3.86E-03	2.02E-02	1.72E-02	4.67E-02	1.79E-02	2.1015E+00	1.0197E+02

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9579530	0.9787480	0.9806010	0.9932010	0.9819850	1.6588E+02	3.6019E+00
$\alpha_2$	3.65E-03	1.53E-02	1.34E-02	3.32E-02	1.26E-02	2.5847E+00	1.6690E+02
$\alpha_3$	3.23E-04	6.00E-03	4.20E-03	1.78E-02	5.40E-03	1.0172E+00	1.6846E+02

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9614210	0.9788920	0.9802510	0.9917140	0.9834660	2.2718E+02	4.8988E+00
$\alpha_2$	2.96E-03	1.18E-02	1.04E-02	2.53E-02	8.16E-03	2.7301E+00	2.2935E+02
$\alpha_3$	8.60E-04	6.77E-03	5.41E-03	1.73E-02	6.34E-03	1.5710E+00	2.3051E+02
$\alpha_4$	2.39E-05	2.58E-03	1.36E-03	9.27E-03	2.04E-03	5.9767E-01	2.3148E+02

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9821490	0.9819850	0.9834660
$\alpha_2$	1.79E-02	1.26E-02	8.16E-03
$\alpha_3$		5.40E-03	6.34E-03
$\alpha_4$			2.04E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.82E-01	9.82E-01	9.83E-01
Beta	1.79E-02	1.80E-02	1.65E-02
Gamma		3.00E-01	5.07E-01
Delta			2.43E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	89.92	134.88	179.84
N <sub>1</sub>	1.7993	1.4480	1.2071
N <sub>2</sub>	1.6670	1.7510	1.5020
N <sub>3</sub>		0.7500	1.1667
N <sub>4</sub>			0.3750

### 1.1.9.2 HIGH PRESSURE INJECTION MOTOR DRIVEN PUMP FAIL TO START

System : Chemical and volume control

High pressure injection

Component : Motor Driven Pump

Failure Mode : Fail to run

Start Date : 1997/01/01

Data Version : 2009/12/31

Total Number of Independent Failure Events: 112.40

Total Number of Common-Cause Failure Events: 4

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9532550	0.9798070	0.9827980	0.9961400	0.9821490	1.0197E+02	2.1015E+00
$\alpha_2$	3.86E-03	2.02E-02	1.72E-02	4.67E-02	1.79E-02	2.1015E+00	1.0197E+02

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9579530	0.9787480	0.9806010	0.9932010	0.9819850	1.6588E+02	3.6019E+00
$\alpha_2$	3.65E-03	1.53E-02	1.34E-02	3.32E-02	1.26E-02	2.5847E+00	1.6690E+02
$\alpha_3$	3.23E-04	6.00E-03	4.20E-03	1.78E-02	5.40E-03	1.0172E+00	1.6846E+02

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9614210	0.9788920	0.9802510	0.9917140	0.9834660	2.2718E+02	4.8988E+00
$\alpha_2$	2.96E-03	1.18E-02	1.04E-02	2.53E-02	8.16E-03	2.7301E+00	2.2935E+02
$\alpha_3$	8.60E-04	6.77E-03	5.41E-03	1.73E-02	6.34E-03	1.5710E+00	2.3051E+02
$\alpha_4$	2.39E-05	2.58E-03	1.36E-03	9.27E-03	2.04E-03	5.9767E-01	2.3148E+02

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9821490	0.9819850	0.9834660
$\alpha_2$	1.79E-02	1.26E-02	8.16E-03
$\alpha_3$		5.40E-03	6.34E-03
$\alpha_4$			2.04E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.82E-01	9.82E-01	9.83E-01
Beta	1.79E-02	1.80E-02	1.65E-02
Gamma		3.00E-01	5.07E-01
Delta			2.43E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	89.92	134.88	179.84
N <sub>1</sub>	1.7993	1.4480	1.2071
N <sub>2</sub>	1.6670	1.7510	1.5020
N <sub>3</sub>		0.7500	1.1667
N <sub>4</sub>			0.3750

### 1.1.9.3 HIGH PRESSURE INJECTION MOTOR DRIVEN PUMP FTR LESS THAN 1H

System :

Chemical and volume control

High pressure injection

Motor Driven Pump

Component :

Fail to Run less than 1 Hour

Failure Mode :

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 8.50

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8577160	0.9557470	0.9718050	0.9988850	0.9500300	1.6583E+01	7.6782E-01
$\alpha_2$	1.12E-03	4.43E-02	2.82E-02	1.42E-01	5.00E-02	7.6782E-01	1.6583E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8806230	0.9476810	0.9549650	0.9897820	0.8947370	3.8055E+01	2.1009E+00
$\alpha_2$	7.48E-03	4.57E-02	3.83E-02	1.09E-01	1.05E-01	1.8337E+00	3.8322E+01
$\alpha_3$	2.34E-07	6.65E-03	1.34E-03	3.16E-02	0.00E+00	2.6722E-01	3.9889E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9011240	0.9526690	0.9576020	0.9873310	0.9188970	5.7466E+01	2.8551E+00
$\alpha_2$	4.27E-03	2.86E-02	2.36E-02	7.03E-02	4.06E-02	1.7281E+00	5.8593E+01
$\alpha_3$	5.99E-04	1.50E-02	1.01E-02	4.62E-02	4.06E-02	9.0431E-01	5.9417E+01
$\alpha_4$	1.59E-08	3.69E-03	5.06E-04	1.85E-02	0.00E+00	2.2267E-01	6.0098E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9500300	0.8947370	0.9188970
$\alpha_2$	5.00E-02	1.05E-01	4.06E-02
$\alpha_3$		0.00E+00	4.06E-02
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.50E-01	8.95E-01	9.19E-01
Beta	5.00E-02	1.05E-01	8.11E-02
Gamma		0.00E+00	5.00E-01
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	5.67	8.50	11.33
N <sub>1</sub>	0.6667	0.0000	0.0000
N <sub>2</sub>	0.3333	1.0000	0.5000
N <sub>3</sub>		0.0000	0.5000
N <sub>4</sub>			0.0000

**1.1.9.4 HIGH PRESSURE INJECTION MOTOR DRIVEN PUMP FAIL TO RUN**

System :

Chemical and volume control

High pressure injection

Component :

Motor Driven Pump

Failure Mode :

Fail to run

Fail to Run less than 1 Hour

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 120.90

Total Number of Common-Cause Failure Events: 5

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9502190	0.9774860	0.9803650	0.9949170	0.9794770	1.0571E+02	2.4348E+00
$\alpha_2$	5.09E-03	2.25E-02	1.96E-02	4.98E-02	2.05E-02	2.4348E+00	1.0571E+02

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9512970	0.9737190	0.9755050	0.9900400	0.9757630	1.7050E+02	4.6019E+00
$\alpha_2$	6.52E-03	2.05E-02	1.87E-02	4.06E-02	1.90E-02	3.5847E+00	1.7152E+02
$\alpha_3$	3.13E-04	5.81E-03	4.07E-03	1.72E-02	5.19E-03	1.0172E+00	1.7408E+02

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9569440	0.9753440	0.9766600	0.9892600	0.9788570	2.3334E+02	5.8988E+00
$\alpha_2$	3.95E-03	1.35E-02	1.22E-02	2.76E-02	1.05E-02	3.2301E+00	2.3601E+02
$\alpha_3$	1.62E-03	8.66E-03	7.33E-03	2.02E-02	8.71E-03	2.0710E+00	2.3717E+02
$\alpha_4$	2.32E-05	2.50E-03	1.31E-03	8.99E-03	1.96E-03	5.9767E-01	2.3864E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9794770	0.9757630	0.9788570
$\alpha_2$	2.05E-02	1.90E-02	1.05E-02
$\alpha_3$		5.19E-03	8.71E-03
$\alpha_4$			1.96E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.79E-01	9.76E-01	9.79E-01
Beta	2.05E-02	2.42E-02	2.11E-02
Gamma		2.14E-01	5.05E-01
Delta			1.84E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	93.00	139.50	186.00
$N_1$	2.4660	1.4480	1.2071
$N_2$	2.0003	2.7510	2.0020
$N_3$		0.7500	1.6667
$N_4$			0.3750

### 1.1.10PWR Residual Heat Removal Pump

#### 1.1.10.1 PWR RHR MDP FAIL TO RUN >1H

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Driven Pump
Failure Mode :	Fail to run
Op. Mode :	CCF Event Can Only Happen During Power Operation CCF Event May Occur During Both Power Operation & Shutdown
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 10.10

Total Number of Common-Cause Failure Events: 0

### ALPHA FACTOR DISTRIBUTIONS

#### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9163020	0.9790900	0.9914310	0.9999580	1.0000000	2.0346E+01	4.3452E-01
$\alpha_2$	3.82E-05	2.09E-02	8.57E-03	8.37E-02	0.00E+00	4.3452E-01	2.0346E+01

#### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9228410	0.9729880	0.9802740	0.9982170	1.0000000	3.9655E+01	1.1009E+00
$\alpha_2$	6.50E-04	2.05E-02	1.33E-02	6.47E-02	0.00E+00	8.3366E-01	3.9922E+01
$\alpha_3$	2.30E-07	6.56E-03	1.32E-03	3.11E-02	0.00E+00	2.6722E-01	4.0489E+01

#### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9235390	0.9680660	0.9732830	0.9947430	1.0000000	5.6236E+01	1.8551E+00
$\alpha_2$	1.75E-03	2.11E-02	1.59E-02	5.83E-02	0.00E+00	1.2281E+00	5.6863E+01
$\alpha_3$	7.85E-06	6.96E-03	2.58E-03	2.87E-02	0.00E+00	4.0431E-01	5.7687E+01
$\alpha_4$	1.66E-08	3.83E-03	5.25E-04	1.92E-02	0.00E+00	2.2267E-01	5.7868E+01

### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	10.10	10.10	10.10
$N_1$	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000
$N_4$			0.0000

**Motor** Driven Pumps  
**PWR** Residual Heat Removal Pump  
**PWR RHR MDP FAIL TO START**

2009

### 1.1.10.2 PWR RHR MDP FAIL TO START

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Driven Pump
Failure Mode :	Fail to start
Op. Mode :	CCF Event Can Only Happen During Power Operation CCF Event May Occur During Both Power Operation & Shutdown
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 32.50

Total Number of Common-Cause Failure Events: 3

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9028780	0.9611600	0.9683620	0.9947730	0.9618020	3.9706E+01	1.6045E+00
$\alpha_2$	5.22E-03	3.88E-02	3.16E-02	9.71E-02	3.82E-02	1.6045E+00	3.9706E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9269580	0.9663310	0.9703470	0.9919590	0.9678510	7.3320E+01	2.5546E+00
$\alpha_2$	3.53E-03	2.32E-02	1.91E-02	5.67E-02	2.05E-02	1.7592E+00	7.4115E+01
$\alpha_3$	2.85E-04	1.05E-02	6.61E-03	3.39E-02	1.17E-02	7.9542E-01	7.5079E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9334550	0.9660880	0.9689400	0.9889740	0.9699020	1.0402E+02	3.6514E+00
$\alpha_2$	4.00E-03	2.02E-02	1.73E-02	4.62E-02	1.58E-02	2.1700E+00	1.0550E+02
$\alpha_3$	4.87E-04	9.32E-03	6.51E-03	2.78E-02	1.00E-02	1.0036E+00	1.0667E+02
$\alpha_4$	1.37E-05	4.44E-03	1.95E-03	1.73E-02	4.27E-03	4.7777E-01	1.0719E+02

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9618020	0.9678510	0.9699020
$\alpha_2$	3.82E-02	2.05E-02	1.58E-02
$\alpha_3$		1.17E-02	1.00E-02
$\alpha_4$			4.27E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.62E-01	9.68E-01	9.70E-01
Beta	3.82E-02	3.21E-02	3.01E-02
Gamma		3.63E-01	4.76E-01
Delta			2.99E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	27.90	41.85	55.79
N <sub>1</sub>	1.5600	1.9145	2.0960
N <sub>2</sub>	1.1700	0.9255	0.9419
N <sub>3</sub>		0.5282	0.5993
N <sub>4</sub>			0.2551

### 1.1.10.3 PWR RHR MDP FTR LESS THAN 1H

**System :** Residual Heat Removal (LCI in BWRs, LPI in PWRs)  
**Component :** Motor Driven Pump  
**Failure Mode :** Fail to Run less than 1 Hour  
**Op. Mode :** CCF Event Can Only Happen During Power Operation  
CCF Event May Occur During Both Power Operation & Shutdown  
**Plant Type :** PWR  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 1.00

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.7180720	0.8868740	0.9070060	0.9864790	0.5000000	1.1246E+01	1.4345E+00
$\alpha_2$	1.35E-02	1.13E-01	9.30E-02	2.82E-01	5.00E-01	1.4345E+00	1.1246E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8561580	0.9366350	0.9452630	0.9875260	0.6000000	3.1055E+01	2.1009E+00
$\alpha_2$	3.97E-03	4.02E-02	3.14E-02	1.07E-01	2.00E-01	1.3337E+00	3.1822E+01
$\alpha_3$	5.68E-04	2.31E-02	1.45E-02	7.53E-02	2.00E-01	7.6722E-01	3.2389E+01

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8834530	0.9440080	0.9497380	0.9849400	0.6666670	4.8136E+01	2.8551E+00
$\alpha_2$	3.39E-03	2.90E-02	2.31E-02	7.48E-02	8.33E-02	1.4781E+00	4.9513E+01
$\alpha_3$	7.11E-04	1.77E-02	1.19E-02	5.46E-02	1.67E-01	9.0431E-01	5.0087E+01
$\alpha_4$	2.72E-05	9.27E-03	4.06E-03	3.62E-02	8.33E-02	4.7267E-01	5.0518E+01

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.5000000	0.6000000	0.6666670
$\alpha_2$	5.00E-01	2.00E-01	8.33E-02
$\alpha_3$		2.00E-01	1.67E-01
$\alpha_4$			8.33E-02

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	5.00E-01	6.00E-01	6.67E-01
Beta	5.00E-01	4.00E-01	3.33E-01
Gamma		5.00E-01	7.50E-01
Delta			3.33E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	1.00	1.50	2.00
N <sub>1</sub>	0.0000	0.0000	0.0000
N <sub>2</sub>	1.0000	0.5000	0.2500
N <sub>3</sub>		0.5000	0.5000
N <sub>4</sub>			0.2500

#### 1.1.10.4 PWR RHR MDP FAIL TO RUN

**System :** Residual Heat Removal (LCI in BWRs, LPI in PWRs)  
**Component :** Motor Driven Pump  
**Failure Mode :** Fail to run  
**Op. Mode :** Fail to Run less than 1 Hour  
**CCF Event Can Only Happen During Power Operation**  
**CCF Event May Occur During Both Power Operation & Shutdown**  
**Plant Type :** PWR  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 11.10

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8386610	0.9370290	0.9494480	0.9927870	0.9173550	2.1346E+01	1.4345E+00
$\alpha_2$	7.21E-03	6.30E-02	5.05E-02	1.61E-01	8.26E-02	1.4345E+00	2.1346E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9003620	0.9565080	0.9626720	0.9915560	0.9433430	4.6205E+01	2.1009E+00
$\alpha_2$	2.70E-03	2.76E-02	2.14E-02	7.38E-02	2.83E-02	1.3337E+00	4.6972E+01
$\alpha_3$	3.87E-04	1.59E-02	9.87E-03	5.19E-02	2.83E-02	7.6722E-01	4.7539E+01

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9159780	0.9598960	0.9641320	0.9893090	0.9568970	6.8336E+01	2.8551E+00
$\alpha_2$	2.42E-03	2.08E-02	1.65E-02	5.38E-02	1.08E-02	1.4781E+00	6.9713E+01
$\alpha_3$	5.07E-04	1.27E-02	8.52E-03	3.92E-02	2.16E-02	9.0431E-01	7.0287E+01
$\alpha_4$	1.94E-05	6.64E-03	2.89E-03	2.59E-02	1.08E-02	4.7267E-01	7.0718E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9173550	0.9433430	0.9568970
$\alpha_2$	8.26E-02	2.83E-02	1.08E-02
$\alpha_3$		2.83E-02	2.16E-02
$\alpha_4$			1.08E-02

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.17E-01	9.43E-01	9.57E-01
Beta	8.26E-02	5.67E-02	4.31E-02
Gamma		5.00E-01	7.50E-01
Delta			3.33E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	11.10	16.65	22.20
N <sub>1</sub>	0.0000	0.0000	0.0000
N <sub>2</sub>	1.0000	0.5000	0.2500
N <sub>3</sub>		0.5000	0.5000
N <sub>4</sub>			0.2500

**1.1.11BWR Standby Liquid Control Pump****1.1.11.1 STANDBY LIQUID CONTROL MDP FAIL TO RUN SPAR: SLC-MDP-FR**

System : Standby liquid control  
 Component : Motor Driven Pump  
 Failure Mode : Fail to run  
 Fail to Run less than 1 Hour  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 5.20

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8907950	0.9726380	0.9886780	0.9999450	1.0000000	1.5446E+01	4.3452E-01
$\alpha_2$	5.06E-05	2.74E-02	1.13E-02	1.09E-01	0.00E+00	4.3452E-01	1.5446E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2
$\alpha_1$	1.0000000
$\alpha_2$	0.00E+00

MGL Parameter	CCCG=2
1-Beta	1.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	5.20
N <sub>1</sub>	0.0000
N <sub>2</sub>	0.0000

### 1.1.11.2 STANDBY LIQUID CONTROL MDP FAIL TO START SPAR: SLC-MDP-FS

System : Standby liquid control  
 Component : Motor Driven Pump  
 Failure Mode : Fail to start  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 11.50

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9210710	0.9801290	0.9916810	0.9999550	0.9991450	2.1926E+01	4.4452E-01
$\alpha_2$	4.16E-05	1.99E-02	8.32E-03	7.89E-02	8.55E-04	4.4452E-01	2.1926E+01

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
$\alpha_1$	0.9991450
$\alpha_2$	8.55E-04

MGL Parameter	CCCG=2
1-Beta	9.99E-01
Beta	8.55E-04

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	11.50
N <sub>1</sub>	0.1800
N <sub>2</sub>	0.0100

### 1.1.12 Component Cooling Water Pumps

#### 1.1.12.1 CCW MOTOR DRIVEN PUMP FAIL TO RUN SPAR: CCW-MDP-FR

System : Component cooling water  
 Component : Motor Driven Pump  
 Failure Mode : Fail to run  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 50.00

Total Number of Common-Cause Failure Events: 2

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9060250	0.9631300	0.9703610	0.9954610	0.9644660	3.9649E+01	1.5178E+00
$\alpha_2$	4.54E-03	3.69E-02	2.96E-02	9.40E-02	3.55E-02	1.5178E+00	3.9649E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9309240	0.9689720	0.9730090	0.9932100	0.9722900	7.3415E+01	2.3509E+00
$\alpha_2$	9.01E-04	1.43E-02	1.03E-02	4.14E-02	5.54E-03	1.0837E+00	7.4682E+01
$\alpha_3$	1.47E-03	1.67E-02	1.27E-02	4.58E-02	2.22E-02	1.2672E+00	7.4499E+01

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3
$\alpha_1$	0.9644660	0.9722900
$\alpha_2$	3.55E-02	5.54E-03
$\alpha_3$		2.22E-02

MGL Parameter	CCCG=2	CCCG=3
1-Beta	9.64E-01	9.72E-01
Beta	3.55E-02	2.77E-02
Gamma		8.00E-01

Avg. Impact Vector	CCCG=2	CCCG=3
Adj. Ind. Events	28.57	42.86
$N_1$	0.8333	1.0000
$N_2$	1.0833	0.2500
$N_3$		1.0000

**Motor** Driven Pumps

2009

**RHR** Service Water

CCW MOTOR DRIVEN PUMP FAIL TO START SPAR: CCW-MDP-FS

### 1.1.12.2 CCW MOTOR DRIVEN PUMP FAIL TO START SPAR: CCW-MDP-FS

System :	Component cooling water
Component :	Motor Driven Pump
Failure Mode :	Fail to start
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 75.20

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9796120	0.9949400	0.9979780	0.9999920	1.0000000	8.5446E+01	4.3452E-01
$\alpha_2$	9.01E-06	5.06E-03	2.03E-03	2.04E-02	0.00E+00	4.3452E-01	8.5446E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9700380	0.9896000	0.9924810	0.9993210	1.0000000	1.0475E+02	1.1009E+00
$\alpha_2$	2.47E-04	7.88E-03	5.07E-03	2.51E-02	0.00E+00	8.3366E-01	1.0502E+02
$\alpha_3$	8.78E-08	2.52E-03	5.05E-04	1.20E-02	0.00E+00	2.6722E-01	1.0558E+02

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3
$\alpha_1$	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00

MGL Parameter	CCCG=2	CCCG=3
1-Beta	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00
Gamma		0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3
Adj. Ind. Events	75.20	75.20
$N_1$	0.0000	0.0000
$N_2$	0.0000	0.0000
$N_3$		0.0000

### 1.1.13RHR Service Water

## 1.2 Turbine Driven Pumps

### 1.2.1 Pooled Turbine Driven Pumps

#### 1.2.1.1 TURBINE DRIVEN PUMP FAIL TO RUN >1H SPAR: TDP-FR

Component : Turbine Driven Pump  
 Failure Mode : Fail to run  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 98.20

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9839160	0.9960090	0.9984070	0.9999860	1.0000000	1.0845E+02	4.3452E-01
$\alpha_2$	7.09E-06	3.99E-03	1.59E-03	1.61E-02	0.00E+00	4.3452E-01	1.0845E+02

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9753630	0.9914560	0.9938270	0.9994420	1.0000000	1.2775E+02	1.1009E+00
$\alpha_2$	2.03E-04	6.47E-03	4.16E-03	2.06E-02	0.00E+00	8.3366E-01	1.2802E+02
$\alpha_3$	7.20E-08	2.07E-03	4.15E-04	9.84E-03	0.00E+00	2.6722E-01	1.2858E+02

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9693440	0.9873110	0.9894540	0.9979350	1.0000000	1.4434E+02	1.8551E+00
$\alpha_2$	6.89E-04	8.40E-03	6.29E-03	2.33E-02	0.00E+00	1.2281E+00	1.4497E+02
$\alpha_3$	3.09E-06	2.77E-03	1.02E-03	1.14E-02	0.00E+00	4.0431E-01	1.4579E+02
$\alpha_4$	6.54E-09	1.52E-03	2.07E-04	7.63E-03	0.00E+00	2.2267E-01	1.4597E+02

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	98.20	98.20	98.20
N <sub>1</sub>	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000
N <sub>4</sub>			0.0000

### 1.2.1.2 TURBINE DRIVEN PUMP FTR LESS THAN 1H SPAR: TDP-FH

Component : Turbine Driven Pump  
 Failure Mode : Fail to Run less than 1 Hour  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 47.60

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9699900	0.9925440	0.9970090	0.9999850	1.0000000	5.7846E+01	4.3452E-01
$\alpha_2$	1.33E-05	7.46E-03	2.99E-03	3.00E-02	0.00E+00	4.3452E-01	5.7846E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9595470	0.9859320	0.9898030	0.9990790	1.0000000	7.7155E+01	1.1009E+00
$\alpha_2$	3.35E-04	1.07E-02	6.87E-03	3.39E-02	0.00E+00	8.3366E-01	7.7422E+01
$\alpha_3$	1.19E-07	3.41E-03	6.85E-04	1.62E-02	0.00E+00	2.6722E-01	7.7989E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9532610	0.9805940	0.9838380	0.9968340	1.0000000	9.3736E+01	1.8551E+00
$\alpha_2$	1.06E-03	1.28E-02	9.64E-03	3.56E-02	0.00E+00	1.2281E+00	9.4363E+01
$\alpha_3$	4.75E-06	4.23E-03	1.56E-03	1.75E-02	0.00E+00	4.0431E-01	9.5187E+01
$\alpha_4$	1.00E-08	2.33E-03	3.18E-04	1.17E-02	0.00E+00	2.2267E-01	9.5368E+01

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	47.60	47.60	47.60
N <sub>1</sub>	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000
N <sub>4</sub>			0.0000

### 1.2.1.3 TURBINE DRIVEN PUMP FAIL TO START SPAR: TDP-FS

Component : Turbine Driven Pump  
Failure Mode : Fail to start  
Start Date : 1997/01/01  
Data Version : 2009/12/31

Total Number of Independent Failure Events: 159.90

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9897880	0.9974680	0.9989930	0.9999910	1.0000000	1.7115E+02	4.3452E-01
$\alpha_2$	4.49E-06	2.53E-03	1.01E-03	1.02E-02	0.00E+00	4.3452E-01	1.7115E+02

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9882350	0.9959300	0.9970710	0.9997350	1.0000000	2.6940E+02	1.1009E+00
$\alpha_2$	9.62E-05	3.08E-03	1.98E-03	9.84E-03	0.00E+00	8.3366E-01	2.6967E+02
$\alpha_3$	3.42E-08	9.88E-04	1.97E-04	4.69E-03	0.00E+00	2.6722E-01	2.7023E+02

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9877760	0.9949560	0.9958220	0.9991830	1.0000000	3.6594E+02	1.8551E+00
$\alpha_2$	2.73E-04	3.34E-03	2.49E-03	9.29E-03	0.00E+00	1.2281E+00	3.6657E+02
$\alpha_3$	1.23E-06	1.10E-03	4.04E-04	4.55E-03	0.00E+00	4.0431E-01	3.6739E+02
$\alpha_4$	2.59E-09	6.05E-04	8.23E-05	3.03E-03	0.00E+00	2.2267E-01	3.6757E+02

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	159.90	239.85	319.80
N <sub>1</sub>	1.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000
N <sub>4</sub>			0.0000

### 1.2.2 AFW Turbine-Driven Pumps

#### 1.2.2.1 AFW TURBINE DRIVEN PUMP FAIL TO RUN >1H SPAR

**System :** Auxiliary feedwater  
**Component :** Turbine Driven Pump  
**Failure Mode :** Fail to run  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 19.60

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9423940	0.9856500	0.9941790	0.9999720	1.0000000	2.9846E+01	4.3452E-01
$\alpha_2$	2.60E-05	1.43E-02	5.82E-03	5.76E-02	0.00E+00	4.3452E-01	2.9846E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9372610	0.9780950	0.9840520	0.9985620	1.0000000	4.9155E+01	1.1009E+00
$\alpha_2$	5.25E-04	1.66E-02	1.08E-02	5.26E-02	0.00E+00	8.3366E-01	4.9422E+01
$\alpha_3$	1.86E-07	5.32E-03	1.07E-03	2.52E-02	0.00E+00	2.6722E-01	4.9989E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9341490	0.9725540	0.9770760	0.9954920	1.0000000	6.5736E+01	1.8551E+00
$\alpha_2$	1.50E-03	1.82E-02	1.37E-02	5.02E-02	0.00E+00	1.2281E+00	6.6363E+01
$\alpha_3$	6.73E-06	5.98E-03	2.22E-03	2.47E-02	0.00E+00	4.0431E-01	6.7187E+01
$\alpha_4$	1.42E-08	3.29E-03	4.51E-04	1.65E-02	0.00E+00	2.2267E-01	6.7368E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	19.60	19.60	19.60
$N_1$	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000
$N_4$			0.0000

**1.2.2.2 AFW TURBINE DRIVEN PUMP FAIL TO START SPAR: AFW-TDP-FS**

System :

Auxiliary feedwater

Component :

Turbine Driven Pump

Failure Mode :

Fail to start

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 62.90

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9762110	0.9940950	0.9976370	0.9999880	1.0000000	7.3146E+01	4.3452E-01
$\alpha_2$	1.05E-05	5.91E-03	2.37E-03	2.38E-02	0.00E+00	4.3452E-01	7.3146E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9661230	0.9882330	0.9914870	0.9992310	1.0000000	9.2455E+01	1.1009E+00
$\alpha_2$	2.80E-04	8.91E-03	5.74E-03	2.84E-02	0.00E+00	8.3366E-01	9.2722E+01
$\alpha_3$	9.94E-08	2.86E-03	5.72E-04	1.35E-02	0.00E+00	2.6722E-01	9.3289E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9596620	0.9832720	0.9860820	0.9972760	1.0000000	1.0904E+02	1.8551E+00
$\alpha_2$	9.10E-04	1.11E-02	8.30E-03	3.07E-02	0.00E+00	1.2281E+00	1.0967E+02
$\alpha_3$	4.09E-06	3.65E-03	1.35E-03	1.51E-02	0.00E+00	4.0431E-01	1.1049E+02
$\alpha_4$	8.63E-09	2.01E-03	2.74E-04	1.01E-02	0.00E+00	2.2267E-01	1.1067E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	62.90	62.90	62.90
$N_1$	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000
$N_4$			0.0000

**1.2.2.3 AFW TURBINE DRIVEN PUMP FTR LESS THAN 1H SPAR: AFW-TDP-FH**

System :

Auxiliary feedwater

Component :

Turbine Driven Pump

Failure Mode :

Fail to Run less than 1 Hour

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 33.00

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9599930	0.9900520	0.9959880	0.9999800	1.0000000	4.3246E+01	4.3452E-01
$\alpha_2$	1.79E-05	9.95E-03	4.01E-03	4.00E-02	0.00E+00	4.3452E-01	4.3246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9503450	0.9827060	0.9874400	0.9988710	1.0000000	6.2555E+01	1.1009E+00
$\alpha_2$	4.13E-04	1.31E-02	8.46E-03	4.16E-02	0.00E+00	8.3366E-01	6.2822E+01
$\alpha_3$	1.47E-07	4.20E-03	8.43E-04	1.99E-02	0.00E+00	2.6722E-01	6.3389E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9449240	0.9770950	0.9809010	0.9962540	1.0000000	7.9136E+01	1.8551E+00
$\alpha_2$	1.25E-03	1.52E-02	1.14E-02	4.20E-02	0.00E+00	1.2281E+00	7.9763E+01
$\alpha_3$	5.61E-06	4.99E-03	1.85E-03	2.06E-02	0.00E+00	4.0431E-01	8.0587E+01
$\alpha_4$	1.18E-08	2.75E-03	3.76E-04	1.38E-02	0.00E+00	2.2267E-01	8.0768E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	33.00	33.00	33.00
$N_1$	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000
$N_4$			0.0000

### 1.2.2.4 AFW TURBINE DRIVEN PUMP FAIL TO RUN: AFW-TDP-FR

System : Auxiliary feedwater  
 Component : Turbine Driven Pump  
 Failure Mode : Fail to run  
 Fail to Run less than 1 Hour  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 52.60

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9723490	0.9931330	0.9972430	0.9999860	1.0000000	6.2846E+01	4.3452E-01
$\alpha_2$	1.23E-05	6.87E-03	2.76E-03	2.76E-02	0.00E+00	4.3452E-01	6.2846E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9619560	0.9867770	0.9904200	0.9991350	1.0000000	8.2155E+01	1.1009E+00
$\alpha_2$	3.15E-04	1.00E-02	6.46E-03	3.18E-02	0.00E+00	8.3366E-01	8.2422E+01
$\alpha_3$	1.12E-07	3.21E-03	6.43E-04	1.52E-02	0.00E+00	2.6722E-01	8.2989E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9555650	0.9815580	0.9846470	0.9969940	1.0000000	9.8736E+01	1.8551E+00
$\alpha_2$	1.00E-03	1.22E-02	9.16E-03	3.38E-02	0.00E+00	1.2281E+00	9.9363E+01
$\alpha_3$	4.51E-06	4.02E-03	1.49E-03	1.66E-02	0.00E+00	4.0431E-01	1.0019E+02
$\alpha_4$	9.52E-09	2.21E-03	3.02E-04	1.11E-02	0.00E+00	2.2267E-01	1.0037E+02

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	52.60	52.60	52.60
N <sub>1</sub>	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000
N <sub>4</sub>			0.0000

### 1.2.3 BWR High Pressure Coolant Injection and Reactor Core Isolation Cooling Pumps

#### 1.2.3.1 COMBINED HPCI AND RCIC TDP FAIL TO START

System :

High pressure coolant injection

Reactor core isolation

Turbine Driven Pump

Component :

Failure Mode :

Fail to start

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 84.00

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9817000	0.9954590	0.9981860	0.9999930	1.0000000	9.5246E+01	4.3452E-01
$\alpha_2$	8.08E-06	4.54E-03	1.82E-03	1.83E-02	0.00E+00	4.3452E-01	9.5246E+01

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
$\alpha_1$	1.0000000
$\alpha_2$	0.00E+00

MGL Parameter	CCCG=2
1-Beta	1.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	84.00
N <sub>1</sub>	1.0000
N <sub>2</sub>	0.0000

**Turbine** Driven Pumps

2009

**BWR** High Pressure Coolant Injection and Reactor Core Isolation Cooling Pumps

COMBINED HPCI AND RCIC TDP FTR LESS THAN 1H

### 1.2.3.2 COMBINED HPCI AND RCIC TDP FTR LESS THAN 1H

System :	High pressure coolant injection Reactor core isolation
Component :	Turbine Driven Pump
Failure Mode :	Fail to Run less than 1 Hour
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 14.60

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9310850	0.9828120	0.9929990	0.9999660	1.0000000	2.4846E+01	4.3452E-01
$\alpha_2$	3.12E-05	1.72E-02	7.00E-03	6.89E-02	0.00E+00	4.3452E-01	2.4846E+01

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
$\alpha_1$	1.0000000
$\alpha_2$	0.00E+00

MGL Parameter	CCCG=2
1-Beta	1.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	14.60
$N_1$	0.0000
$N_2$	0.0000

### 1.2.3.3 COMBINED HPCI AND RCIC TDP FAIL TO RUN >1H

System :	High pressure coolant injection Reactor core isolation
Component :	Turbine Driven Pump
Failure Mode :	Fail to run
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 19.60

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9423940	0.9856500	0.9941790	0.9999720	1.0000000	2.9846E+01	4.3452E-01
$\alpha_2$	2.60E-05	1.43E-02	5.82E-03	5.76E-02	0.00E+00	4.3452E-01	2.9846E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2
$\alpha_1$	1.0000000
$\alpha_2$	0.00E+00

MGL Parameter	CCCG=2
1-Beta	1.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	19.60
N <sub>1</sub>	0.0000
N <sub>2</sub>	0.0000

**1.2.3.4 COMBINED HPCI AND RCIC TDP FAIL TO RUN****System :**

High pressure coolant injection

Reactor core isolation

**Component :**

Turbine Driven Pump

**Failure Mode :**

Fail to run

Fail to Run less than 1 Hour

**Start Date :**

1997/01/01

**Data Version :**

2009/12/31

Total Number of Independent Failure Events: 34.20

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9610590	0.9903180	0.9960960	0.9999810	1.0000000	4.4446E+01	4.3452E-01
$\alpha_2$	1.74E-05	9.68E-03	3.90E-03	3.89E-02	0.00E+00	4.3452E-01	4.4446E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2
$\alpha_1$	1.0000000
$\alpha_2$	0.00E+00

**Turbine** Driven Pumps

2009

**BWR** High Pressure Coolant Injection and Reactor Core Isolation Cooling Pumps

COMBINED HPCI AND RCIC TDP FAIL TO RUN

<b>MGL Parameter</b>	<b>CCCG=2</b>
<b>1-Beta</b>	<b>1.00E+00</b>
<b>Beta</b>	<b>0.00E+00</b>

<b>Avg. Impact Vector</b>	<b>CCCG=2</b>
<b>Adj. Ind. Events</b>	<b>34.20</b>
<b>N<sub>1</sub></b>	<b>0.0000</b>
<b>N<sub>2</sub></b>	<b>0.0000</b>

## 1.3 Motor Operated Valves

### 1.3.1 Pooled Motor Operated Valve Distributions

#### 1.3.1.1 MOV FAIL TO OPEN ALL SYSTEMS SPAR: MOV-CC

Component : Motor Operated Valve  
Failure Mode : Fail to open on demand  
Start Date : 1997/01/01  
Data Version : 2009/12/31

Total Number of Independent Failure Events: 254.60

Total Number of Common-Cause Failure Events: 4

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9489980	0.9796210	0.9834370	0.9971960	0.9827170	7.9065E+01	1.6448E+00
$\alpha_2$	2.81E-03	2.04E-02	1.66E-02	5.10E-02	1.73E-02	1.6448E+00	7.9065E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9578070	0.9804960	0.9828220	0.9952440	0.9853190	1.3231E+02	2.6319E+00
$\alpha_2$	2.12E-03	1.34E-02	1.11E-02	3.27E-02	9.41E-03	1.8146E+00	1.3313E+02
$\alpha_3$	1.78E-04	6.06E-03	3.86E-03	1.94E-02	5.28E-03	8.1732E-01	1.3412E+02

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9608680	0.9800630	0.9817530	0.9934760	0.9865520	1.8270E+02	3.7167E+00
$\alpha_2$	2.23E-03	1.15E-02	9.78E-03	2.65E-02	6.58E-03	2.1395E+00	1.8428E+02
$\alpha_3$	3.87E-04	5.92E-03	4.28E-03	1.71E-02	5.06E-03	1.1045E+00	1.8531E+02
$\alpha_4$	7.37E-06	2.54E-03	1.10E-03	9.93E-03	1.81E-03	4.7267E-01	1.8594E+02

##### **CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9633870	0.9792780	0.9804390	0.9911920	0.9878130	2.6656E+02	5.6406E+00
$\alpha_2$	2.72E-03	1.04E-02	9.26E-03	2.22E-02	4.21E-03	2.8410E+00	2.6936E+02
$\alpha_3$	1.10E-03	6.81E-03	5.64E-03	1.65E-02	5.08E-03	1.8529E+00	2.7035E+02
$\alpha_4$	6.10E-05	2.75E-03	1.67E-03	9.13E-03	2.17E-03	7.4939E-01	2.7145E+02
$\alpha_5$	6.10E-10	7.25E-04	7.26E-05	3.75E-03	7.25E-04	1.9728E-01	2.7200E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9663590	0.9803790	0.9813460	0.9910880	0.9895780	3.2136E+02	6.4317E+00
$\alpha_2$	1.69E-03	7.49E-03	6.51E-03	1.66E-02	1.04E-03	2.4537E+00	3.2534E+02
$\alpha_3$	1.60E-03	7.30E-03	6.32E-03	1.63E-02	6.06E-03	2.3928E+00	3.2540E+02
$\alpha_4$	1.39E-04	2.95E-03	2.02E-03	8.93E-03	1.82E-03	9.6722E-01	3.2682E+02
$\alpha_5$	4.16E-06	1.44E-03	6.23E-04	5.64E-03	1.21E-03	4.7220E-01	3.2732E+02
$\alpha_6$	2.27E-12	4.45E-04	1.66E-05	2.46E-03	3.03E-04	1.4574E-01	3.2765E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9676980	0.9799190	0.9806540	0.9896210	0.9908050	4.2248E+02	8.6578E+00
$\alpha_2$	2.31E-03	7.72E-03	6.98E-03	1.57E-02	1.01E-03	3.3297E+00	4.2781E+02
$\alpha_3$	1.21E-03	5.54E-03	4.80E-03	1.24E-02	3.15E-03	2.3895E+00	4.2875E+02
$\alpha_4$	5.65E-04	3.95E-03	3.21E-03	9.84E-03	2.96E-03	1.7014E+00	4.2944E+02
$\alpha_5$	6.04E-05	1.94E-03	1.24E-03	6.18E-03	1.30E-03	8.3427E-01	4.3030E+02
$\alpha_6$	2.65E-07	7.95E-04	2.37E-04	3.48E-03	6.50E-04	3.4258E-01	4.3080E+02
$\alpha_7$	3.85E-25	1.40E-04	1.41E-08	7.87E-04	1.30E-04	6.0371E-02	4.3108E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9694380	0.9805480	0.9811820	0.9894910	0.9916920	4.9113E+02	9.7430E+00
$\alpha_2$	2.33E-03	7.26E-03	6.62E-03	1.44E-02	1.07E-03	3.6388E+00	4.9723E+02
$\alpha_3$	8.74E-04	4.38E-03	3.74E-03	1.01E-02	1.66E-03	2.1955E+00	4.9868E+02
$\alpha_4$	6.03E-04	3.72E-03	3.08E-03	9.00E-03	2.60E-03	1.8610E+00	4.9901E+02
$\alpha_5$	1.77E-04	2.36E-03	1.74E-03	6.66E-03	1.72E-03	1.1808E+00	4.9969E+02
$\alpha_6$	1.14E-05	1.20E-03	6.34E-04	4.31E-03	8.53E-04	6.0136E-01	5.0027E+02
$\alpha_7$	1.31E-09	4.33E-04	5.51E-05	2.18E-03	3.41E-04	2.1677E-01	5.0066E+02
$\alpha_8$	2.32E-30	9.73E-05	7.74E-10	5.13E-04	5.68E-05	4.8724E-02	5.0082E+02

**ALPHA FACTOR and MGL PARAMETERS**

<b>Alpha Factor</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>	<b>CCCG=7</b>	<b>CCCG=8</b>
$\alpha_1$	0.9827170	0.9853190	0.9865520	0.9878130	0.9895780	0.9908050	0.9916920
$\alpha_2$	1.73E-02	9.41E-03	6.58E-03	4.21E-03	1.04E-03	1.01E-03	1.07E-03
$\alpha_3$		5.28E-03	5.06E-03	5.08E-03	6.06E-03	3.15E-03	1.66E-03
$\alpha_4$			1.81E-03	2.17E-03	1.82E-03	2.96E-03	2.60E-03
$\alpha_5$				7.25E-04	1.21E-03	1.30E-03	1.72E-03
$\alpha_6$					3.03E-04	6.50E-04	8.53E-04
$\alpha_7$						1.30E-04	3.41E-04
$\alpha_8$							5.68E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.83E-01	9.85E-01	9.87E-01	9.88E-01	9.90E-01	9.91E-01	9.92E-01
Beta	1.73E-02	1.47E-02	1.34E-02	1.22E-02	1.04E-02	9.20E-03	8.31E-03
Gamma		3.59E-01	5.10E-01	6.54E-01	9.00E-01	8.91E-01	8.71E-01
Delta			2.63E-01	3.64E-01	3.55E-01	6.15E-01	7.70E-01
Epsilon				2.50E-01	4.55E-01	4.12E-01	5.33E-01
Mu					2.00E-01	3.75E-01	4.21E-01
Upsilon						1.67E-01	3.18E-01
Sigma							1.43E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	67.89	101.84	135.79	169.73	203.68	237.63	271.57
N <sub>1</sub>	0.9293	0.9132	0.7766	0.6698	0.7430	0.7972	0.8319
N <sub>2</sub>	1.2103	0.9809	0.9114	0.7268	0.2145	0.2419	0.2941
N <sub>3</sub>		0.5501	0.7002	0.8755	1.2510	0.7583	0.4571
N <sub>4</sub>			0.2500	0.3750	0.3750	0.7125	0.7145
N <sub>5</sub>				0.1250	0.2500	0.3125	0.4725
N <sub>6</sub>					0.0625	0.1563	0.2344
N <sub>7</sub>						0.0313	0.0938
N <sub>8</sub>							0.0156

### 1.3.1.2 MOV SPURIOUS OPERATION ALL SYSTEMS SPAR: MOV-CO

Component :

Motor Operated Valve

Failure Mode :

Spurious operation open or close

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 20.50

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8790650	0.9670820	0.9833330	0.9997950	0.9814470	1.5912E+01	5.4162E-01
$\alpha_2$	2.03E-04	3.29E-02	1.67E-02	1.21E-01	1.86E-02	5.4162E-01	1.5912E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9069420	0.9645950	0.9721790	0.9962680	0.9664220	3.7781E+01	1.3867E+00
$\alpha_2$	1.86E-03	2.81E-02	2.06E-02	8.03E-02	3.15E-02	1.1016E+00	3.8066E+01
$\alpha_3$	4.90E-07	7.28E-03	1.65E-03	3.38E-02	2.10E-03	2.8512E-01	3.8883E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9117700	0.9601980	0.9652780	0.9912250	0.9552720	5.6815E+01	2.3551E+00
$\alpha_2$	3.92E-03	2.80E-02	2.29E-02	6.97E-02	3.83E-02	1.6567E+00	5.7513E+01
$\alpha_3$	2.44E-05	8.04E-03	3.53E-03	3.13E-02	6.39E-03	4.7571E-01	5.8694E+01
$\alpha_4$	1.63E-08	3.76E-03	5.16E-04	1.89E-02	0.00E+00	2.2267E-01	5.8947E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9294330	0.9625300	0.9652170	0.9864300	0.9482100	1.0924E+02	4.2526E+00
$\alpha_2$	5.75E-03	2.33E-02	2.06E-02	5.03E-02	3.88E-02	2.6499E+00	1.1084E+02
$\alpha_3$	7.38E-04	1.02E-02	7.49E-03	2.89E-02	1.29E-02	1.1560E+00	1.1234E+02
$\alpha_4$	2.17E-06	3.30E-03	1.11E-03	1.40E-02	0.00E+00	3.7439E-01	1.1312E+02
$\alpha_5$	5.26E-21	6.37E-04	3.60E-07	3.69E-03	0.00E+00	7.2277E-02	1.1342E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9325690	0.9624170	0.9646370	0.9846720	0.9454940	1.3243E+02	5.1715E+00
$\alpha_2$	5.18E-03	2.02E-02	1.79E-02	4.29E-02	3.27E-02	2.7749E+00	1.3483E+02
$\alpha_3$	1.29E-03	1.09E-02	8.63E-03	2.82E-02	2.18E-02	1.4989E+00	1.3610E+02
$\alpha_4$	3.85E-05	4.30E-03	2.25E-03	1.55E-02	0.00E+00	5.9222E-01	1.3701E+02
$\alpha_5$	6.75E-09	1.61E-03	2.19E-04	8.09E-03	0.00E+00	2.2220E-01	1.3738E+02
$\alpha_6$	1.02E-18	6.05E-04	1.06E-06	3.53E-03	0.00E+00	8.3237E-02	1.3752E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9814470	0.9664220	0.9552720	0.9482100	0.9454940
$\alpha_2$	1.86E-02	3.15E-02	3.83E-02	3.88E-02	3.27E-02
$\alpha_3$		2.10E-03	6.39E-03	1.29E-02	2.18E-02
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.81E-01	9.66E-01	9.55E-01	9.48E-01	9.45E-01
Beta	1.86E-02	3.36E-02	4.47E-02	5.18E-02	5.45E-02
Gamma		6.26E-02	1.43E-01	2.50E-01	4.00E-01
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	5.13	7.69	10.25	12.81	15.38
N <sub>1</sub>	0.5357	0.5357	0.4286	0.2679	0.1071
N <sub>2</sub>	0.1071	0.2679	0.4286	0.5357	0.5357
N <sub>3</sub>		0.0179	0.0714	0.1786	0.3571
N <sub>4</sub>			0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000
N <sub>6</sub>					0.0000

### 1.3.1.3 MOV FAIL TO OPERATE ALL SYSTEMS SPAR: MOV-FO

Component :

Motor Operated Valve

Failure Mode :

Fail to close (reset) on demand

Fail to open on demand

Fail to Operate (Open/Close)

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 461.40

Total Number of Common-Cause Failure Events: 8

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9732510	0.9888900	0.9907480	0.9981640	0.9908840	1.6718E+02	1.8782E+00
$\alpha_2$	1.83E-03	1.11E-02	9.25E-03	2.68E-02	9.12E-03	1.8782E+00	1.6718E+02

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9747020	0.9875260	0.9887180	0.9962600	0.9905640	2.6377E+02	3.3319E+00
$\alpha_2$	2.18E-03	9.41E-03	8.22E-03	2.07E-02	7.11E-03	2.5146E+00	2.6459E+02
$\alpha_3$	8.99E-05	3.06E-03	1.94E-03	9.84E-03	2.33E-03	8.1732E-01	2.6628E+02

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9743950	0.9858720	0.9867550	0.9943240	0.9896180	3.5705E+02	5.1167E+00
$\alpha_2$	3.07E-03	9.77E-03	8.89E-03	1.95E-02	7.36E-03	3.5395E+00	3.5863E+02
$\alpha_3$	1.99E-04	3.05E-03	2.20E-03	8.81E-03	2.23E-03	1.1045E+00	3.6106E+02
$\alpha_4$	3.79E-06	1.31E-03	5.65E-04	5.11E-03	7.96E-04	4.7267E-01	3.6169E+02

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9750600	0.9850560	0.9857100	0.9928100	0.9903180	4.8166E+02	7.3073E+00
$\alpha_2$	3.01E-03	8.54E-03	7.88E-03	1.63E-02	5.29E-03	4.1744E+00	4.8479E+02
$\alpha_3$	8.87E-04	4.47E-03	3.82E-03	1.03E-02	3.11E-03	2.1862E+00	4.8678E+02
$\alpha_4$	3.39E-05	1.53E-03	9.29E-04	5.09E-03	9.63E-04	7.4939E-01	4.8822E+02
$\alpha_5$	3.39E-10	4.03E-04	4.04E-05	2.09E-03	3.21E-04	1.9728E-01	4.8877E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9767560	0.9856490	0.9861940	0.9926740	0.9910940	5.7908E+02	8.4315E+00
$\alpha_2$	2.23E-03	6.63E-03	6.08E-03	1.29E-02	3.56E-03	3.8981E+00	5.8361E+02
$\alpha_3$	1.25E-03	4.83E-03	4.28E-03	1.03E-02	3.64E-03	2.8372E+00	5.8467E+02
$\alpha_4$	1.13E-04	1.84E-03	1.31E-03	5.35E-03	1.04E-03	1.0783E+00	5.8643E+02
$\alpha_5$	2.32E-06	8.04E-04	3.47E-04	3.15E-03	5.36E-04	4.7220E-01	5.8704E+02
$\alpha_6$	1.27E-12	2.48E-04	9.25E-06	1.37E-03	1.34E-04	1.4574E-01	5.8737E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9775410	0.9854760	0.9859120	0.9919130	0.9922460	7.2315E+02	1.0658E+01
$\alpha_2$	2.21E-03	6.03E-03	5.59E-03	1.14E-02	2.46E-03	4.4260E+00	7.2938E+02
$\alpha_3$	1.14E-03	4.13E-03	3.69E-03	8.64E-03	2.58E-03	3.0339E+00	7.3077E+02
$\alpha_4$	4.44E-04	2.62E-03	2.19E-03	6.29E-03	1.72E-03	1.9237E+00	7.3188E+02
$\alpha_5$	4.21E-05	1.19E-03	7.76E-04	3.73E-03	6.43E-04	8.7127E-01	7.3294E+02
$\alpha_6$	1.56E-07	4.67E-04	1.39E-04	2.04E-03	2.88E-04	3.4258E-01	7.3347E+02
$\alpha_7$	2.26E-25	8.23E-05	8.29E-09	4.62E-04	5.76E-05	6.0371E-02	7.3375E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9789350	0.9861280	0.9865060	0.9920250	0.9930970	8.3476E+02	1.1743E+01
$\alpha_2$	1.95E-03	5.29E-03	4.90E-03	9.94E-03	1.82E-03	4.4763E+00	8.4203E+02
$\alpha_3$	9.14E-04	3.44E-03	3.06E-03	7.27E-03	1.89E-03	2.9106E+00	8.4359E+02
$\alpha_4$	5.17E-04	2.60E-03	2.22E-03	5.97E-03	1.69E-03	2.1973E+00	8.4431E+02
$\alpha_5$	1.34E-04	1.51E-03	1.14E-03	4.15E-03	9.21E-04	1.2796E+00	8.4522E+02
$\alpha_6$	7.52E-06	7.25E-04	3.88E-04	2.59E-03	3.98E-04	6.1366E-01	8.4589E+02
$\alpha_7$	7.77E-10	2.56E-04	3.26E-05	1.29E-03	1.51E-04	2.1677E-01	8.4629E+02
$\alpha_8$	1.37E-30	5.76E-05	4.58E-10	3.03E-04	2.51E-05	4.8724E-02	8.4645E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9908840	0.9905640	0.9896180	0.9903180	0.9910940	0.9922460	0.9930970
$\alpha_2$	9.12E-03	7.11E-03	7.36E-03	5.29E-03	3.56E-03	2.46E-03	1.82E-03
$\alpha_3$		2.33E-03	2.23E-03	3.11E-03	3.64E-03	2.58E-03	1.89E-03
$\alpha_4$			7.96E-04	9.63E-04	1.04E-03	1.72E-03	1.69E-03
$\alpha_5$				3.21E-04	5.36E-04	6.43E-04	9.21E-04
$\alpha_6$					1.34E-04	2.88E-04	3.98E-04
$\alpha_7$						5.76E-05	1.51E-04
$\alpha_8$							2.51E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.91E-01	9.91E-01	9.90E-01	9.90E-01	9.91E-01	9.92E-01	9.93E-01
Beta	9.12E-03	9.44E-03	1.04E-02	9.68E-03	8.91E-03	7.75E-03	6.90E-03
Gamma		2.47E-01	2.91E-01	4.53E-01	6.01E-01	6.82E-01	7.36E-01
Delta			2.63E-01	2.93E-01	3.20E-01	5.12E-01	6.28E-01
Epsilon				2.50E-01	3.91E-01	3.65E-01	4.69E-01
Mu					2.00E-01	3.49E-01	3.84E-01
Upsilon						1.67E-01	3.07E-01
Sigma							1.43E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	153.80	230.70	307.60	384.50	461.40	538.30	615.20
N <sub>1</sub>	3.1293	3.5132	3.3099	1.0032	0.7430	0.7972	0.8319
N <sub>2</sub>	1.4437	1.6809	2.3114	2.0602	1.6589	1.3382	1.1316
N <sub>3</sub>		0.5501	0.7002	1.2088	1.6954	1.4027	1.1722
N <sub>4</sub>			0.2500	0.3750	0.4861	0.9348	1.0508
N <sub>5</sub>				0.1250	0.2500	0.3495	0.5713
N <sub>6</sub>					0.0625	0.1563	0.2467
N <sub>7</sub>						0.0313	0.0938
N <sub>8</sub>							0.0156

### 1.3.1.4 MOV FAIL TO CLOSE ALL SYSTEMS SPAR: MOV-OO

Component :

Motor Operated Valve

Failure Mode :

Fail to close (reseat) on demand

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 184.80

Total Number of Common-Cause Failure Events: 4

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9758110	0.9929880	0.9960050	0.9998950	0.9972410	9.4576E+01	6.6782E-01
$\alpha_2$	1.03E-04	7.01E-03	3.99E-03	2.42E-02	2.76E-03	6.6782E-01	9.4576E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9720380	0.9885400	0.9905400	0.9982110	0.9944660	1.5535E+02	1.8009E+00
$\alpha_2$	1.20E-03	9.76E-03	7.77E-03	2.51E-02	5.53E-03	1.5337E+00	1.5562E+02
$\alpha_3$	5.90E-08	1.70E-03	3.40E-04	8.07E-03	0.00E+00	2.6722E-01	1.5688E+02

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9693020	0.9849440	0.9864160	0.9955690	0.9916770	2.1294E+02	3.2551E+00
$\alpha_2$	2.95E-03	1.22E-02	1.07E-02	2.64E-02	8.32E-03	2.6281E+00	2.1357E+02
$\alpha_3$	2.09E-06	1.87E-03	6.89E-04	7.74E-03	0.00E+00	4.0431E-01	2.1579E+02
$\alpha_4$	4.41E-09	1.03E-03	1.40E-04	5.16E-03	0.00E+00	2.2267E-01	2.1597E+02

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9694300	0.9830470	0.9840830	0.9931140	0.9919620	3.0182E+02	5.2049E+00
$\alpha_2$	3.45E-03	1.12E-02	1.02E-02	2.26E-02	6.43E-03	3.4475E+00	3.0358E+02
$\alpha_3$	3.96E-04	4.27E-03	3.25E-03	1.16E-02	1.61E-03	1.3107E+00	3.0571E+02
$\alpha_4$	7.99E-07	1.22E-03	4.09E-04	5.18E-03	0.00E+00	3.7439E-01	3.0665E+02
$\alpha_5$	1.94E-21	2.35E-04	1.33E-07	1.36E-03	0.00E+00	7.2277E-02	3.0695E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9706900	0.9830130	0.9838750	0.9923820	0.9919490	3.6334E+02	6.2786E+00
$\alpha_2$	3.22E-03	9.97E-03	9.10E-03	1.97E-02	5.81E-03	3.6836E+00	3.6593E+02
$\alpha_3$	5.52E-04	4.29E-03	3.44E-03	1.10E-02	1.79E-03	1.5862E+00	3.6803E+02
$\alpha_4$	3.37E-05	1.90E-03	1.11E-03	6.46E-03	4.47E-04	7.0332E-01	3.6892E+02
$\alpha_5$	2.51E-09	6.01E-04	8.13E-05	3.01E-03	0.00E+00	2.2220E-01	3.6940E+02
$\alpha_6$	3.81E-19	2.25E-04	3.93E-07	1.31E-03	0.00E+00	8.3237E-02	3.6954E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9715390	0.9824050	0.9830690	0.9910020	0.9930910	4.7152E+02	8.4449E+00
$\alpha_2$	3.08E-03	8.72E-03	8.04E-03	1.66E-02	3.79E-03	4.1841E+00	4.7578E+02
$\alpha_3$	9.85E-04	4.74E-03	4.07E-03	1.08E-02	2.23E-03	2.2756E+00	4.7769E+02
$\alpha_4$	2.00E-04	2.52E-03	1.88E-03	7.06E-03	7.68E-04	1.2111E+00	4.7875E+02
$\alpha_5$	7.97E-06	1.16E-03	5.82E-04	4.30E-03	1.28E-04	5.5877E-01	4.7941E+02
$\alpha_6$	1.40E-10	3.88E-04	3.31E-05	2.04E-03	0.00E+00	1.8628E-01	4.7978E+02
$\alpha_7$	0.00E+00	6.06E-05	5.29E-14	2.28E-04	0.00E+00	2.9071E-02	4.7994E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9731250	0.9830060	0.9835780	0.9909240	0.9939490	5.4726E+02	9.4610E+00
$\alpha_2$	2.65E-03	7.51E-03	6.93E-03	1.44E-02	2.53E-03	4.1822E+00	5.5254E+02
$\alpha_3$	9.93E-04	4.41E-03	3.83E-03	9.80E-03	2.16E-03	2.4535E+00	5.5427E+02
$\alpha_4$	3.07E-04	2.66E-03	2.10E-03	6.96E-03	1.02E-03	1.4828E+00	5.5524E+02
$\alpha_5$	4.09E-05	1.45E-03	9.14E-04	4.68E-03	2.99E-04	8.0713E-01	5.5591E+02
$\alpha_6$	4.89E-07	6.81E-04	2.32E-04	2.88E-03	3.72E-05	3.7926E-01	5.5634E+02
$\alpha_7$	2.92E-14	2.21E-04	3.97E-06	1.26E-03	0.00E+00	1.2297E-01	5.5660E+02
$\alpha_8$	5.48E-43	5.95E-05	8.47E-13	2.51E-04	0.00E+00	3.3124E-02	5.5669E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9972410	0.9944660	0.9916770	0.9919620	0.9919490	0.9930910	0.9939490
$\alpha_2$	2.76E-03	5.53E-03	8.32E-03	6.43E-03	5.81E-03	3.79E-03	2.53E-03
$\alpha_3$		0.00E+00	0.00E+00	1.61E-03	1.79E-03	2.23E-03	2.16E-03
$\alpha_4$			0.00E+00	0.00E+00	4.47E-04	7.68E-04	1.02E-03
$\alpha_5$				0.00E+00	0.00E+00	1.28E-04	2.99E-04
$\alpha_6$					0.00E+00	0.00E+00	3.72E-05
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.97E-01	9.94E-01	9.92E-01	9.92E-01	9.92E-01	9.93E-01	9.94E-01
Beta	2.76E-03	5.53E-03	8.32E-03	8.04E-03	8.05E-03	6.91E-03	6.05E-03
Gamma		0.00E+00	0.00E+00	2.00E-01	2.78E-01	4.52E-01	5.81E-01
Delta			0.00E+00	0.00E+00	2.00E-01	2.87E-01	3.85E-01
Epsilon				0.00E+00	0.00E+00	1.43E-01	2.48E-01
Mu					0.00E+00	0.00E+00	1.11E-01
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	82.13	123.20	164.27	205.33	246.40	287.47	328.53
N <sub>1</sub>	2.2000	2.6000	2.5333	0.3333	0.0000	0.0000	0.0000
N <sub>2</sub>	0.2333	0.7000	1.4000	1.3333	1.4444	1.0963	0.8375
N <sub>3</sub>		0.0000	0.0000	0.3333	0.4444	0.6444	0.7151
N <sub>4</sub>			0.0000	0.0000	0.1111	0.2222	0.3363
N <sub>5</sub>				0.0000	0.0000	0.0370	0.0988
N <sub>6</sub>					0.0000	0.0000	0.0123
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

**1.3.2 PWR Containment Spray Motor Operated Valves****1.3.2.1 CONTAINMENT SPRAY MOV-CC**

System : Containment spray recirculation  
 Component : Motor Operated Valve  
 Failure Mode : Fail to open on demand  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 13.50

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9279790	0.9820300	0.9926730	0.9999640	1.0000000	2.3746E+01	4.3452E-01
$\alpha_2$	3.27E-05	1.80E-02	7.33E-03	7.20E-02	0.00E+00	4.3452E-01	2.3746E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9287040	0.9750680	0.9818160	0.9983530	1.0000000	4.3055E+01	1.1009E+00
$\alpha_2$	5.99E-04	1.89E-02	1.23E-02	5.98E-02	0.00E+00	8.3366E-01	4.3322E+01
$\alpha_3$	2.12E-07	6.05E-03	1.22E-03	2.87E-02	0.00E+00	2.6722E-01	4.3889E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9277020	0.9698320	0.9747770	0.9950350	1.0000000	5.9636E+01	1.8551E+00
$\alpha_2$	1.65E-03	2.00E-02	1.50E-02	5.51E-02	0.00E+00	1.2281E+00	6.0263E+01
$\alpha_3$	7.41E-06	6.58E-03	2.44E-03	2.72E-02	0.00E+00	4.0431E-01	6.1087E+01
$\alpha_4$	1.56E-08	3.62E-03	4.96E-04	1.81E-02	0.00E+00	2.2267E-01	6.1268E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9380830	0.9687430	0.9714630	0.9900880	1.0000000	1.0966E+02	3.5382E+00
$\alpha_2$	3.60E-03	1.87E-02	1.59E-02	4.32E-02	0.00E+00	2.1142E+00	1.1108E+02
$\alpha_3$	4.22E-04	8.63E-03	5.96E-03	2.60E-02	0.00E+00	9.7738E-01	1.1222E+02
$\alpha_4$	2.17E-06	3.31E-03	1.11E-03	1.40E-02	0.00E+00	3.7439E-01	1.1282E+02
$\alpha_5$	5.27E-21	6.38E-04	3.61E-07	3.70E-03	0.00E+00	7.2277E-02	1.1313E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9401620	0.9682400	0.9705290	0.9884810	1.0000000	1.3044E+02	4.2787E+00
$\alpha_2$	3.42E-03	1.66E-02	1.43E-02	3.78E-02	0.00E+00	2.2392E+00	1.3248E+02
$\alpha_3$	5.97E-04	8.48E-03	6.20E-03	2.41E-02	0.00E+00	1.1418E+00	1.3358E+02
$\alpha_4$	3.93E-05	4.40E-03	2.30E-03	1.59E-02	0.00E+00	5.9222E-01	1.3413E+02
$\alpha_5$	6.89E-09	1.65E-03	2.24E-04	8.26E-03	0.00E+00	2.2220E-01	1.3450E+02
$\alpha_6$	1.05E-18	6.18E-04	1.08E-06	3.61E-03	0.00E+00	8.3237E-02	1.3464E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	13.50	13.50	13.50	13.50	13.50
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000
N <sub>6</sub>					0.0000

### 1.3.2.2 CONTAINMENT SPRAY MOV-OO

System :

Containment spray recirculation

Component :

Motor Operated Valve

Failure Mode :

Fail to close (reseat) on demand

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 7.00

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9017830	0.9754240	0.9898730	0.9999510	1.0000000	1.7246E+01	4.3452E-01
$\alpha_2$	4.52E-05	2.46E-02	1.01E-02	9.82E-02	0.00E+00	4.3452E-01	1.7246E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9165860	0.9707650	0.9786210	0.9980670	1.0000000	3.6555E+01	1.1009E+00
$\alpha_2$	7.05E-04	2.21E-02	1.44E-02	7.00E-02	0.00E+00	8.3366E-01	3.6822E+01
$\alpha_3$	2.49E-07	7.10E-03	1.44E-03	3.37E-02	0.00E+00	2.6722E-01	3.7389E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9192920	0.9662660	0.9717540	0.9944390	1.0000000	5.3136E+01	1.8551E+00
$\alpha_2$	1.85E-03	2.23E-02	1.68E-02	6.16E-02	0.00E+00	1.2281E+00	5.3763E+01
$\alpha_3$	8.29E-06	7.35E-03	2.73E-03	3.04E-02	0.00E+00	4.0431E-01	5.4587E+01
$\alpha_4$	1.75E-08	4.05E-03	5.55E-04	2.03E-02	0.00E+00	2.2267E-01	5.4768E+01

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9343580	0.9668390	0.9697150	0.9894740	1.0000000	1.0316E+02	3.5382E+00
$\alpha_2$	3.82E-03	1.98E-02	1.69E-02	4.58E-02	0.00E+00	2.1142E+00	1.0458E+02
$\alpha_3$	4.48E-04	9.16E-03	6.33E-03	2.75E-02	0.00E+00	9.7738E-01	1.0572E+02
$\alpha_4$	2.31E-06	3.51E-03	1.18E-03	1.49E-02	0.00E+00	3.7439E-01	1.0632E+02
$\alpha_5$	5.59E-21	6.77E-04	3.83E-07	3.92E-03	0.00E+00	7.2277E-02	1.0663E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9371630	0.9666300	0.9690330	0.9878880	1.0000000	1.2394E+02	4.2787E+00
$\alpha_2$	3.59E-03	1.75E-02	1.50E-02	3.97E-02	0.00E+00	2.2392E+00	1.2598E+02
$\alpha_3$	6.27E-04	8.91E-03	6.51E-03	2.54E-02	0.00E+00	1.1418E+00	1.2708E+02
$\alpha_4$	4.13E-05	4.62E-03	2.42E-03	1.67E-02	0.00E+00	5.9222E-01	1.2763E+02
$\alpha_5$	7.25E-09	1.73E-03	2.35E-04	8.68E-03	0.00E+00	2.2220E-01	1.2800E+02
$\alpha_6$	1.10E-18	6.49E-04	1.14E-06	3.79E-03	0.00E+00	8.3237E-02	1.2814E+02

**ALPHA FACTOR and MGL PARAMETERS**

<b>Alpha Factor</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

<b>MGL Parameter</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>
<b>1-Beta</b>	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
<b>Beta</b>	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00

<b>Avg. Impact Vector</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>
<b>Adj. Ind. Events</b>	7.00	7.00	7.00	7.00	7.00
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000

### 1.3.3 BWR Residual Heat Removal Motor-Operated Valves

#### 1.3.3.1 BWR RHR MOV FAIL TO OPEN

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)					
Component :	Motor Operated Valve					
Failure Mode :	Fail to open on demand					
Plant Type :	BWR					
Start Date :	1997/01/01					
Data Version :	2009/12/31					

Total Number of Independent Failure Events: 70.90

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9544520	0.9826290	0.9863500	0.9980820	0.9860920	8.1146E+01	1.4345E+00
$\alpha_2$	1.92E-03	1.74E-02	1.37E-02	4.56E-02	1.39E-02	1.4345E+00	8.1146E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9646820	0.9847760	0.9870520	0.9971000	0.9906850	1.3590E+02	2.1009E+00
$\alpha_2$	9.30E-04	9.66E-03	7.42E-03	2.61E-02	4.66E-03	1.3337E+00	1.3667E+02
$\alpha_3$	1.34E-04	5.56E-03	3.42E-03	1.83E-02	4.66E-03	7.6722E-01	1.3723E+02

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9683330	0.9850360	0.9866980	0.9960690	0.9929970	1.8794E+02	2.8551E+00
$\alpha_2$	8.92E-04	7.75E-03	6.11E-03	2.02E-02	1.75E-03	1.4781E+00	1.8932E+02
$\alpha_3$	1.87E-04	4.74E-03	3.16E-03	1.47E-02	3.50E-03	9.0431E-01	1.8989E+02
$\alpha_4$	7.20E-06	2.48E-03	1.07E-03	9.70E-03	1.75E-03	4.7267E-01	1.9032E+02

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9695380	0.9836720	0.9848160	0.9938940	0.9943900	2.7341E+02	4.5383E+00
$\alpha_2$	1.65E-03	8.06E-03	6.91E-03	1.84E-02	7.01E-04	2.2392E+00	2.7571E+02
$\alpha_3$	4.78E-04	4.87E-03	3.74E-03	1.31E-02	2.10E-03	1.3524E+00	2.7660E+02
$\alpha_4$	5.98E-05	2.70E-03	1.64E-03	8.94E-03	2.10E-03	7.4939E-01	2.7720E+02
$\alpha_5$	5.97E-10	7.10E-04	7.11E-05	3.67E-03	7.01E-04	1.9728E-01	2.7775E+02

##### CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9716680	0.9842390	0.9851910	0.9935510	0.9953210	3.2964E+02	5.2787E+00
$\alpha_2$	1.45E-03	6.87E-03	5.92E-03	1.56E-02	2.92E-04	2.3017E+00	3.3262E+02
$\alpha_3$	4.30E-04	4.16E-03	3.22E-03	1.11E-02	1.17E-03	1.3918E+00	3.3353E+02
$\alpha_4$	1.37E-04	2.89E-03	1.98E-03	8.74E-03	1.75E-03	9.6722E-01	3.3395E+02
$\alpha_5$	4.07E-06	1.41E-03	6.10E-04	5.52E-03	1.17E-03	4.7220E-01	3.3445E+02
$\alpha_6$	2.22E-12	4.35E-04	1.62E-05	2.41E-03	2.92E-04	1.4574E-01	3.3477E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9718620	0.9830650	0.9837900	0.9917810	0.9959860	4.3220E+02	7.4452E+00
$\alpha_2$	2.01E-03	7.09E-03	6.36E-03	1.47E-02	1.26E-04	3.1191E+00	4.3653E+02
$\alpha_3$	6.24E-04	4.07E-03	3.34E-03	9.98E-03	6.27E-04	1.7875E+00	4.3786E+02
$\alpha_4$	2.71E-04	2.96E-03	2.25E-03	8.08E-03	1.25E-03	1.3014E+00	4.3834E+02
$\alpha_5$	5.93E-05	1.90E-03	1.22E-03	6.06E-03	1.25E-03	8.3427E-01	4.3881E+02
$\alpha_6$	2.60E-07	7.79E-04	2.32E-04	3.41E-03	6.27E-04	3.4258E-01	4.3930E+02
$\alpha_7$	3.78E-25	1.37E-04	1.38E-08	7.71E-04	1.26E-04	6.0371E-02	4.3958E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9732040	0.9834350	0.9840600	0.9915250	0.9964860	5.0233E+02	8.4611E+00
$\alpha_2$	1.98E-03	6.58E-03	5.95E-03	1.33E-02	5.48E-05	3.3603E+00	5.0743E+02
$\alpha_3$	5.70E-04	3.59E-03	2.96E-03	8.74E-03	3.30E-04	1.8322E+00	5.0896E+02
$\alpha_4$	2.76E-04	2.70E-03	2.09E-03	7.23E-03	8.24E-04	1.3809E+00	5.0941E+02
$\alpha_5$	1.08E-04	2.00E-03	1.40E-03	5.94E-03	1.10E-03	1.0208E+00	5.0977E+02
$\alpha_6$	1.12E-05	1.18E-03	6.21E-04	4.23E-03	8.24E-04	6.0136E-01	5.1019E+02
$\alpha_7$	1.29E-09	4.24E-04	5.41E-05	2.14E-03	3.30E-04	2.1677E-01	5.1057E+02
$\alpha_8$	2.27E-30	9.54E-05	7.59E-10	5.03E-04	5.48E-05	4.8724E-02	5.1074E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9860920	0.9906850	0.9929970	0.9943900	0.9953210	0.9959860	0.9964860
$\alpha_2$	1.39E-02	4.66E-03	1.75E-03	7.01E-04	2.92E-04	1.26E-04	5.48E-05
$\alpha_3$		4.66E-03	3.50E-03	2.10E-03	1.17E-03	6.27E-04	3.30E-04
$\alpha_4$			1.75E-03	2.10E-03	1.75E-03	1.25E-03	8.24E-04
$\alpha_5$				7.01E-04	1.17E-03	1.25E-03	1.10E-03
$\alpha_6$					2.92E-04	6.27E-04	8.24E-04
$\alpha_7$						1.26E-04	3.30E-04
$\alpha_8$							5.48E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.86E-01	9.91E-01	9.93E-01	9.94E-01	9.95E-01	9.96E-01	9.96E-01
<b>Beta</b>	1.39E-02	9.32E-03	7.00E-03	5.61E-03	4.68E-03	4.01E-03	3.51E-03
<b>Gamma</b>		5.00E-01	7.50E-01	8.75E-01	9.38E-01	9.69E-01	9.84E-01
<b>Delta</b>			3.33E-01	5.71E-01	7.33E-01	8.39E-01	9.05E-01
<b>Epsilon</b>				2.50E-01	4.55E-01	6.15E-01	7.37E-01
<b>Mu</b>					2.00E-01	3.75E-01	5.24E-01
<b>Upsilon</b>						1.67E-01	3.18E-01
<b>Sigma</b>							1.43E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	70.90	106.35	141.80	177.25	212.70	248.15	283.60
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	1.0000	0.5000	0.2500	0.1250	0.0625	0.0313	0.0156
N <sub>3</sub>		0.5000	0.5000	0.3750	0.2500	0.1563	0.0938
N <sub>4</sub>			0.2500	0.3750	0.3750	0.3125	0.2344
N <sub>5</sub>				0.1250	0.2500	0.3125	0.3125
N <sub>6</sub>					0.0625	0.1563	0.2344
N <sub>7</sub>						0.0313	0.0938
N <sub>8</sub>							0.0156

### 1.3.3.2 BWR RHR MOV FAIL TO CLOSE

System :

Residual Heat Removal (LCI in BWRs, LPI in PWRs)

Component :

Motor Operated Valve

Failure Mode :

Fail to close (reseat) on demand

Plant Type :

BWR

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 46.30

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9491540	0.9873430	0.9948750	0.9999750	1.0000000	3.3896E+01	4.3452E-01
$\alpha_2$	2.28E-05	1.27E-02	5.12E-03	5.08E-02	0.00E+00	4.3452E-01	3.3896E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9521840	0.9833520	0.9879130	0.9989090	1.0000000	6.5025E+01	1.1009E+00
$\alpha_2$	3.97E-04	1.26E-02	8.15E-03	4.00E-02	0.00E+00	8.3366E-01	6.5292E+01
$\alpha_3$	1.41E-07	4.04E-03	8.12E-04	1.92E-02	0.00E+00	2.6722E-01	6.5859E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9531150	0.9805320	0.9837870	0.9968240	1.0000000	9.3436E+01	1.8551E+00
$\alpha_2$	1.06E-03	1.29E-02	9.67E-03	3.57E-02	0.00E+00	1.2281E+00	9.4063E+01
$\alpha_3$	4.76E-06	4.24E-03	1.57E-03	1.75E-02	0.00E+00	4.0431E-01	9.4887E+01
$\alpha_4$	1.01E-08	2.34E-03	3.19E-04	1.17E-02	0.00E+00	2.2267E-01	9.5068E+01

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9553810	0.9775460	0.9795350	0.9929140	1.0000000	1.5404E+02	3.5382E+00
$\alpha_2$	2.57E-03	1.34E-02	1.14E-02	3.11E-02	0.00E+00	2.1142E+00	1.5546E+02
$\alpha_3$	3.02E-04	6.20E-03	4.28E-03	1.87E-02	0.00E+00	9.7738E-01	1.5660E+02
$\alpha_4$	1.56E-06	2.38E-03	7.99E-04	1.01E-02	0.00E+00	3.7439E-01	1.5720E+02
$\alpha_5$	3.78E-21	4.59E-04	2.59E-07	2.65E-03	0.00E+00	7.2277E-02	1.5751E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9575880	0.9775600	0.9792080	0.9918990	1.0000000	1.8639E+02	4.2787E+00
$\alpha_2$	2.41E-03	1.17E-02	1.01E-02	2.68E-02	0.00E+00	2.2392E+00	1.8843E+02
$\alpha_3$	4.21E-04	5.99E-03	4.37E-03	1.71E-02	0.00E+00	1.1418E+00	1.8953E+02
$\alpha_4$	2.77E-05	3.11E-03	1.62E-03	1.12E-02	0.00E+00	5.9222E-01	1.9008E+02
$\alpha_5$	4.87E-09	1.17E-03	1.58E-04	5.84E-03	0.00E+00	2.2220E-01	1.9045E+02
$\alpha_6$	7.39E-19	4.37E-04	7.63E-07	2.55E-03	0.00E+00	8.3237E-02	1.9059E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9593660	0.9762640	0.9774270	0.9891940	1.0000000	2.6508E+02	6.4450E+00
$\alpha_2$	3.20E-03	1.14E-02	1.02E-02	2.36E-02	0.00E+00	3.0878E+00	2.6844E+02
$\alpha_3$	8.08E-04	6.01E-03	4.85E-03	1.52E-02	0.00E+00	1.6312E+00	2.6989E+02
$\alpha_4$	1.82E-04	3.64E-03	2.52E-03	1.09E-02	0.00E+00	9.8887E-01	2.7054E+02
$\alpha_5$	9.44E-06	1.92E-03	9.09E-04	7.26E-03	0.00E+00	5.2177E-01	2.7100E+02
$\alpha_6$	2.47E-10	6.86E-04	5.85E-05	3.60E-03	0.00E+00	1.8628E-01	2.7134E+02
$\alpha_7$	0.00E+00	1.07E-04	9.37E-14	4.03E-04	0.00E+00	2.9071E-02	2.7150E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9612040	0.9765960	0.9775890	0.9886120	1.0000000	3.1133E+02	7.4610E+00
$\alpha_2$	3.15E-03	1.05E-02	9.49E-03	2.13E-02	0.00E+00	3.3447E+00	3.1545E+02
$\alpha_3$	8.06E-04	5.45E-03	4.46E-03	1.35E-02	0.00E+00	1.7384E+00	3.1705E+02
$\alpha_4$	2.54E-04	3.60E-03	2.63E-03	1.03E-02	0.00E+00	1.1465E+00	3.1764E+02
$\alpha_5$	4.04E-05	2.22E-03	1.30E-03	7.52E-03	0.00E+00	7.0833E-01	3.1808E+02
$\alpha_6$	6.51E-07	1.15E-03	3.77E-04	4.92E-03	0.00E+00	3.6696E-01	3.1842E+02
$\alpha_7$	5.11E-14	3.86E-04	6.93E-06	2.20E-03	0.00E+00	1.2297E-01	3.1867E+02
$\alpha_8$	9.56E-43	1.04E-04	1.48E-12	4.39E-04	0.00E+00	3.3124E-02	3.1876E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	23.15	34.72	46.30	57.88	69.45	81.03	92.60
N <sub>1</sub>	0.5000	0.7500	1.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

**1.3.4 BWR Isolation Condenser Motor-Operated Valves****1.3.4.1 ISO CONDENSER MOV FAIL TO OPEN**

System : Isolation condenser  
 Component : Motor Operated Valve  
 Failure Mode : Fail to open on demand  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 6.00

Total Number of Common-Cause Failure Events: 0

### ALPHA FACTOR DISTRIBUTIONS

#### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8959650	0.9739500	0.9892430	0.9999480	1.0000000	1.6246E+01	4.3452E-01
$\alpha_2$	4.81E-05	2.60E-02	1.08E-02	1.04E-01	0.00E+00	4.3452E-01	1.6246E+01

#### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9143470	0.9699670	0.9780280	0.9980130	1.0000000	3.5555E+01	1.1009E+00
$\alpha_2$	7.25E-04	2.27E-02	1.48E-02	7.18E-02	0.00E+00	8.3366E-01	3.5822E+01
$\alpha_3$	2.56E-07	7.29E-03	1.48E-03	3.46E-02	0.00E+00	2.6722E-01	3.6389E+01

#### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9178250	0.9656410	0.9712250	0.9943340	1.0000000	5.2136E+01	1.8551E+00
$\alpha_2$	1.89E-03	2.27E-02	1.72E-02	6.27E-02	0.00E+00	1.2281E+00	5.2763E+01
$\alpha_3$	8.45E-06	7.49E-03	2.78E-03	3.09E-02	0.00E+00	4.0431E-01	5.3587E+01
$\alpha_4$	1.78E-08	4.12E-03	5.66E-04	2.07E-02	0.00E+00	2.2267E-01	5.3768E+01

#### **CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9337450	0.9665250	0.9694270	0.9893730	1.0000000	1.0216E+02	3.5382E+00
$\alpha_2$	3.85E-03	2.00E-02	1.71E-02	4.62E-02	0.00E+00	2.1142E+00	1.0358E+02
$\alpha_3$	4.52E-04	9.25E-03	6.39E-03	2.78E-02	0.00E+00	9.7738E-01	1.0472E+02
$\alpha_4$	2.33E-06	3.54E-03	1.19E-03	1.50E-02	0.00E+00	3.7439E-01	1.0532E+02
$\alpha_5$	5.65E-21	6.84E-04	3.87E-07	3.96E-03	0.00E+00	7.2277E-02	1.0563E+02

#### **CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9366750	0.9663680	0.9687880	0.9877920	1.0000000	1.2294E+02	4.2787E+00
$\alpha_2$	3.62E-03	1.76E-02	1.51E-02	4.00E-02	0.00E+00	2.2392E+00	1.2498E+02
$\alpha_3$	6.32E-04	8.98E-03	6.57E-03	2.55E-02	0.00E+00	1.1418E+00	1.2608E+02
$\alpha_4$	4.16E-05	4.66E-03	2.44E-03	1.68E-02	0.00E+00	5.9222E-01	1.2663E+02
$\alpha_5$	7.30E-09	1.75E-03	2.37E-04	8.75E-03	0.00E+00	2.2220E-01	1.2700E+02
$\alpha_6$	1.11E-18	6.54E-04	1.14E-06	3.82E-03	0.00E+00	8.3237E-02	1.2714E+02

### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	6.00	6.00	6.00	6.00	6.00
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000
N <sub>6</sub>					0.0000

### 1.3.4.2 ISO CONDENSER MOV FAIL TO CLOSE

System :

Isolation condenser

Component :

Motor Operated Valve

Failure Mode :

Fail to close (reseat) on demand

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8636860	0.9657330	0.9856730	0.9999380	1.0000000	1.2246E+01	4.3452E-01
$\alpha_2$	6.41E-05	3.43E-02	1.43E-02	1.36E-01	0.00E+00	4.3452E-01	1.2246E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9040420	0.9662880	0.9752810	0.9977560	1.0000000	3.1555E+01	1.1009E+00
$\alpha_2$	8.16E-04	2.55E-02	1.67E-02	8.05E-02	0.00E+00	8.3366E-01	3.1822E+01
$\alpha_3$	2.88E-07	8.18E-03	1.66E-03	3.88E-02	0.00E+00	2.6722E-01	3.2389E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9113590	0.9628920	0.9688970	0.9938680	1.0000000	4.8136E+01	1.8551E+00
$\alpha_2$	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
$\alpha_3$	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
$\alpha_4$	1.93E-08	4.45E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9768E+01

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9311740	0.9652090	0.9682200	0.9889480	1.0000000	9.8161E+01	3.5382E+00
$\alpha_2$	4.01E-03	2.08E-02	1.77E-02	4.80E-02	0.00E+00	2.1142E+00	9.9585E+01
$\alpha_3$	4.70E-04	9.61E-03	6.64E-03	2.89E-02	0.00E+00	9.7738E-01	1.0072E+02
$\alpha_4$	2.42E-06	3.68E-03	1.24E-03	1.56E-02	0.00E+00	3.7439E-01	1.0132E+02
$\alpha_5$	5.87E-21	7.11E-04	4.02E-07	4.12E-03	0.00E+00	7.2277E-02	1.0163E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9346440	0.9652760	0.9677640	0.9873890	1.0000000	1.1894E+02	4.2787E+00
$\alpha_2$	3.74E-03	1.82E-02	1.56E-02	4.13E-02	0.00E+00	2.2392E+00	1.2098E+02
$\alpha_3$	6.53E-04	9.27E-03	6.78E-03	2.64E-02	0.00E+00	1.1418E+00	1.2208E+02
$\alpha_4$	4.30E-05	4.81E-03	2.52E-03	1.73E-02	0.00E+00	5.9222E-01	1.2263E+02
$\alpha_5$	7.54E-09	1.80E-03	2.45E-04	9.04E-03	0.00E+00	2.2220E-01	1.2300E+02
$\alpha_6$	1.14E-18	6.76E-04	1.18E-06	3.94E-03	0.00E+00	8.3237E-02	1.2314E+02

**ALPHA FACTOR and MGL PARAMETERS**

<b>Alpha Factor</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

<b>MGL Parameter</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>
<b>1-Beta</b>	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
<b>Beta</b>	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00

<b>Avg. Impact Vector</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>
<b>Adj. Ind. Events</b>	2.00	2.00	2.00	2.00	2.00
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000

### 1.3.5 PWR Auxiliary Feedwater Motor-Operated Valves

#### 1.3.5.1 AFW MOV FAIL TO OPEN SPAR: AFW-MOV-CC

System :	Auxiliary feedwater
Component :	Motor Operated Valve
Failure Mode :	Fail to open on demand
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 23.20

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8854700	0.9669700	0.9813120	0.9995880	0.9765530	1.8576E+01	6.3452E-01
$\alpha_2$	4.10E-04	3.30E-02	1.87E-02	1.15E-01	2.34E-02	6.3452E-01	1.8576E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9071980	0.9629470	0.9698510	0.9950370	0.9601590	4.1605E+01	1.6009E+00
$\alpha_2$	2.71E-03	2.97E-02	2.28E-02	8.04E-02	3.59E-02	1.2837E+00	4.1922E+01
$\alpha_3$	1.31E-06	7.34E-03	1.98E-03	3.29E-02	3.98E-03	3.1722E-01	4.2889E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9119230	0.9588110	0.9634770	0.9897350	0.9514270	6.1806E+01	2.6551E+00
$\alpha_2$	4.57E-03	2.84E-02	2.36E-02	6.83E-02	3.64E-02	1.8281E+00	6.2633E+01
$\alpha_3$	9.21E-05	9.37E-03	5.01E-03	3.35E-02	1.21E-02	6.0431E-01	6.3857E+01
$\alpha_4$	1.49E-08	3.45E-03	4.73E-04	1.73E-02	0.00E+00	2.2267E-01	6.4238E+01

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9299610	0.9621900	0.9647310	0.9857230	0.9508120	1.1549E+02	4.5383E+00
$\alpha_2$	5.29E-03	2.18E-02	1.92E-02	4.72E-02	2.46E-02	2.6142E+00	1.1741E+02
$\alpha_3$	1.42E-03	1.23E-02	9.72E-03	3.20E-02	2.46E-02	1.4774E+00	1.1855E+02
$\alpha_4$	2.05E-06	3.12E-03	1.05E-03	1.32E-02	0.00E+00	3.7439E-01	1.1965E+02
$\alpha_5$	4.97E-21	6.02E-04	3.40E-07	3.49E-03	0.00E+00	7.2277E-02	1.1996E+02

##### CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9351640	0.9637000	0.9658110	0.9850320	0.9586780	1.4014E+02	5.2787E+00
$\alpha_2$	3.16E-03	1.54E-02	1.32E-02	3.50E-02	0.00E+00	2.2392E+00	1.4318E+02
$\alpha_3$	2.87E-03	1.47E-02	1.26E-02	3.40E-02	4.13E-02	2.1418E+00	1.4328E+02
$\alpha_4$	3.64E-05	4.07E-03	2.13E-03	1.47E-02	0.00E+00	5.9222E-01	1.4483E+02
$\alpha_5$	6.39E-09	1.53E-03	2.07E-04	7.66E-03	0.00E+00	2.2220E-01	1.4520E+02
$\alpha_6$	9.69E-19	5.72E-04	1.00E-06	3.34E-03	0.00E+00	8.3237E-02	1.4534E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9436710	0.9659370	0.9673480	0.9833820	0.9643750	2.1112E+02	7.4450E+00
$\alpha_2$	3.98E-03	1.41E-02	1.27E-02	2.92E-02	0.00E+00	3.0878E+00	2.1548E+02
$\alpha_3$	2.08E-03	1.02E-02	8.76E-03	2.33E-02	2.14E-02	2.2312E+00	2.1633E+02
$\alpha_4$	6.56E-04	6.35E-03	4.93E-03	1.69E-02	1.43E-02	1.3889E+00	2.1718E+02
$\alpha_5$	1.17E-05	2.39E-03	1.13E-03	9.02E-03	0.00E+00	5.2177E-01	2.1804E+02
$\alpha_6$	3.07E-10	8.52E-04	7.28E-05	4.47E-03	0.00E+00	1.8628E-01	2.1838E+02
$\alpha_7$	0.00E+00	1.33E-04	1.16E-13	5.01E-04	0.00E+00	2.9071E-02	2.1854E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9471990	0.9672210	0.9684240	0.9831430	0.9686810	2.4966E+02	8.4610E+00
$\alpha_2$	3.90E-03	1.30E-02	1.17E-02	2.62E-02	0.00E+00	3.3447E+00	2.5478E+02
$\alpha_3$	1.54E-03	8.13E-03	6.90E-03	1.89E-02	1.13E-02	2.0984E+00	2.5602E+02
$\alpha_4$	8.44E-04	6.30E-03	5.08E-03	1.59E-02	1.50E-02	1.6265E+00	2.5649E+02
$\alpha_5$	1.18E-04	3.36E-03	2.20E-03	1.06E-02	5.01E-03	8.6833E-01	2.5725E+02
$\alpha_6$	8.04E-07	1.42E-03	4.65E-04	6.08E-03	0.00E+00	3.6696E-01	2.5775E+02
$\alpha_7$	6.31E-14	4.76E-04	8.57E-06	2.71E-03	0.00E+00	1.2297E-01	2.5800E+02
$\alpha_8$	1.18E-42	1.28E-04	1.83E-12	5.42E-04	0.00E+00	3.3124E-02	2.5809E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9765530	0.9601590	0.9514270	0.9508120	0.9586780	0.9643750	0.9686810
$\alpha_2$	2.34E-02	3.59E-02	3.64E-02	2.46E-02	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		3.98E-03	1.21E-02	2.46E-02	4.13E-02	2.14E-02	1.13E-02
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	1.43E-02	1.50E-02
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	5.01E-03
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.77E-01	9.60E-01	9.51E-01	9.51E-01	9.59E-01	9.64E-01	9.69E-01
<b>Beta</b>	2.34E-02	3.98E-02	4.86E-02	4.92E-02	4.13E-02	3.56E-02	3.13E-02
<b>Gamma</b>		1.00E-01	2.50E-01	5.00E-01	1.00E+00	1.00E+00	1.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	4.00E-01	6.40E-01
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	2.50E-01
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	7.73	11.60	15.47	19.33	23.20	27.07	30.93
N <sub>1</sub>	0.6000	0.4500	0.2000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.2000	0.4500	0.6000	0.5000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0500	0.2000	0.5000	1.0000	0.6000	0.3600
N <sub>4</sub>			0.0000	0.0000	0.0000	0.4000	0.4800
N <sub>5</sub>				0.0000	0.0000	0.0000	0.1600
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

### 1.3.5.2 AFW MOV FAIL TO CLOSE SPAR: AFW-MOV-OO

System :

Auxiliary feedwater

Component :

Motor Operated Valve

Failure Mode :

Fail to close (reseat) on demand

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 24.60

Total Number of Common-Cause Failure Events: 2

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8963180	0.9695810	0.9822820	0.9995370	0.9793050	2.1286E+01	6.6782E-01
$\alpha_2$	4.60E-04	3.04E-02	1.77E-02	1.04E-01	2.07E-02	6.6782E-01	2.1286E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9080740	0.9618580	0.9681960	0.9939400	0.9577290	4.5415E+01	1.8009E+00
$\alpha_2$	4.05E-03	3.25E-02	2.61E-02	8.27E-02	4.23E-02	1.5337E+00	4.5682E+01
$\alpha_3$	1.98E-07	5.66E-03	1.14E-03	2.68E-02	0.00E+00	2.6722E-01	4.6949E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9058000	0.9532340	0.9575240	0.9860000	0.9352250	6.6349E+01	3.2551E+00
$\alpha_2$	9.30E-03	3.78E-02	3.34E-02	8.11E-02	6.48E-02	2.6281E+00	6.6976E+01
$\alpha_3$	6.53E-06	5.81E-03	2.15E-03	2.40E-02	0.00E+00	4.0431E-01	6.9200E+01
$\alpha_4$	1.38E-08	3.20E-03	4.38E-04	1.60E-02	0.00E+00	2.2267E-01	6.9381E+01

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9262580	0.9587880	0.9611940	0.9831010	0.9373460	1.2109E+02	5.2049E+00
$\alpha_2$	8.47E-03	2.73E-02	2.48E-02	5.45E-02	5.01E-02	3.4475E+00	1.2285E+02
$\alpha_3$	9.67E-04	1.04E-02	7.93E-03	2.82E-02	1.25E-02	1.3107E+00	1.2498E+02
$\alpha_4$	1.95E-06	2.96E-03	9.98E-04	1.26E-02	0.00E+00	3.7439E-01	1.2592E+02
$\alpha_5$	4.72E-21	5.72E-04	3.23E-07	3.31E-03	0.00E+00	7.2277E-02	1.2622E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9295760	0.9588930	0.9608820	0.9814120	0.9365510	1.4646E+02	6.2786E+00
$\alpha_2$	7.85E-03	2.41E-02	2.21E-02	4.74E-02	4.58E-02	3.6836E+00	1.4905E+02
$\alpha_3$	1.34E-03	1.04E-02	8.34E-03	2.64E-02	1.41E-02	1.5862E+00	1.5115E+02
$\alpha_4$	8.19E-05	4.60E-03	2.70E-03	1.56E-02	3.52E-03	7.0332E-01	1.5204E+02
$\alpha_5$	6.08E-09	1.45E-03	1.97E-04	7.29E-03	0.00E+00	2.2220E-01	1.5252E+02
$\alpha_6$	9.23E-19	5.45E-04	9.53E-07	3.18E-03	0.00E+00	8.3237E-02	1.5266E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9401030	0.9627870	0.9641420	0.9808520	0.9451180	2.1849E+02	8.4449E+00
$\alpha_2$	6.55E-03	1.84E-02	1.70E-02	3.51E-02	3.01E-02	4.1841E+00	2.2275E+02
$\alpha_3$	2.09E-03	1.00E-02	8.63E-03	2.27E-02	1.77E-02	2.2756E+00	2.2466E+02
$\alpha_4$	4.24E-04	5.34E-03	3.97E-03	1.49E-02	6.10E-03	1.2111E+00	2.2572E+02
$\alpha_5$	1.69E-05	2.46E-03	1.23E-03	9.08E-03	1.02E-03	5.5877E-01	2.2638E+02
$\alpha_6$	2.96E-10	8.21E-04	7.01E-05	4.31E-03	0.00E+00	1.8628E-01	2.2675E+02
$\alpha_7$	0.00E+00	1.28E-04	1.12E-13	4.82E-04	0.00E+00	2.9071E-02	2.2691E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9443330	0.9646390	0.9657930	0.9810040	0.9516440	2.5809E+02	9.4610E+00
$\alpha_2$	5.54E-03	1.56E-02	1.44E-02	2.98E-02	2.02E-02	4.1822E+00	2.6337E+02
$\alpha_3$	2.07E-03	9.17E-03	7.98E-03	2.03E-02	1.73E-02	2.4535E+00	2.6510E+02
$\alpha_4$	6.40E-04	5.54E-03	4.37E-03	1.45E-02	8.13E-03	1.4828E+00	2.6607E+02
$\alpha_5$	8.52E-05	3.02E-03	1.90E-03	9.74E-03	2.39E-03	8.0713E-01	2.6674E+02
$\alpha_6$	1.02E-06	1.42E-03	4.84E-04	6.00E-03	2.97E-04	3.7926E-01	2.6717E+02
$\alpha_7$	6.08E-14	4.60E-04	8.26E-06	2.62E-03	0.00E+00	1.2297E-01	2.6743E+02
$\alpha_8$	1.14E-42	1.24E-04	1.76E-12	5.23E-04	0.00E+00	3.3124E-02	2.6752E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9793050	0.9577290	0.9352250	0.9373460	0.9365510	0.9451180	0.9516440
$\alpha_2$	2.07E-02	4.23E-02	6.48E-02	5.01E-02	4.58E-02	3.01E-02	2.02E-02
$\alpha_3$		0.00E+00	0.00E+00	1.25E-02	1.41E-02	1.77E-02	1.73E-02
$\alpha_4$			0.00E+00	0.00E+00	3.52E-03	6.10E-03	8.13E-03
$\alpha_5$				0.00E+00	0.00E+00	1.02E-03	2.39E-03
$\alpha_6$					0.00E+00	0.00E+00	2.97E-04
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.79E-01	9.58E-01	9.35E-01	9.37E-01	9.37E-01	9.45E-01	9.52E-01
Beta	2.07E-02	4.23E-02	6.48E-02	6.27E-02	6.34E-02	5.49E-02	4.84E-02
Gamma		0.00E+00	0.00E+00	2.00E-01	2.78E-01	4.52E-01	5.81E-01
Delta			0.00E+00	0.00E+00	2.00E-01	2.87E-01	3.85E-01
Epsilon				0.00E+00	0.00E+00	1.43E-01	2.48E-01
Mu					0.00E+00	0.00E+00	1.11E-01
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	9.84	14.76	19.68	24.60	29.52	34.44	39.36
N <sub>1</sub>	1.2000	1.1000	0.5333	0.3333	0.0000	0.0000	0.0000
N <sub>2</sub>	0.2333	0.7000	1.4000	1.3333	1.4444	1.0963	0.8375
N <sub>3</sub>		0.0000	0.0000	0.3333	0.4444	0.6444	0.7151
N <sub>4</sub>			0.0000	0.0000	0.1111	0.2222	0.3363
N <sub>5</sub>				0.0000	0.0000	0.0370	0.0988
N <sub>6</sub>					0.0000	0.0000	0.0123
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

**1.3.5.3 AFW MOV FAIL TO OPERATE ALL SYSTEMS SPAR: AFW-MOV-FO**

System :

Auxiliary feedwater

Component :

Motor Operated Valve

Failure Mode :

Fail to close (reseat) on demand

Fail to open on demand

Fail to Operate (Open/Close)

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 50.80

Total Number of Common-Cause Failure Events: 3

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9156850	0.9728580	0.9819360	0.9990180	0.9796510	3.1106E+01	8.6782E-01
$\alpha_2$	9.79E-04	2.71E-02	1.81E-02	8.43E-02	2.03E-02	8.6782E-01	3.1106E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9170590	0.9628860	0.9677550	0.9920360	0.9617100	5.9695E+01	2.3009E+00
$\alpha_2$	5.75E-03	3.20E-02	2.71E-02	7.50E-02	3.67E-02	1.9837E+00	6.0012E+01
$\alpha_3$	9.10E-07	5.12E-03	1.38E-03	2.30E-02	1.60E-03	3.1722E-01	6.1679E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9134340	0.9544600	0.9578280	0.9839630	0.9464110	8.4989E+01	4.0551E+00
$\alpha_2$	1.07E-02	3.63E-02	3.28E-02	7.35E-02	4.87E-02	3.2281E+00	8.5816E+01
$\alpha_3$	6.64E-05	6.79E-03	3.62E-03	2.43E-02	4.87E-03	6.0431E-01	8.8440E+01
$\alpha_4$	1.08E-08	2.50E-03	3.42E-04	1.25E-02	0.00E+00	2.2267E-01	8.8821E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9291090	0.9587290	0.9607480	0.9814440	0.9473520	1.4414E+02	6.2049E+00
$\alpha_2$	8.99E-03	2.63E-02	2.42E-02	5.06E-02	3.62E-02	3.9475E+00	1.4640E+02
$\alpha_3$	1.89E-03	1.20E-02	9.96E-03	2.93E-02	1.65E-02	1.8107E+00	1.4853E+02
$\alpha_4$	1.63E-06	2.49E-03	8.38E-04	1.06E-02	0.00E+00	3.7439E-01	1.4997E+02
$\alpha_5$	3.96E-21	4.81E-04	2.72E-07	2.78E-03	0.00E+00	7.2277E-02	1.5027E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9334370	0.9598780	0.9615560	0.9805730	0.9501590	1.7413E+02	7.2786E+00
$\alpha_2$	6.60E-03	2.03E-02	1.86E-02	3.99E-02	2.40E-02	3.6836E+00	1.7772E+02
$\alpha_3$	3.41E-03	1.43E-02	1.25E-02	3.11E-02	2.40E-02	2.5862E+00	1.7882E+02
$\alpha_4$	6.89E-05	3.88E-03	2.27E-03	1.31E-02	1.85E-03	7.0332E-01	1.8071E+02
$\alpha_5$	5.11E-09	1.22E-03	1.66E-04	6.14E-03	0.00E+00	2.2220E-01	1.8119E+02
$\alpha_6$	7.76E-19	4.59E-04	8.02E-07	2.68E-03	0.00E+00	8.3237E-02	1.8133E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9428590	0.9637030	0.9648890	0.9805090	0.9569720	2.5077E+02	9.4449E+00
$\alpha_2$	5.71E-03	1.61E-02	1.49E-02	3.06E-02	1.57E-02	4.1841E+00	2.5603E+02
$\alpha_3$	2.92E-03	1.11E-02	9.82E-03	2.34E-02	1.78E-02	2.8756E+00	2.5734E+02
$\alpha_4$	8.18E-04	6.19E-03	4.98E-03	1.57E-02	8.92E-03	1.6111E+00	2.5860E+02
$\alpha_5$	1.47E-05	2.15E-03	1.07E-03	7.92E-03	5.31E-04	5.5877E-01	2.5966E+02
$\alpha_6$	2.58E-10	7.16E-04	6.11E-05	3.76E-03	0.00E+00	1.8628E-01	2.6003E+02
$\alpha_7$	0.00E+00	1.12E-04	9.77E-14	4.20E-04	0.00E+00	2.9071E-02	2.6019E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9471020	0.9657510	0.9667660	0.9809450	0.9621450	2.9498E+02	1.0461E+01
$\alpha_2$	4.85E-03	1.37E-02	1.26E-02	2.61E-02	1.06E-02	4.1822E+00	3.0126E+02
$\alpha_3$	2.38E-03	9.21E-03	8.16E-03	1.96E-02	1.36E-02	2.8135E+00	3.0263E+02
$\alpha_4$	1.12E-03	6.43E-03	5.39E-03	1.53E-02	1.03E-02	1.9628E+00	3.0348E+02
$\alpha_5$	1.50E-04	3.17E-03	2.17E-03	9.58E-03	3.27E-03	9.6713E-01	3.0447E+02
$\alpha_6$	8.92E-07	1.24E-03	4.23E-04	5.25E-03	1.55E-04	3.7926E-01	3.0506E+02
$\alpha_7$	5.33E-14	4.03E-04	7.24E-06	2.29E-03	0.00E+00	1.2297E-01	3.0532E+02
$\alpha_8$	9.98E-43	1.08E-04	1.54E-12	4.58E-04	0.00E+00	3.3124E-02	3.0541E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9796510	0.9617100	0.9464110	0.9473520	0.9501590	0.9569720	0.9621450
$\alpha_2$	2.03E-02	3.67E-02	4.87E-02	3.62E-02	2.40E-02	1.57E-02	1.06E-02
$\alpha_3$		1.60E-03	4.87E-03	1.65E-02	2.40E-02	1.78E-02	1.36E-02
$\alpha_4$			0.00E+00	0.00E+00	1.85E-03	8.92E-03	1.03E-02
$\alpha_5$				0.00E+00	0.00E+00	5.31E-04	3.27E-03
$\alpha_6$					0.00E+00	0.00E+00	1.55E-04
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.80E-01	9.62E-01	9.46E-01	9.47E-01	9.50E-01	9.57E-01	9.62E-01
<b>Beta</b>	2.03E-02	3.83E-02	5.36E-02	5.26E-02	4.98E-02	4.30E-02	3.79E-02
<b>Gamma</b>		4.17E-02	9.09E-02	3.12E-01	5.19E-01	6.35E-01	7.21E-01
<b>Delta</b>			0.00E+00	0.00E+00	7.14E-02	3.46E-01	5.03E-01
<b>Epsilon</b>				0.00E+00	0.00E+00	5.61E-02	2.49E-01
<b>Mu</b>					0.00E+00	0.00E+00	4.54E-02
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	19.06	28.59	38.12	47.65	57.19	66.72	76.25
<b>N<sub>1</sub></b>	1.8000	1.5500	0.7333	0.3333	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.4333	1.1500	2.0000	1.8333	1.4444	1.0963	0.8375
<b>N<sub>3</sub></b>		0.0500	0.2000	0.8333	1.4444	1.2444	1.0751
<b>N<sub>4</sub></b>			0.0000	0.0000	0.1111	0.6222	0.8163
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0370	0.2588
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0123
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

### 1.3.6 PWR High Pressure Safety Injection Motor-Operated Valves

#### 1.3.6.1 HIGH PRESSURE INJECTION MOTOR OPERATED VALVE FAIL TO OPEN

System :

Chemical and volume control

Component :

High pressure injection

Failure Mode :

Motor Operated Valve

Start Date :

Fail to open on demand

Data Version :

1997/01/01

2009/12/31

Total Number of Independent Failure Events: 28.60

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9555320	0.9889380	0.9955360	0.9999780	1.0000000	3.8846E+01	4.3452E-01
$\alpha_2$	1.99E-05	1.11E-02	4.47E-03	4.45E-02	0.00E+00	4.3452E-01	3.8846E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9466930	0.9814220	0.9865020	0.9987840	1.0000000	5.8155E+01	1.1009E+00
$\alpha_2$	4.44E-04	1.41E-02	9.10E-03	4.46E-02	0.00E+00	8.3366E-01	5.8422E+01
$\alpha_3$	1.58E-07	4.51E-03	9.07E-04	2.14E-02	0.00E+00	2.6722E-01	5.8989E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9417960	0.9757790	0.9797940	0.9960300	1.0000000	7.4736E+01	1.8551E+00
$\alpha_2$	1.32E-03	1.60E-02	1.21E-02	4.44E-02	0.00E+00	1.2281E+00	7.5363E+01
$\alpha_3$	5.93E-06	5.28E-03	1.95E-03	2.18E-02	0.00E+00	4.0431E-01	7.6187E+01
$\alpha_4$	1.25E-08	2.91E-03	3.97E-04	1.46E-02	0.00E+00	2.2267E-01	7.6368E+01

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9452960	0.9724220	0.9748440	0.9912700	1.0000000	1.2476E+02	3.5382E+00
$\alpha_2$	3.17E-03	1.65E-02	1.40E-02	3.81E-02	0.00E+00	2.1142E+00	1.2618E+02
$\alpha_3$	3.72E-04	7.62E-03	5.26E-03	2.29E-02	0.00E+00	9.7738E-01	1.2732E+02
$\alpha_4$	1.92E-06	2.92E-03	9.82E-04	1.24E-02	0.00E+00	3.7439E-01	1.2792E+02
$\alpha_5$	4.65E-21	5.63E-04	3.18E-07	3.26E-03	0.00E+00	7.2277E-02	1.2823E+02

##### CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9461380	0.9714410	0.9735170	0.9896570	1.0000000	1.4554E+02	4.2787E+00
$\alpha_2$	3.07E-03	1.49E-02	1.28E-02	3.40E-02	0.00E+00	2.2392E+00	1.4758E+02
$\alpha_3$	5.36E-04	7.62E-03	5.57E-03	2.17E-02	0.00E+00	1.1418E+00	1.4868E+02
$\alpha_4$	3.53E-05	3.95E-03	2.07E-03	1.43E-02	0.00E+00	5.9222E-01	1.4923E+02
$\alpha_5$	6.20E-09	1.48E-03	2.01E-04	7.43E-03	0.00E+00	2.2220E-01	1.4960E+02
$\alpha_6$	9.41E-19	5.56E-04	9.71E-07	3.24E-03	0.00E+00	8.3237E-02	1.4974E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9497300	0.9705840	0.9720020	0.9865860	1.0000000	2.1265E+02	6.4450E+00
$\alpha_2$	3.97E-03	1.41E-02	1.26E-02	2.92E-02	0.00E+00	3.0878E+00	2.1601E+02
$\alpha_3$	1.00E-03	7.45E-03	6.01E-03	1.88E-02	0.00E+00	1.6312E+00	2.1746E+02
$\alpha_4$	2.26E-04	4.51E-03	3.12E-03	1.35E-02	0.00E+00	9.8887E-01	2.1811E+02
$\alpha_5$	1.17E-05	2.38E-03	1.13E-03	9.00E-03	0.00E+00	5.2177E-01	2.1857E+02
$\alpha_6$	3.07E-10	8.50E-04	7.26E-05	4.46E-03	0.00E+00	1.8628E-01	2.1891E+02
$\alpha_7$	0.00E+00	1.33E-04	1.16E-13	4.99E-04	0.00E+00	2.9071E-02	2.1907E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9515350	0.9707170	0.9719390	0.9857240	1.0000000	2.4733E+02	7.4610E+00
$\alpha_2$	3.95E-03	1.31E-02	1.19E-02	2.66E-02	0.00E+00	3.3447E+00	2.5145E+02
$\alpha_3$	1.01E-03	6.82E-03	5.58E-03	1.69E-02	0.00E+00	1.7384E+00	2.5305E+02
$\alpha_4$	3.18E-04	4.50E-03	3.29E-03	1.28E-02	0.00E+00	1.1465E+00	2.5364E+02
$\alpha_5$	5.06E-05	2.78E-03	1.63E-03	9.41E-03	0.00E+00	7.0833E-01	2.5408E+02
$\alpha_6$	8.15E-07	1.44E-03	4.71E-04	6.16E-03	0.00E+00	3.6696E-01	2.5442E+02
$\alpha_7$	6.39E-14	4.83E-04	8.68E-06	2.75E-03	0.00E+00	1.2297E-01	2.5467E+02
$\alpha_8$	1.20E-42	1.30E-04	1.85E-12	5.49E-04	0.00E+00	3.3124E-02	2.5476E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	1.00E+00						
<b>Beta</b>	0.00E+00						
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	28.60	28.60	28.60	28.60	28.60	28.60	28.60
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

### 1.3.6.2 HIGH PRESSURE INJECTION MOTOR OPERATED VALVE FAIL TO CLOSE

System :

Chemical and volume control

Component :

High pressure injection

Failure Mode :

Motor Operated Valve

Start Date :

Fail to open on demand

Data Version :

1997/01/01

2009/12/31

Total Number of Independent Failure Events: 28.60

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9555320	0.9889380	0.9955360	0.9999780	1.0000000	3.8846E+01	4.3452E-01
$\alpha_2$	1.99E-05	1.11E-02	4.47E-03	4.45E-02	0.00E+00	4.3452E-01	3.8846E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9466930	0.9814220	0.9865020	0.9987840	1.0000000	5.8155E+01	1.1009E+00
$\alpha_2$	4.44E-04	1.41E-02	9.10E-03	4.46E-02	0.00E+00	8.3366E-01	5.8422E+01
$\alpha_3$	1.58E-07	4.51E-03	9.07E-04	2.14E-02	0.00E+00	2.6722E-01	5.8989E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9417960	0.9757790	0.9797940	0.9960300	1.0000000	7.4736E+01	1.8551E+00
$\alpha_2$	1.32E-03	1.60E-02	1.21E-02	4.44E-02	0.00E+00	1.2281E+00	7.5363E+01
$\alpha_3$	5.93E-06	5.28E-03	1.95E-03	2.18E-02	0.00E+00	4.0431E-01	7.6187E+01
$\alpha_4$	1.25E-08	2.91E-03	3.97E-04	1.46E-02	0.00E+00	2.2267E-01	7.6368E+01

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9452960	0.9724220	0.9748440	0.9912700	1.0000000	1.2476E+02	3.5382E+00
$\alpha_2$	3.17E-03	1.65E-02	1.40E-02	3.81E-02	0.00E+00	2.1142E+00	1.2618E+02
$\alpha_3$	3.72E-04	7.62E-03	5.26E-03	2.29E-02	0.00E+00	9.7738E-01	1.2732E+02
$\alpha_4$	1.92E-06	2.92E-03	9.82E-04	1.24E-02	0.00E+00	3.7439E-01	1.2792E+02
$\alpha_5$	4.65E-21	5.63E-04	3.18E-07	3.26E-03	0.00E+00	7.2277E-02	1.2823E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9461380	0.9714410	0.9735170	0.9896570	1.0000000	1.4554E+02	4.2787E+00
$\alpha_2$	3.07E-03	1.49E-02	1.28E-02	3.40E-02	0.00E+00	2.2392E+00	1.4758E+02
$\alpha_3$	5.36E-04	7.62E-03	5.57E-03	2.17E-02	0.00E+00	1.1418E+00	1.4868E+02
$\alpha_4$	3.53E-05	3.95E-03	2.07E-03	1.43E-02	0.00E+00	5.9222E-01	1.4923E+02
$\alpha_5$	6.20E-09	1.48E-03	2.01E-04	7.43E-03	0.00E+00	2.2220E-01	1.4960E+02
$\alpha_6$	9.41E-19	5.56E-04	9.71E-07	3.24E-03	0.00E+00	8.3237E-02	1.4974E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9497300	0.9705840	0.9720020	0.9865860	1.0000000	2.1265E+02	6.4450E+00
$\alpha_2$	3.97E-03	1.41E-02	1.26E-02	2.92E-02	0.00E+00	3.0878E+00	2.1601E+02
$\alpha_3$	1.00E-03	7.45E-03	6.01E-03	1.88E-02	0.00E+00	1.6312E+00	2.1746E+02
$\alpha_4$	2.26E-04	4.51E-03	3.12E-03	1.35E-02	0.00E+00	9.8887E-01	2.1811E+02
$\alpha_5$	1.17E-05	2.38E-03	1.13E-03	9.00E-03	0.00E+00	5.2177E-01	2.1857E+02
$\alpha_6$	3.07E-10	8.50E-04	7.26E-05	4.46E-03	0.00E+00	1.8628E-01	2.1891E+02
$\alpha_7$	0.00E+00	1.33E-04	1.16E-13	4.99E-04	0.00E+00	2.9071E-02	2.1907E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9515350	0.9707170	0.9719390	0.9857240	1.0000000	2.4733E+02	7.4610E+00
$\alpha_2$	3.95E-03	1.31E-02	1.19E-02	2.66E-02	0.00E+00	3.3447E+00	2.5145E+02
$\alpha_3$	1.01E-03	6.82E-03	5.58E-03	1.69E-02	0.00E+00	1.7384E+00	2.5305E+02
$\alpha_4$	3.18E-04	4.50E-03	3.29E-03	1.28E-02	0.00E+00	1.1465E+00	2.5364E+02
$\alpha_5$	5.06E-05	2.78E-03	1.63E-03	9.41E-03	0.00E+00	7.0833E-01	2.5408E+02
$\alpha_6$	8.15E-07	1.44E-03	4.71E-04	6.16E-03	0.00E+00	3.6696E-01	2.5442E+02
$\alpha_7$	6.39E-14	4.83E-04	8.68E-06	2.75E-03	0.00E+00	1.2297E-01	2.5467E+02
$\alpha_8$	1.20E-42	1.30E-04	1.85E-12	5.49E-04	0.00E+00	3.3124E-02	2.5476E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	28.60	28.60	28.60	28.60	28.60	28.60	28.60
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

**1.3.7 PWR Residual Heat Removal Motor-Operated Valves****1.3.7.1 PWR RHR MOV FAIL TO OPEN**

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Motor Operated Valve
Failure Mode :	Fail to open on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 50.70

Total Number of Common-Cause Failure Events: 1

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8982310	0.9743470	0.9892100	0.9999430	0.9987390	1.6819E+01	4.4282E-01
$\alpha_2$	5.30E-05	2.57E-02	1.08E-02	1.02E-01	1.26E-03	4.4282E-01	1.6819E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9212700	0.9722110	0.9795440	0.9980720	0.9974650	3.9390E+01	1.1259E+00
$\alpha_2$	7.36E-04	2.12E-02	1.40E-02	6.63E-02	2.54E-03	8.5866E-01	3.9657E+01
$\alpha_3$	2.32E-07	6.60E-03	1.33E-03	3.13E-02	0.00E+00	2.6722E-01	4.0249E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9259650	0.9688310	0.9738020	0.9946880	0.9961920	5.9216E+01	1.9051E+00
$\alpha_2$	1.87E-03	2.09E-02	1.60E-02	5.69E-02	3.81E-03	1.2781E+00	5.9843E+01
$\alpha_3$	7.45E-06	6.61E-03	2.45E-03	2.73E-02	0.00E+00	4.0431E-01	6.0717E+01
$\alpha_4$	1.57E-08	3.64E-03	4.99E-04	1.82E-02	0.00E+00	2.2267E-01	6.0898E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9385850	0.9688020	0.9714550	0.9899320	0.9949150	1.1246E+02	3.6215E+00
$\alpha_2$	3.81E-03	1.89E-02	1.62E-02	4.32E-02	5.08E-03	2.1975E+00	1.1388E+02
$\alpha_3$	4.11E-04	8.42E-03	5.82E-03	2.53E-02	0.00E+00	9.7738E-01	1.1510E+02
$\alpha_4$	2.12E-06	3.23E-03	1.09E-03	1.37E-02	0.00E+00	3.7439E-01	1.1571E+02
$\alpha_5$	5.14E-21	6.23E-04	3.52E-07	3.60E-03	0.00E+00	7.2277E-02	1.1601E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9415160	0.9687360	0.9709280	0.9884500	0.9936340	1.3645E+02	4.4037E+00
$\alpha_2$	3.66E-03	1.68E-02	1.46E-02	3.75E-02	6.37E-03	2.3642E+00	1.3849E+02
$\alpha_3$	5.70E-04	8.11E-03	5.93E-03	2.31E-02	0.00E+00	1.1418E+00	1.3971E+02
$\alpha_4$	3.76E-05	4.20E-03	2.20E-03	1.52E-02	0.00E+00	5.9222E-01	1.4026E+02
$\alpha_5$	6.59E-09	1.58E-03	2.14E-04	7.90E-03	0.00E+00	2.2220E-01	1.4063E+02
$\alpha_6$	1.00E-18	5.91E-04	1.03E-06	3.45E-03	0.00E+00	8.3237E-02	1.4077E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9473230	0.9689760	0.9704290	0.9856570	0.9923510	2.0676E+02	6.6200E+00
$\alpha_2$	4.51E-03	1.53E-02	1.38E-02	3.12E-02	7.65E-03	3.2628E+00	2.1012E+02
$\alpha_3$	1.03E-03	7.64E-03	6.17E-03	1.93E-02	0.00E+00	1.6312E+00	2.1175E+02
$\alpha_4$	2.32E-04	4.63E-03	3.21E-03	1.39E-02	0.00E+00	9.8887E-01	2.1239E+02
$\alpha_5$	1.20E-05	2.45E-03	1.16E-03	9.24E-03	0.00E+00	5.2177E-01	2.1286E+02
$\alpha_6$	3.15E-10	8.73E-04	7.45E-05	4.58E-03	0.00E+00	1.8628E-01	2.1319E+02
$\alpha_7$	0.00E+00	1.36E-04	1.19E-13	5.13E-04	0.00E+00	2.9071E-02	2.1335E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9498730	0.9695040	0.9707350	0.9849280	0.9910670	2.4461E+02	7.6943E+00
$\alpha_2$	4.50E-03	1.42E-02	1.29E-02	2.82E-02	8.93E-03	3.5780E+00	2.4873E+02
$\alpha_3$	1.02E-03	6.89E-03	5.64E-03	1.70E-02	0.00E+00	1.7384E+00	2.5057E+02
$\alpha_4$	3.22E-04	4.54E-03	3.32E-03	1.29E-02	0.00E+00	1.1465E+00	2.5116E+02
$\alpha_5$	5.11E-05	2.81E-03	1.65E-03	9.50E-03	0.00E+00	7.0833E-01	2.5160E+02
$\alpha_6$	8.23E-07	1.45E-03	4.76E-04	6.22E-03	0.00E+00	3.6696E-01	2.5194E+02
$\alpha_7$	6.45E-14	4.87E-04	8.76E-06	2.77E-03	0.00E+00	1.2297E-01	2.5218E+02
$\alpha_8$	1.21E-42	1.31E-04	1.87E-12	5.55E-04	0.00E+00	3.3124E-02	2.5227E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9987390	0.9974650	0.9961920	0.9949150	0.9936340	0.9923510	0.9910670
$\alpha_2$	1.26E-03	2.54E-03	3.81E-03	5.08E-03	6.37E-03	7.65E-03	8.93E-03
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.99E-01	9.97E-01	9.96E-01	9.95E-01	9.94E-01	9.92E-01	9.91E-01
<b>Beta</b>	1.26E-03	2.54E-03	3.81E-03	5.08E-03	6.37E-03	7.65E-03	8.93E-03
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	6.34	9.51	12.68	15.84	19.01	22.18	25.35
<b>N<sub>1</sub></b>	0.2333	0.3250	0.4000	0.4583	0.5000	0.5250	0.5333
<b>N<sub>2</sub></b>	0.0083	0.0250	0.0500	0.0833	0.1250	0.1750	0.2333
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0000
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

### 1.3.7.2 PWR RHR MOV FAIL TO CLOSE

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)					
Component :	Motor Operated Valve					
Failure Mode :	Fail to close (reseat) on demand					
Plant Type :	PWR					
Start Date :	1997/01/01					
Data Version :	2009/12/31					

Total Number of Independent Failure Events: 23.10

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9483310	0.9871370	0.9947900	0.9999740	1.0000000	3.3346E+01	4.3452E-01
$\alpha_2$	2.32E-05	1.29E-02	5.21E-03	5.17E-02	0.00E+00	4.3452E-01	3.3346E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9413020	0.9795210	0.9851030	0.9986530	1.0000000	5.2655E+01	1.1009E+00
$\alpha_2$	4.90E-04	1.55E-02	1.00E-02	4.92E-02	0.00E+00	8.3366E-01	5.2922E+01
$\alpha_3$	1.74E-07	4.97E-03	1.00E-03	2.36E-02	0.00E+00	2.6722E-01	5.3489E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9373480	0.9739060	0.9782160	0.9957170	1.0000000	6.9236E+01	1.8551E+00
$\alpha_2$	1.43E-03	1.73E-02	1.30E-02	4.78E-02	0.00E+00	1.2281E+00	6.9863E+01
$\alpha_3$	6.40E-06	5.69E-03	2.11E-03	2.35E-02	0.00E+00	4.0431E-01	7.0687E+01
$\alpha_4$	1.35E-08	3.13E-03	4.28E-04	1.57E-02	0.00E+00	2.2267E-01	7.0868E+01

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9428720	0.9711870	0.9737110	0.9908740	1.0000000	1.1926E+02	3.5382E+00
$\alpha_2$	3.31E-03	1.72E-02	1.47E-02	3.98E-02	0.00E+00	2.1142E+00	1.2068E+02
$\alpha_3$	3.88E-04	7.96E-03	5.50E-03	2.39E-02	0.00E+00	9.7738E-01	1.2182E+02
$\alpha_4$	2.00E-06	3.05E-03	1.03E-03	1.29E-02	0.00E+00	3.7439E-01	1.2242E+02
$\alpha_5$	4.86E-21	5.89E-04	3.33E-07	3.41E-03	0.00E+00	7.2277E-02	1.2273E+02

##### CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9441060	0.9703530	0.9725030	0.9892570	1.0000000	1.4004E+02	4.2787E+00
$\alpha_2$	3.19E-03	1.55E-02	1.33E-02	3.53E-02	0.00E+00	2.2392E+00	1.4208E+02
$\alpha_3$	5.57E-04	7.91E-03	5.78E-03	2.25E-02	0.00E+00	1.1418E+00	1.4318E+02
$\alpha_4$	3.67E-05	4.10E-03	2.15E-03	1.48E-02	0.00E+00	5.9222E-01	1.4373E+02
$\alpha_5$	6.43E-09	1.54E-03	2.09E-04	7.71E-03	0.00E+00	2.2220E-01	1.4410E+02
$\alpha_6$	9.77E-19	5.77E-04	1.01E-06	3.37E-03	0.00E+00	8.3237E-02	1.4424E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9484470	0.9698260	0.9712800	0.9862310	1.0000000	2.0715E+02	6.4450E+00
$\alpha_2$	4.07E-03	1.45E-02	1.30E-02	2.99E-02	0.00E+00	3.0878E+00	2.1051E+02
$\alpha_3$	1.03E-03	7.64E-03	6.16E-03	1.93E-02	0.00E+00	1.6312E+00	2.1196E+02
$\alpha_4$	2.32E-04	4.63E-03	3.20E-03	1.39E-02	0.00E+00	9.8887E-01	2.1261E+02
$\alpha_5$	1.20E-05	2.44E-03	1.16E-03	9.23E-03	0.00E+00	5.2177E-01	2.1307E+02
$\alpha_6$	3.15E-10	8.72E-04	7.44E-05	4.58E-03	0.00E+00	1.8628E-01	2.1341E+02
$\alpha_7$	0.00E+00	1.36E-04	1.19E-13	5.12E-04	0.00E+00	2.9071E-02	2.1357E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9504710	0.9700710	0.9713180	0.9854010	1.0000000	2.4183E+02	7.4610E+00
$\alpha_2$	4.03E-03	1.34E-02	1.21E-02	2.72E-02	0.00E+00	3.3447E+00	2.4595E+02
$\alpha_3$	1.03E-03	6.97E-03	5.71E-03	1.72E-02	0.00E+00	1.7384E+00	2.4755E+02
$\alpha_4$	3.26E-04	4.60E-03	3.36E-03	1.31E-02	0.00E+00	1.1465E+00	2.4814E+02
$\alpha_5$	5.17E-05	2.84E-03	1.67E-03	9.62E-03	0.00E+00	7.0833E-01	2.4858E+02
$\alpha_6$	8.33E-07	1.47E-03	4.82E-04	6.30E-03	0.00E+00	3.6696E-01	2.4892E+02
$\alpha_7$	6.53E-14	4.93E-04	8.87E-06	2.81E-03	0.00E+00	1.2297E-01	2.4917E+02
$\alpha_8$	1.22E-42	1.33E-04	1.89E-12	5.62E-04	0.00E+00	3.3124E-02	2.4926E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	1.00E+00						
<b>Beta</b>	0.00E+00						
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

**BWR High Pressure Coolant Injection and Reactor Core Isolation Cooling Motor-Operated Valves**  
**COMBINED HPCI AND RCIC MOTOR OPERATED VALVE FAIL TO OPEN**

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	23.10	23.10	23.10	23.10	23.10	23.10	23.10
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

### 1.3.8 BWR High Pressure Coolant Injection and Reactor Core Isolation Cooling Motor-Operated Valves

#### 1.3.8.1 COMBINED HPCI AND RCIC MOTOR OPERATED VALVE FAIL TO OPEN

System : High pressure coolant injection

Reactor core isolation

Component : Motor Operated Valve

Failure Mode : Fail to open on demand

Start Date : 1997/01/01

Data Version : 2009/12/31

Total Number of Independent Failure Events: 32.10

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9187570	0.9796760	0.9916400	0.9999590	0.9998150	2.1042E+01	4.3652E-01
$\alpha_2$	3.82E-05	2.03E-02	8.36E-03	8.12E-02	1.85E-04	4.3652E-01	2.1042E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9325210	0.9763740	0.9827500	0.9984230	0.9996290	4.5743E+01	1.1069E+00
$\alpha_2$	5.80E-04	1.79E-02	1.17E-02	5.66E-02	3.64E-04	8.3956E-01	4.6010E+01
$\alpha_3$	2.01E-07	5.71E-03	1.15E-03	2.71E-02	6.18E-06	2.6732E-01	4.6583E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9357400	0.9731720	0.9775710	0.9955580	0.9994630	6.7713E+01	1.8667E+00
$\alpha_2$	1.50E-03	1.78E-02	1.34E-02	4.91E-02	5.28E-04	1.2395E+00	6.8340E+01
$\alpha_3$	6.56E-06	5.81E-03	2.16E-03	2.40E-02	9.26E-06	4.0451E-01	6.9175E+01
$\alpha_4$	1.38E-08	3.20E-03	4.38E-04	1.60E-02	0.00E+00	2.2267E-01	6.9357E+01

**BWR High Pressure Coolant Injection and Reactor Core Isolation Cooling Motor-Operated Valves**  
**COMBINED HPCI AND RCIC MOTOR OPERATED VALVE FAIL TO OPEN**

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9443900	0.9719190	0.9743700	0.9910730	0.9992960	1.2312E+02	3.5572E+00
$\alpha_2$	3.27E-03	1.68E-02	1.44E-02	3.89E-02	6.86E-04	2.1327E+00	1.2454E+02
$\alpha_3$	3.77E-04	7.72E-03	5.33E-03	2.32E-02	1.85E-05	9.7788E-01	1.2570E+02
$\alpha_4$	1.94E-06	2.96E-03	9.95E-04	1.26E-02	0.00E+00	3.7439E-01	1.2630E+02
$\alpha_5$	4.71E-21	5.71E-04	3.22E-07	3.30E-03	0.00E+00	7.2277E-02	1.2660E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9471940	0.9719590	0.9739870	0.9898030	0.9991350	1.4928E+02	4.3067E+00
$\alpha_2$	3.07E-03	1.48E-02	1.27E-02	3.35E-02	8.34E-04	2.2662E+00	1.5132E+02
$\alpha_3$	5.24E-04	7.44E-03	5.44E-03	2.12E-02	3.09E-05	1.1428E+00	1.5244E+02
$\alpha_4$	3.45E-05	3.86E-03	2.02E-03	1.39E-02	0.00E+00	5.9222E-01	1.5299E+02
$\alpha_5$	6.04E-09	1.45E-03	1.96E-04	7.25E-03	0.00E+00	2.2220E-01	1.5336E+02
$\alpha_6$	9.18E-19	5.42E-04	9.48E-07	3.16E-03	0.00E+00	8.3237E-02	1.5350E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9998150	0.9996290	0.9994630	0.9992960	0.9991350
$\alpha_2$	1.85E-04	3.64E-04	5.28E-04	6.86E-04	8.34E-04
$\alpha_3$		6.18E-06	9.26E-06	1.85E-05	3.09E-05
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>1-Beta</b>	1.00E+00	1.00E+00	9.99E-01	9.99E-01	9.99E-01
<b>Beta</b>	1.85E-04	3.71E-04	5.37E-04	7.04E-04	8.65E-04
<b>Gamma</b>		1.67E-02	1.72E-02	2.63E-02	3.57E-02
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>Adj. Ind. Events</b>	10.70	16.05	21.40	26.75	32.10
<b>N<sub>1</sub></b>	0.0960	0.1382	0.1766	0.2115	0.2430
<b>N<sub>2</sub></b>	0.0020	0.0059	0.0114	0.0185	0.0270
<b>N<sub>3</sub></b>		0.0001	0.0002	0.0005	0.0010
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000

### 1.3.8.2 COMBINED HPCI AND RCIC MOTOR OPERATED VALVE FAIL TO CLOSE

System : High pressure coolant injection  
 Component : Reactor core isolation  
 Failure Mode : Motor Operated Valve  
 Start Date : Fail to close (reseat) on demand  
 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 32.80

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9367930	0.9842450	0.9935970	0.9999690	1.0000000	2.7146E+01	4.3452E-01
$\alpha_2$	2.86E-05	1.58E-02	6.41E-03	6.32E-02	0.00E+00	4.3452E-01	2.7146E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9436320	0.9803440	0.9857090	0.9987070	1.0000000	5.4905E+01	1.1009E+00
$\alpha_2$	4.70E-04	1.49E-02	9.63E-03	4.72E-02	0.00E+00	8.3366E-01	5.5172E+01
$\alpha_3$	1.67E-07	4.77E-03	9.60E-04	2.26E-02	0.00E+00	2.6722E-01	5.5739E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9454570	0.9773190	0.9810890	0.9962910	1.0000000	7.9936E+01	1.8551E+00
$\alpha_2$	1.24E-03	1.50E-02	1.13E-02	4.16E-02	0.00E+00	1.2281E+00	8.0563E+01
$\alpha_3$	5.55E-06	4.94E-03	1.83E-03	2.04E-02	0.00E+00	4.0431E-01	8.1387E+01
$\alpha_4$	1.17E-08	2.72E-03	3.72E-04	1.36E-02	0.00E+00	2.2267E-01	8.1568E+01

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9500720	0.9748520	0.9770720	0.9920540	1.0000000	1.3716E+02	3.5382E+00
$\alpha_2$	2.89E-03	1.50E-02	1.28E-02	3.48E-02	0.00E+00	2.1142E+00	1.3858E+02
$\alpha_3$	3.39E-04	6.95E-03	4.79E-03	2.09E-02	0.00E+00	9.7738E-01	1.3972E+02
$\alpha_4$	1.75E-06	2.66E-03	8.95E-04	1.13E-02	0.00E+00	3.7439E-01	1.4032E+02
$\alpha_5$	4.24E-21	5.14E-04	2.90E-07	2.97E-03	0.00E+00	7.2277E-02	1.4063E+02

##### CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9525870	0.9748930	0.9767320	0.9909210	1.0000000	1.6614E+02	4.2787E+00
$\alpha_2$	2.69E-03	1.31E-02	1.13E-02	2.99E-02	0.00E+00	2.2392E+00	1.6818E+02
$\alpha_3$	4.71E-04	6.70E-03	4.90E-03	1.91E-02	0.00E+00	1.1418E+00	1.6928E+02
$\alpha_4$	3.10E-05	3.48E-03	1.82E-03	1.25E-02	0.00E+00	5.9222E-01	1.6983E+02
$\alpha_5$	5.45E-09	1.30E-03	1.77E-04	6.53E-03	0.00E+00	2.2220E-01	1.7020E+02
$\alpha_6$	8.27E-19	4.88E-04	8.54E-07	2.85E-03	0.00E+00	8.3237E-02	1.7034E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	16.40	24.60	32.80	41.00	49.20
$N_1$	0.5000	0.7500	1.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000	0.0000	0.0000
$N_4$			0.0000	0.0000	0.0000
$N_5$				0.0000	0.0000
$N_6$					0.0000

**1.3.9 Pressurizer PORV Motor-Operated Block Valves****1.3.9.1 PRESSURIZER PORV BLOCK MOVS FAIL TO OPEN**

System : Reactor coolant  
 Component : Motor Operated Valve  
 Failure Mode : Fail to open on demand  
 Plant Type : PWR  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 4.00

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8819910	0.9704020	0.9877120	0.9999410	1.0000000	1.4246E+01	4.3452E-01
$\alpha_2$	5.49E-05	2.96E-02	1.23E-02	1.18E-01	0.00E+00	4.3452E-01	1.4246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9094830	0.9682340	0.9767350	0.9978890	1.0000000	3.3555E+01	1.1009E+00
$\alpha_2$	7.68E-04	2.41E-02	1.57E-02	7.59E-02	0.00E+00	8.3366E-01	3.3822E+01
$\alpha_3$	2.71E-07	7.71E-03	1.56E-03	3.66E-02	0.00E+00	2.6722E-01	3.4389E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9147120	0.9643190	0.9701040	0.9941100	1.0000000	5.0136E+01	1.8551E+00
$\alpha_2$	1.96E-03	2.36E-02	1.78E-02	6.51E-02	0.00E+00	1.2281E+00	5.0763E+01
$\alpha_3$	8.78E-06	7.78E-03	2.89E-03	3.21E-02	0.00E+00	4.0431E-01	5.1587E+01
$\alpha_4$	1.85E-08	4.28E-03	5.88E-04	2.15E-02	0.00E+00	2.2267E-01	5.1768E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	4.00	4.00	4.00
$N_1$	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000
$N_4$			0.0000

**1.3.9.2 PRESSURIZER PORV BLOCK MOVS FAIL TO CLOSE**

System :

Reactor coolant

Component :

Motor Operated Valve

Failure Mode :

Fail to close (reseat) on demand

Plant Type :

PWR

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 4.00

Total Number of Common-Cause Failure Events: 0

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8819910	0.9704020	0.9877120	0.9999410	1.0000000	1.4246E+01	4.3452E-01
$\alpha_2$	5.49E-05	2.96E-02	1.23E-02	1.18E-01	0.00E+00	4.3452E-01	1.4246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9094830	0.9682340	0.9767350	0.9978890	1.0000000	3.3555E+01	1.1009E+00
$\alpha_2$	7.68E-04	2.41E-02	1.57E-02	7.59E-02	0.00E+00	8.3366E-01	3.3822E+01
$\alpha_3$	2.71E-07	7.71E-03	1.56E-03	3.66E-02	0.00E+00	2.6722E-01	3.4389E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9147120	0.9643190	0.9701040	0.9941100	1.0000000	5.0136E+01	1.8551E+00
$\alpha_2$	1.96E-03	2.36E-02	1.78E-02	6.51E-02	0.00E+00	1.2281E+00	5.0763E+01
$\alpha_3$	8.78E-06	7.78E-03	2.89E-03	3.21E-02	0.00E+00	4.0431E-01	5.1587E+01
$\alpha_4$	1.85E-08	4.28E-03	5.88E-04	2.15E-02	0.00E+00	2.2267E-01	5.1768E+01

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	4.00	4.00	4.00
$N_1$	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000
$N_4$			0.0000

## 1.4 Air Operated Valves

### 1.4.1 Pooled Air Operated Valves

#### 1.4.1.1 AOV FAIL TO OPEN ALL SYSTEMS SPAR: AOV-CC

Component : Air Operated Valve  
 Failure Mode : Fail to open on demand  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 62.30

Total Number of Common-Cause Failure Events: 4

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9293770	0.9772970	0.9849220	0.9991760	0.9842430	3.7461E+01	8.7022E-01
$\alpha_2$	8.21E-04	2.27E-02	1.51E-02	7.06E-02	1.58E-02	8.7022E-01	3.7461E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9311110	0.9698620	0.9741310	0.9940140	0.9741840	6.9446E+01	2.1580E+00
$\alpha_2$	3.78E-03	2.47E-02	2.04E-02	6.02E-02	2.28E-02	1.7658E+00	6.9838E+01
$\alpha_3$	5.02E-06	5.48E-03	1.96E-03	2.29E-02	3.05E-03	3.9222E-01	7.1212E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9297200	0.9641440	0.9671430	0.9883180	0.9666310	9.8331E+01	3.6569E+00
$\alpha_2$	6.73E-03	2.66E-02	2.36E-02	5.69E-02	2.76E-02	2.7174E+00	9.9270E+01
$\alpha_3$	8.70E-05	6.42E-03	3.60E-03	2.23E-02	4.63E-03	6.5431E-01	1.0133E+02
$\alpha_4$	1.87E-07	2.80E-03	6.30E-04	1.30E-02	1.16E-03	2.8517E-01	1.0170E+02

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9372330	0.9637320	0.9655770	0.9839340	0.9625690	1.6053E+02	6.0413E+00
$\alpha_2$	8.41E-03	2.42E-02	2.23E-02	4.64E-02	2.87E-02	4.0338E+00	1.6254E+02
$\alpha_3$	8.36E-04	8.24E-03	6.38E-03	2.20E-02	5.92E-03	1.3732E+00	1.6520E+02
$\alpha_4$	1.71E-05	3.19E-03	1.53E-03	1.20E-02	2.34E-03	5.3069E-01	1.6604E+02
$\alpha_5$	1.01E-15	6.22E-04	4.55E-06	3.61E-03	4.68E-04	1.0358E-01	1.6647E+02

**Pooled Air Operated Valves**

AOV FAIL TO OPEN ALL SYSTEMS SPAR: AOV-CC

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9380990	0.9624250	0.9639530	0.9815360	0.9589560	1.9326E+02	7.5454E+00
$\alpha_2$	8.88E-03	2.33E-02	2.17E-02	4.30E-02	3.05E-02	4.6690E+00	1.9614E+02
$\alpha_3$	1.08E-03	8.07E-03	6.51E-03	2.04E-02	6.02E-03	1.6210E+00	1.9918E+02
$\alpha_4$	1.34E-04	4.19E-03	2.70E-03	1.33E-02	3.12E-03	8.4052E-01	1.9996E+02
$\alpha_5$	2.69E-07	1.57E-03	4.18E-04	7.08E-03	1.18E-03	3.1600E-01	2.0049E+02
$\alpha_6$	2.08E-16	4.92E-04	2.73E-06	2.86E-03	1.96E-04	9.8837E-02	2.0071E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9442730	0.9641130	0.9652010	0.9802290	0.9598720	2.7259E+02	1.0146E+01
$\alpha_2$	8.21E-03	1.95E-02	1.84E-02	3.47E-02	2.64E-02	5.5252E+00	2.7721E+02
$\alpha_3$	1.80E-03	8.32E-03	7.20E-03	1.87E-02	7.83E-03	2.3535E+00	2.8038E+02
$\alpha_4$	4.22E-04	4.60E-03	3.50E-03	1.26E-02	3.39E-03	1.3017E+00	2.8143E+02
$\alpha_5$	3.98E-05	2.43E-03	1.41E-03	8.33E-03	1.80E-03	6.8817E-01	2.8205E+02
$\alpha_6$	9.49E-09	8.52E-04	1.38E-04	4.17E-03	5.93E-04	2.4098E-01	2.8250E+02
$\alpha_7$	1.06E-38	1.30E-04	1.40E-11	5.96E-04	8.46E-05	3.6871E-02	2.8270E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9468780	0.9649310	0.9658610	0.9797970	0.9604320	3.1941E+02	1.1609E+01
$\alpha_2$	7.68E-03	1.77E-02	1.68E-02	3.10E-02	2.40E-02	5.8657E+00	3.2515E+02
$\alpha_3$	1.89E-03	7.87E-03	6.90E-03	1.72E-02	8.27E-03	2.6051E+00	3.2841E+02
$\alpha_4$	5.66E-04	4.63E-03	3.68E-03	1.20E-02	3.70E-03	1.5342E+00	3.2948E+02
$\alpha_5$	1.22E-04	2.83E-03	1.91E-03	8.66E-03	2.17E-03	9.3553E-01	3.3008E+02
$\alpha_6$	4.39E-06	1.44E-03	6.29E-04	5.62E-03	1.05E-03	4.7676E-01	3.3054E+02
$\alpha_7$	7.05E-12	4.66E-04	2.15E-05	2.55E-03	2.99E-04	1.5427E-01	3.3086E+02
$\alpha_8$	1.27E-38	1.12E-04	1.30E-11	5.12E-04	3.72E-05	3.7024E-02	3.3098E+02

**ALPHA FACTOR and MGL PARAMETERS**

<b>Alpha Factor</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>	<b>CCCG=7</b>	<b>CCCG=8</b>
$\alpha_1$	0.9842430	0.9741840	0.9666310	0.9625690	0.9589560	0.9598720	0.9604320
$\alpha_2$	1.58E-02	2.28E-02	2.76E-02	2.87E-02	3.05E-02	2.64E-02	2.40E-02
$\alpha_3$		3.05E-03	4.63E-03	5.92E-03	6.02E-03	7.83E-03	8.27E-03
$\alpha_4$			1.16E-03	2.34E-03	3.12E-03	3.39E-03	3.70E-03
$\alpha_5$				4.68E-04	1.18E-03	1.80E-03	2.17E-03
$\alpha_6$					1.96E-04	5.93E-04	1.05E-03
$\alpha_7$						8.46E-05	2.99E-04
$\alpha_8$							3.72E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.84E-01	9.74E-01	9.67E-01	9.63E-01	9.59E-01	9.60E-01	9.60E-01
Beta	1.58E-02	2.58E-02	3.34E-02	3.74E-02	4.10E-02	4.01E-02	3.96E-02
Gamma		1.18E-01	1.73E-01	2.33E-01	2.56E-01	3.41E-01	3.92E-01
Delta			2.00E-01	3.22E-01	4.27E-01	4.29E-01	4.67E-01
Epsilon				1.67E-01	3.06E-01	4.23E-01	4.90E-01
Mu					1.43E-01	2.73E-01	3.90E-01
Upsilon						1.25E-01	2.43E-01
Sigma							1.11E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	24.92	37.38	49.84	62.30	74.76	87.22	99.68
N <sub>1</sub>	2.2952	2.5107	2.3548	2.0670	1.5640	1.3174	0.9958
N <sub>2</sub>	0.4357	0.9321	1.4893	1.9196	2.4298	2.4374	2.5210
N <sub>3</sub>		0.1250	0.2500	0.3958	0.4792	0.7223	0.8667
N <sub>4</sub>			0.0625	0.1563	0.2483	0.3128	0.3877
N <sub>5</sub>				0.0313	0.0938	0.1664	0.2272
N <sub>6</sub>					0.0156	0.0547	0.1098
N <sub>7</sub>						0.0078	0.0313
N <sub>8</sub>							0.0039

#### 1.4.1.2 AOV FAIL TO OPERATE ALL SYSTEMS SPAR: AOV-FO

Component :

Air Operated Valve

Failure Mode :

Fail to close (reseat) on demand

Fail to open on demand

Fail to Operate (Open/Close)

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 103.60

Total Number of Common-Cause Failure Events: 7

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9453270	0.9807140	0.9858220	0.9986420	0.9854400	5.7895E+01	1.1385E+00
$\alpha_2$	1.36E-03	1.93E-02	1.42E-02	5.47E-02	1.46E-02	1.1385E+00	5.7895E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9396580	0.9710240	0.9740450	0.9920680	0.9739940	9.9296E+01	2.9630E+00
$\alpha_2$	6.01E-03	2.51E-02	2.21E-02	5.46E-02	2.43E-02	2.5708E+00	9.9688E+01
$\alpha_3$	3.50E-06	3.84E-03	1.37E-03	1.60E-02	1.75E-03	3.9222E-01	1.0187E+02

**Pooled Air Operated Valves**

AOV FAIL TO OPERATE ALL SYSTEMS SPAR: AOV-FO

**CCCG = 4**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9338780	0.9629920	0.9651410	0.9847550	0.9638300	1.3705E+02	5.2669E+00
$\alpha_2$	1.11E-02	3.04E-02	2.82E-02	5.71E-02	3.29E-02	4.3274E+00	1.3799E+02
$\alpha_3$	6.22E-05	4.60E-03	2.58E-03	1.60E-02	2.65E-03	6.5431E-01	1.4166E+02
$\alpha_4$	1.34E-07	2.00E-03	4.50E-04	9.31E-03	6.63E-04	2.8517E-01	1.4203E+02

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9395180	0.9627810	0.9642010	0.9812080	0.9613040	2.0843E+02	8.0574E+00
$\alpha_2$	1.13E-02	2.64E-02	2.50E-02	4.64E-02	3.08E-02	5.7162E+00	2.1077E+02
$\alpha_3$	1.14E-03	7.88E-03	6.43E-03	1.96E-02	6.25E-03	1.7069E+00	2.1478E+02
$\alpha_4$	1.31E-05	2.45E-03	1.18E-03	9.21E-03	1.34E-03	5.3069E-01	2.1596E+02
$\alpha_5$	7.76E-16	4.78E-04	3.50E-06	2.77E-03	2.68E-04	1.0358E-01	2.1638E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9422830	0.9632400	0.9644250	0.9801680	0.9619640	2.5073E+02	9.5686E+00
$\alpha_2$	9.83E-03	2.26E-02	2.14E-02	3.95E-02	2.62E-02	5.8858E+00	2.5441E+02
$\alpha_3$	1.89E-03	8.90E-03	7.68E-03	2.01E-02	8.45E-03	2.3163E+00	2.5798E+02
$\alpha_4$	1.66E-04	3.66E-03	2.49E-03	1.11E-02	2.58E-03	9.5162E-01	2.5935E+02
$\alpha_5$	2.07E-07	1.21E-03	3.22E-04	5.46E-03	6.74E-04	3.1600E-01	2.5998E+02
$\alpha_6$	1.60E-16	3.80E-04	2.10E-06	2.21E-03	1.12E-04	9.8837E-02	2.6020E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9480130	0.9653830	0.9662600	0.9797570	0.9644580	3.3962E+02	1.2178E+01
$\alpha_2$	8.26E-03	1.82E-02	1.73E-02	3.13E-02	2.06E-02	6.4141E+00	3.4538E+02
$\alpha_3$	2.59E-03	9.02E-03	8.11E-03	1.86E-02	9.57E-03	3.1745E+00	3.4862E+02
$\alpha_4$	5.81E-04	4.51E-03	3.61E-03	1.15E-02	3.70E-03	1.5865E+00	3.5021E+02
$\alpha_5$	4.08E-05	2.06E-03	1.23E-03	6.92E-03	1.26E-03	7.2517E-01	3.5107E+02
$\alpha_6$	7.62E-09	6.85E-04	1.11E-04	3.35E-03	3.39E-04	2.4098E-01	3.5156E+02
$\alpha_7$	8.52E-39	1.05E-04	1.13E-11	4.79E-04	4.84E-05	3.6871E-02	3.5176E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9509310	0.9666810	0.9674360	0.9798430	0.9662690	3.9601E+02	1.3650E+01
$\alpha_2$	7.27E-03	1.59E-02	1.51E-02	2.72E-02	1.73E-02	6.5236E+00	4.0314E+02
$\alpha_3$	2.56E-03	8.36E-03	7.57E-03	1.68E-02	9.19E-03	3.4245E+00	4.0624E+02
$\alpha_4$	8.42E-04	4.81E-03	4.03E-03	1.14E-02	4.50E-03	1.9712E+00	4.0769E+02
$\alpha_5$	1.48E-04	2.56E-03	1.81E-03	7.54E-03	1.86E-03	1.0499E+00	4.0861E+02
$\alpha_6$	4.18E-06	1.19E-03	5.33E-04	4.62E-03	6.66E-04	4.8906E-01	4.0917E+02
$\alpha_7$	5.69E-12	3.77E-04	1.74E-05	2.06E-03	1.71E-04	1.5427E-01	4.0951E+02
$\alpha_8$	1.02E-38	9.04E-05	1.05E-11	4.14E-04	2.13E-05	3.7024E-02	4.0962E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9854400	0.9739940	0.9638300	0.9613040	0.9619640	0.9644580	0.9662690
$\alpha_2$	1.46E-02	2.43E-02	3.29E-02	3.08E-02	2.62E-02	2.06E-02	1.73E-02
$\alpha_3$		1.75E-03	2.65E-03	6.25E-03	8.45E-03	9.57E-03	9.19E-03
$\alpha_4$			6.63E-04	1.34E-03	2.58E-03	3.70E-03	4.50E-03
$\alpha_5$				2.68E-04	6.74E-04	1.26E-03	1.86E-03
$\alpha_6$					1.12E-04	3.39E-04	6.66E-04
$\alpha_7$						4.84E-05	1.71E-04
$\alpha_8$							2.13E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.85E-01	9.74E-01	9.64E-01	9.61E-01	9.62E-01	9.64E-01	9.66E-01
Beta	1.46E-02	2.60E-02	3.62E-02	3.87E-02	3.80E-02	3.55E-02	3.37E-02
Gamma		6.71E-02	9.16E-02	2.03E-01	3.11E-01	4.20E-01	4.86E-01
Delta			2.00E-01	2.05E-01	2.85E-01	3.59E-01	4.40E-01
Epsilon				1.67E-01	2.33E-01	3.08E-01	3.77E-01
Mu					1.43E-01	2.35E-01	3.15E-01
Upsilon						1.25E-01	2.24E-01
Sigma							1.11E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	43.99	65.99	87.98	109.98	131.97	153.97	175.97
N <sub>1</sub>	3.6586	3.7507	2.9348	2.2845	1.8163	1.6020	1.3101
N <sub>2</sub>	0.7040	1.7371	3.0993	3.6020	3.6466	3.3263	3.1789
N <sub>3</sub>		0.1250	0.2500	0.7295	1.1745	1.5433	1.6861
N <sub>4</sub>			0.0625	0.1563	0.3594	0.5976	0.8247
N <sub>5</sub>				0.0313	0.0938	0.2034	0.3416
N <sub>6</sub>					0.0156	0.0547	0.1221
N <sub>7</sub>						0.0078	0.0313
N <sub>8</sub>							0.0039

**1.4.1.3 AOV FAIL TO CLOSE ALL SYSTEMS SPAR: AOV-OO**

Component :

Air Operated Valve

Failure Mode :

Fail to close (reseat) on demand

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 35.80

Total Number of Common-Cause Failure Events: 3

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9182340	0.9756400	0.9854650	0.9995550	0.9852350	2.8149E+01	7.0282E-01
$\alpha_2$	4.42E-04	2.44E-02	1.45E-02	8.18E-02	1.48E-02	7.0282E-01	2.8149E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9213520	0.9668540	0.9721130	0.9943400	0.9700130	5.5595E+01	1.9059E+00
$\alpha_2$	3.93E-03	2.85E-02	2.32E-02	7.11E-02	3.00E-02	1.6387E+00	5.5862E+01
$\alpha_3$	1.62E-07	4.65E-03	9.35E-04	2.20E-02	0.00E+00	2.6722E-01	5.7234E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9174070	0.9583780	0.9620050	0.9869430	0.9543390	7.9786E+01	3.4651E+00
$\alpha_2$	9.01E-03	3.41E-02	3.04E-02	7.17E-02	4.57E-02	2.8381E+00	8.0413E+01
$\alpha_3$	5.45E-06	4.86E-03	1.80E-03	2.01E-02	0.00E+00	4.0431E-01	8.2847E+01
$\alpha_4$	1.15E-08	2.67E-03	3.65E-04	1.34E-02	0.00E+00	2.2267E-01	8.3028E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9316390	0.9612330	0.9633660	0.9835490	0.9537330	1.3772E+02	5.5543E+00
$\alpha_2$	8.83E-03	2.65E-02	2.43E-02	5.16E-02	3.86E-02	3.7965E+00	1.3948E+02
$\alpha_3$	8.53E-04	9.15E-03	6.99E-03	2.48E-02	7.66E-03	1.3111E+00	1.4196E+02
$\alpha_4$	1.72E-06	2.61E-03	8.79E-04	1.11E-02	0.00E+00	3.7439E-01	1.4290E+02
$\alpha_5$	4.16E-21	5.04E-04	2.85E-07	2.92E-03	0.00E+00	7.2277E-02	1.4320E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9375990	0.9635940	0.9653710	0.9835360	0.9610060	1.6680E+02	6.3019E+00
$\alpha_2$	6.18E-03	2.00E-02	1.81E-02	4.00E-02	2.35E-02	3.4560E+00	1.6965E+02
$\alpha_3$	1.70E-03	1.06E-02	8.80E-03	2.57E-02	1.34E-02	1.8371E+00	1.7126E+02
$\alpha_4$	7.22E-05	4.06E-03	2.38E-03	1.38E-02	2.14E-03	7.0332E-01	1.7240E+02
$\alpha_5$	5.36E-09	1.28E-03	1.74E-04	6.43E-03	0.00E+00	2.2220E-01	1.7288E+02
$\alpha_6$	8.14E-19	4.81E-04	8.40E-07	2.80E-03	0.00E+00	8.3237E-02	1.7302E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9455660	0.9661860	0.9674170	0.9825930	0.9662490	2.4221E+02	8.4767E+00
$\alpha_2$	5.44E-03	1.59E-02	1.46E-02	3.06E-02	1.48E-02	3.9767E+00	2.4671E+02
$\alpha_3$	2.21E-03	9.78E-03	8.51E-03	2.17E-02	1.36E-02	2.4522E+00	2.4823E+02
$\alpha_4$	4.46E-04	5.08E-03	3.84E-03	1.40E-02	4.73E-03	1.2737E+00	2.4941E+02
$\alpha_5$	1.53E-05	2.23E-03	1.11E-03	8.22E-03	6.15E-04	5.5877E-01	2.5013E+02
$\alpha_6$	2.68E-10	7.43E-04	6.34E-05	3.90E-03	0.00E+00	1.8628E-01	2.5050E+02
$\alpha_7$	0.00E+00	1.16E-04	1.01E-13	4.36E-04	0.00E+00	2.9071E-02	2.5066E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9492430	0.9677550	0.9688110	0.9826660	0.9702010	2.8518E+02	9.5021E+00
$\alpha_2$	4.67E-03	1.36E-02	1.25E-02	2.62E-02	9.61E-03	4.0026E+00	2.9068E+02
$\alpha_3$	2.05E-03	8.68E-03	7.60E-03	1.90E-02	1.20E-02	2.5579E+00	2.9212E+02
$\alpha_4$	6.90E-04	5.37E-03	4.30E-03	1.37E-02	6.38E-03	1.5835E+00	2.9310E+02
$\alpha_5$	8.36E-05	2.79E-03	1.78E-03	8.95E-03	1.67E-03	8.2273E-01	2.9386E+02
$\alpha_6$	9.25E-07	1.29E-03	4.39E-04	5.44E-03	1.80E-04	3.7926E-01	2.9430E+02
$\alpha_7$	5.52E-14	4.17E-04	7.50E-06	2.38E-03	0.00E+00	1.2297E-01	2.9456E+02
$\alpha_8$	1.03E-42	1.12E-04	1.60E-12	4.75E-04	0.00E+00	3.3124E-02	2.9465E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9852350	0.9700130	0.9543390	0.9537330	0.9610060	0.9662490	0.9702010
$\alpha_2$	1.48E-02	3.00E-02	4.57E-02	3.86E-02	2.35E-02	1.48E-02	9.61E-03
$\alpha_3$		0.00E+00	0.00E+00	7.66E-03	1.34E-02	1.36E-02	1.20E-02
$\alpha_4$			0.00E+00	0.00E+00	2.14E-03	4.73E-03	6.38E-03
$\alpha_5$				0.00E+00	0.00E+00	6.15E-04	1.67E-03
$\alpha_6$					0.00E+00	0.00E+00	1.80E-04
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.85E-01	9.70E-01	9.54E-01	9.54E-01	9.61E-01	9.66E-01	9.70E-01
<b>Beta</b>	1.48E-02	3.00E-02	4.57E-02	4.63E-02	3.90E-02	3.38E-02	2.98E-02
<b>Gamma</b>		0.00E+00	0.00E+00	1.66E-01	3.99E-01	5.62E-01	6.78E-01
<b>Delta</b>			0.00E+00	0.00E+00	1.38E-01	2.82E-01	4.08E-01
<b>Epsilon</b>				0.00E+00	0.00E+00	1.15E-01	2.25E-01
<b>Mu</b>					0.00E+00	0.00E+00	9.71E-02
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	16.54	24.80	33.07	41.34	49.61	57.88	66.14
<b>N<sub>1</sub></b>	1.3633	1.2400	0.5800	0.2175	0.2523	0.2845	0.3143
<b>N<sub>2</sub></b>	0.2683	0.8050	1.6100	1.6823	1.2168	0.8889	0.6579
<b>N<sub>3</sub></b>		0.0000	0.0000	0.3337	0.6953	0.8210	0.8195
<b>N<sub>4</sub></b>			0.0000	0.0000	0.1111	0.2848	0.4370
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0370	0.1144
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0123
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

## 1.4.2 BWR Isolation Condenser Air-Operated Valves

### 1.4.2.1 ISO CONDENSER AOV FAIL TO OPEN

**System :** Isolation condenser  
**Component :** Air Operated Valve  
**Failure Mode :** Fail to open on demand  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 1.00

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8522320	0.9628000	0.9843830	0.9999320	1.0000000	1.1246E+01	4.3452E-01
$\alpha_2$	7.00E-05	3.72E-02	1.56E-02	1.48E-01	0.00E+00	4.3452E-01	1.1246E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9010680	0.9652240	0.9744830	0.9976820	1.0000000	3.0555E+01	1.1009E+00
$\alpha_2$	8.43E-04	2.63E-02	1.72E-02	8.30E-02	0.00E+00	8.3366E-01	3.0822E+01
$\alpha_3$	2.98E-07	8.44E-03	1.71E-03	4.00E-02	0.00E+00	2.6722E-01	3.1389E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9095820	0.9621340	0.9682530	0.9937390	1.0000000	4.7136E+01	1.8551E+00
$\alpha_2$	2.09E-03	2.51E-02	1.89E-02	6.90E-02	0.00E+00	1.2281E+00	4.7763E+01
$\alpha_3$	9.32E-06	8.25E-03	3.07E-03	3.41E-02	0.00E+00	4.0431E-01	4.8587E+01
$\alpha_4$	1.97E-08	4.55E-03	6.24E-04	2.28E-02	0.00E+00	2.2267E-01	4.8768E+01

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9304990	0.9648630	0.9678980	0.9888360	1.0000000	9.7161E+01	3.5382E+00
$\alpha_2$	4.05E-03	2.10E-02	1.79E-02	4.85E-02	0.00E+00	2.1142E+00	9.8585E+01
$\alpha_3$	4.74E-04	9.71E-03	6.71E-03	2.92E-02	0.00E+00	9.7738E-01	9.9722E+01
$\alpha_4$	2.45E-06	3.72E-03	1.25E-03	1.58E-02	0.00E+00	3.7439E-01	1.0032E+02
$\alpha_5$	5.93E-21	7.18E-04	4.06E-07	4.16E-03	0.00E+00	7.2277E-02	1.0063E+02

##### CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9341160	0.9649920	0.9674990	0.9872840	1.0000000	1.1794E+02	4.2787E+00
$\alpha_2$	3.77E-03	1.83E-02	1.58E-02	4.16E-02	0.00E+00	2.2392E+00	1.1998E+02
$\alpha_3$	6.58E-04	9.34E-03	6.84E-03	2.66E-02	0.00E+00	1.1418E+00	1.2108E+02
$\alpha_4$	4.33E-05	4.85E-03	2.54E-03	1.75E-02	0.00E+00	5.9222E-01	1.2163E+02
$\alpha_5$	7.60E-09	1.82E-03	2.47E-04	9.11E-03	0.00E+00	2.2220E-01	1.2200E+02
$\alpha_6$	1.15E-18	6.81E-04	1.19E-06	3.98E-03	0.00E+00	8.3237E-02	1.2214E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	1.00	1.00	1.00	1.00	1.00
$N_1$	0.0000	0.0000	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000	0.0000	0.0000
$N_4$			0.0000	0.0000	0.0000
$N_5$				0.0000	0.0000
$N_6$					0.0000

**1.4.2.2 ISO CONDENSER AOV FAIL TO CLOSE**

System :

Isolation condenser

Component :

Air Operated Valve

Failure Mode :

Fail to close (reseat) on demand

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8386830	0.9593170	0.9828300	0.9999250	1.0000000	1.0246E+01	4.3452E-01
$\alpha_2$	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8979020	0.9640890	0.9736330	0.9976040	1.0000000	2.9555E+01	1.1009E+00
$\alpha_2$	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
$\alpha_3$	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9077330	0.9613450	0.9675780	0.9936050	1.0000000	4.6136E+01	1.8551E+00
$\alpha_2$	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
$\alpha_3$	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
$\alpha_4$	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9298110	0.9645110	0.9675740	0.9887220	1.0000000	9.6161E+01	3.5382E+00
$\alpha_2$	4.09E-03	2.12E-02	1.81E-02	4.90E-02	0.00E+00	2.1142E+00	9.7585E+01
$\alpha_3$	4.79E-04	9.80E-03	6.78E-03	2.95E-02	0.00E+00	9.7738E-01	9.8722E+01
$\alpha_4$	2.47E-06	3.76E-03	1.27E-03	1.59E-02	0.00E+00	3.7439E-01	9.9325E+01
$\alpha_5$	5.99E-21	7.25E-04	4.10E-07	4.20E-03	0.00E+00	7.2277E-02	9.9627E+01

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9335790	0.9647030	0.9672350	0.9871780	1.0000000	1.1694E+02	4.2787E+00
$\alpha_2$	3.80E-03	1.85E-02	1.59E-02	4.20E-02	0.00E+00	2.2392E+00	1.1898E+02
$\alpha_3$	6.64E-04	9.42E-03	6.89E-03	2.68E-02	0.00E+00	1.1418E+00	1.2008E+02
$\alpha_4$	4.37E-05	4.89E-03	2.56E-03	1.76E-02	0.00E+00	5.9222E-01	1.2063E+02
$\alpha_5$	7.67E-09	1.83E-03	2.49E-04	9.18E-03	0.00E+00	2.2220E-01	1.2100E+02
$\alpha_6$	1.16E-18	6.87E-04	1.20E-06	4.01E-03	0.00E+00	8.3237E-02	1.2114E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

## PWR Auxiliary Feedwater Air-Operated Valves

AFW AOV FAIL TO OPEN SPAR: AFW-AOV-CC

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	0.00	0.00	0.00	0.00	0.00
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000
N <sub>6</sub>					0.0000

**1.4.3 PWR Auxiliary Feedwater Air-Operated Valves****1.4.3.1 AFW AOV FAIL TO OPEN SPAR: AFW-AOV-CC**

System : Auxiliary feedwater  
 Component : Air Operated Valve  
 Failure Mode : Fail to open on demand  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 28.10

Total Number of Common-Cause Failure Events: 3

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8905070	0.9658380	0.9781610	0.9990790	0.9714760	2.2248E+01	7.8692E-01
$\alpha_2$	9.22E-04	3.42E-02	2.18E-02	1.09E-01	2.85E-02	7.8692E-01	2.2248E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9075050	0.9608960	0.9670320	0.9932840	0.9555020	4.6886E+01	1.9080E+00
$\alpha_2$	3.80E-03	3.11E-02	2.49E-02	7.94E-02	3.76E-02	1.5158E+00	4.7278E+01
$\alpha_3$	7.40E-06	8.04E-03	2.89E-03	3.35E-02	6.89E-03	3.9222E-01	4.8402E+01

**CCCG = 4**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9105050	0.9559940	0.9601770	0.9871720	0.9451800	6.8581E+01	3.1569E+00
$\alpha_2$	6.34E-03	3.09E-02	2.67E-02	7.00E-02	4.17E-02	2.2174E+00	6.9520E+01
$\alpha_3$	1.24E-04	9.12E-03	5.14E-03	3.17E-02	1.05E-02	6.5431E-01	7.1084E+01
$\alpha_4$	2.66E-07	3.98E-03	8.97E-04	1.85E-02	2.63E-03	2.8517E-01	7.1453E+01

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9259840	0.9583120	0.9606660	0.9826000	0.9371560	1.2355E+02	5.3747E+00
$\alpha_2$	8.30E-03	2.68E-02	2.44E-02	5.35E-02	4.57E-02	3.4505E+00	1.2547E+02
$\alpha_3$	9.04E-04	1.00E-02	7.61E-03	2.73E-02	1.07E-02	1.2899E+00	1.2763E+02
$\alpha_4$	2.21E-05	4.12E-03	1.98E-03	1.55E-02	5.35E-03	5.3069E-01	1.2839E+02
$\alpha_5$	1.30E-15	8.03E-04	5.89E-06	4.66E-03	1.07E-03	1.0358E-01	1.2882E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9273780	0.9569620	0.9589080	0.9799010	0.9298300	1.4909E+02	6.7051E+00
$\alpha_2$	8.91E-03	2.57E-02	2.37E-02	4.94E-02	5.12E-02	4.0093E+00	1.5179E+02
$\alpha_3$	1.05E-03	9.33E-03	7.33E-03	2.45E-02	9.04E-03	1.4543E+00	1.5434E+02
$\alpha_4$	1.62E-04	5.31E-03	3.39E-03	1.70E-02	6.78E-03	8.2662E-01	1.5497E+02
$\alpha_5$	3.47E-07	2.03E-03	5.39E-04	9.12E-03	2.71E-03	3.1600E-01	1.5548E+02
$\alpha_6$	2.68E-16	6.34E-04	3.52E-06	3.69E-03	4.51E-04	9.8837E-02	1.5570E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9372280	0.9603590	0.9616880	0.9789610	0.9326310	2.2125E+02	9.1325E+00
$\alpha_2$	8.09E-03	2.08E-02	1.95E-02	3.83E-02	4.30E-02	4.8019E+00	2.2558E+02
$\alpha_3$	1.74E-03	9.14E-03	7.76E-03	2.12E-02	1.19E-02	2.1046E+00	2.2828E+02
$\alpha_4$	4.73E-04	5.48E-03	4.13E-03	1.51E-02	6.85E-03	1.2623E+00	2.2912E+02
$\alpha_5$	4.81E-05	2.98E-03	1.72E-03	1.02E-02	4.11E-03	6.8587E-01	2.2970E+02
$\alpha_6$	1.17E-08	1.05E-03	1.70E-04	5.12E-03	1.37E-03	2.4098E-01	2.3014E+02
$\alpha_7$	1.30E-38	1.60E-04	1.72E-11	7.31E-04	1.96E-04	3.6871E-02	2.3035E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9406840	0.9615800	0.9627060	0.9786220	0.9343680	2.6094E+02	1.0426E+01
$\alpha_2$	7.53E-03	1.88E-02	1.76E-02	3.40E-02	3.87E-02	5.0941E+00	2.6627E+02
$\alpha_3$	1.75E-03	8.39E-03	7.22E-03	1.90E-02	1.19E-02	2.2772E+00	2.6909E+02
$\alpha_4$	6.06E-04	5.38E-03	4.22E-03	1.41E-02	6.94E-03	1.4599E+00	2.6991E+02
$\alpha_5$	1.44E-04	3.42E-03	2.30E-03	1.05E-02	4.84E-03	9.2713E-01	2.7044E+02
$\alpha_6$	5.32E-06	1.76E-03	7.66E-04	6.86E-03	2.42E-03	4.7636E-01	2.7089E+02
$\alpha_7$	8.60E-12	5.68E-04	2.63E-05	3.11E-03	6.93E-04	1.5427E-01	2.7121E+02
$\alpha_8$	1.55E-38	1.36E-04	1.58E-11	6.25E-04	8.63E-05	3.7024E-02	2.7133E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9714760	0.9555020	0.9451800	0.9371560	0.9298300	0.9326310	0.9343680
$\alpha_2$	2.85E-02	3.76E-02	4.17E-02	4.57E-02	5.12E-02	4.30E-02	3.87E-02
$\alpha_3$		6.89E-03	1.05E-02	1.07E-02	9.04E-03	1.19E-02	1.19E-02
$\alpha_4$			2.63E-03	5.35E-03	6.78E-03	6.85E-03	6.94E-03
$\alpha_5$				1.07E-03	2.71E-03	4.11E-03	4.84E-03
$\alpha_6$					4.51E-04	1.37E-03	2.42E-03
$\alpha_7$						1.96E-04	6.93E-04
$\alpha_8$							8.63E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.71E-01	9.56E-01	9.45E-01	9.37E-01	9.30E-01	9.33E-01	9.34E-01
<b>Beta</b>	2.85E-02	4.45E-02	5.48E-02	6.28E-02	7.02E-02	6.74E-02	6.56E-02
<b>Gamma</b>		1.55E-01	2.40E-01	2.72E-01	2.70E-01	3.62E-01	4.10E-01
<b>Delta</b>			2.00E-01	3.75E-01	5.24E-01	5.14E-01	5.57E-01
<b>Epsilon</b>				1.67E-01	3.18E-01	4.53E-01	5.37E-01
<b>Mu</b>					1.43E-01	2.76E-01	3.98E-01
<b>Upsilon</b>						1.25E-01	2.43E-01
<b>Sigma</b>							1.11E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	10.54	15.82	21.09	26.36	31.63	36.90	42.18
<b>N<sub>1</sub></b>	1.4619	1.5107	1.3548	1.0253	0.5223	0.3047	0.0313
<b>N<sub>2</sub></b>	0.3524	0.6821	0.9893	1.3363	1.7701	1.7141	1.7494
<b>N<sub>3</sub></b>		0.1250	0.2500	0.3125	0.3125	0.4734	0.5388
<b>N<sub>4</sub></b>			0.0625	0.1563	0.2344	0.2734	0.3134
<b>N<sub>5</sub></b>				0.0313	0.0938	0.1641	0.2188
<b>N<sub>6</sub></b>					0.0156	0.0547	0.1094
<b>N<sub>7</sub></b>						0.0078	0.0313
<b>N<sub>8</sub></b>							0.0039

**1.4.3.2 AFW AOV FAIL TO CLOSE SPAR: AFW-AOV-OO**

System :

Auxiliary feedwater

Component :

Air Operated Valve

Failure Mode :

Fail to close (reseat) on demand

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 18.60

Total Number of Common-Cause Failure Events: 2

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8979280	0.9711730	0.9843030	0.9997150	0.9835510	2.0309E+01	6.0282E-01
$\alpha_2$	2.88E-04	2.88E-02	1.57E-02	1.02E-01	1.64E-02	6.0282E-01	2.0309E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9120900	0.9648990	0.9714420	0.9952830	0.9665450	4.4145E+01	1.6059E+00
$\alpha_2$	2.88E-03	2.93E-02	2.27E-02	7.81E-02	3.35E-02	1.3387E+00	4.4412E+01
$\alpha_3$	2.05E-07	5.84E-03	1.18E-03	2.77E-02	0.00E+00	2.6722E-01	4.5484E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9116070	0.9577300	0.9621660	0.9886820	0.9489640	6.4916E+01	2.8651E+00
$\alpha_2$	6.85E-03	3.30E-02	2.85E-02	7.45E-02	5.10E-02	2.2381E+00	6.5543E+01
$\alpha_3$	6.71E-06	5.96E-03	2.21E-03	2.46E-02	0.00E+00	4.0431E-01	6.7377E+01
$\alpha_4$	1.42E-08	3.29E-03	4.50E-04	1.65E-02	0.00E+00	2.2267E-01	6.7558E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9321000	0.9633270	0.9657920	0.9861290	0.9585030	1.1963E+02	4.5543E+00
$\alpha_2$	5.83E-03	2.25E-02	2.00E-02	4.78E-02	2.79E-02	2.7965E+00	1.2139E+02
$\alpha_3$	9.85E-04	1.06E-02	8.07E-03	2.86E-02	1.36E-02	1.3111E+00	1.2287E+02
$\alpha_4$	1.98E-06	3.01E-03	1.01E-03	1.28E-02	0.00E+00	3.7439E-01	1.2381E+02
$\alpha_5$	4.80E-21	5.82E-04	3.29E-07	3.37E-03	0.00E+00	7.2277E-02	1.2411E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9370770	0.9647460	0.9667920	0.9854350	0.9649290	1.4509E+02	5.3019E+00
$\alpha_2$	4.51E-03	1.80E-02	1.59E-02	3.86E-02	1.60E-02	2.7060E+00	1.4769E+02
$\alpha_3$	1.37E-03	1.06E-02	8.48E-03	2.68E-02	1.53E-02	1.5871E+00	1.4880E+02
$\alpha_4$	8.31E-05	4.68E-03	2.74E-03	1.59E-02	3.81E-03	7.0332E-01	1.4969E+02
$\alpha_5$	6.17E-09	1.48E-03	2.00E-04	7.40E-03	0.00E+00	2.2220E-01	1.5017E+02
$\alpha_6$	9.37E-19	5.53E-04	9.68E-07	3.23E-03	0.00E+00	8.3237E-02	1.5031E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9449300	0.9666750	0.9680550	0.9837160	0.9695360	2.1688E+02	7.4767E+00
$\alpha_2$	4.66E-03	1.52E-02	1.38E-02	3.06E-02	9.64E-03	3.4142E+00	2.2094E+02
$\alpha_3$	1.73E-03	9.26E-03	7.85E-03	2.16E-02	1.32E-02	2.0772E+00	2.2228E+02
$\alpha_4$	4.29E-04	5.40E-03	4.02E-03	1.51E-02	6.56E-03	1.2112E+00	2.2315E+02
$\alpha_5$	1.71E-05	2.49E-03	1.25E-03	9.18E-03	1.09E-03	5.5877E-01	2.2380E+02
$\alpha_6$	3.00E-10	8.30E-04	7.09E-05	4.36E-03	0.00E+00	1.8628E-01	2.2417E+02
$\alpha_7$	0.00E+00	1.30E-04	1.13E-13	4.88E-04	0.00E+00	2.9071E-02	2.2433E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9483110	0.9678850	0.9690600	0.9834570	0.9729950	2.5624E+02	8.5022E+00
$\alpha_2$	4.29E-03	1.35E-02	1.23E-02	2.69E-02	6.12E-03	3.5808E+00	2.6116E+02
$\alpha_3$	1.56E-03	8.07E-03	6.87E-03	1.87E-02	1.03E-02	2.1360E+00	2.6261E+02
$\alpha_4$	6.01E-04	5.45E-03	4.27E-03	1.43E-02	7.69E-03	1.4429E+00	2.6330E+02
$\alpha_5$	8.61E-05	3.05E-03	1.92E-03	9.84E-03	2.56E-03	8.0713E-01	2.6394E+02
$\alpha_6$	1.03E-06	1.43E-03	4.89E-04	6.06E-03	3.19E-04	3.7926E-01	2.6436E+02
$\alpha_7$	6.15E-14	4.64E-04	8.35E-06	2.64E-03	0.00E+00	1.2297E-01	2.6462E+02
$\alpha_8$	1.15E-42	1.25E-04	1.78E-12	5.29E-04	0.00E+00	3.3124E-02	2.6471E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9835510	0.9665450	0.9489640	0.9585030	0.9649290	0.9695360	0.9729950
$\alpha_2$	1.64E-02	3.35E-02	5.10E-02	2.79E-02	1.60E-02	9.64E-03	6.12E-03
$\alpha_3$		0.00E+00	0.00E+00	1.36E-02	1.53E-02	1.32E-02	1.03E-02
$\alpha_4$			0.00E+00	0.00E+00	3.81E-03	6.56E-03	7.69E-03
$\alpha_5$				0.00E+00	0.00E+00	1.09E-03	2.56E-03
$\alpha_6$					0.00E+00	0.00E+00	3.19E-04
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.84E-01	9.67E-01	9.49E-01	9.59E-01	9.65E-01	9.70E-01	9.73E-01
<b>Beta</b>	1.64E-02	3.35E-02	5.10E-02	4.15E-02	3.51E-02	3.05E-02	2.70E-02
<b>Gamma</b>		0.00E+00	0.00E+00	3.28E-01	5.44E-01	6.84E-01	7.73E-01
<b>Delta</b>			0.00E+00	0.00E+00	2.00E-01	3.68E-01	5.06E-01
<b>Epsilon</b>				0.00E+00	0.00E+00	1.43E-01	2.73E-01
<b>Mu</b>					0.00E+00	0.00E+00	1.11E-01
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	9.30	13.95	18.60	23.25	27.90	32.55	37.20
<b>N<sub>1</sub></b>	0.7633	0.6400	0.1800	0.2175	0.2523	0.2845	0.3143
<b>N<sub>2</sub></b>	0.1683	0.5050	1.0100	0.6823	0.4668	0.3264	0.2361
<b>N<sub>3</sub></b>		0.0000	0.0000	0.3337	0.4453	0.4460	0.3976
<b>N<sub>4</sub></b>			0.0000	0.0000	0.1111	0.2223	0.2964
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0370	0.0988
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0123
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

## 1.4.4 High Pressure Coolant Injection and Reactor Core Isolation Cooling Air Operated Valves

### 1.4.4.1 COMBINED HPCI AND RCIC AIR OPERATED VALVE FAIL TO OPEN

**System :** High pressure coolant injection

Reactor core isolation

**Component :**

Air Operated Valve

**Failure Mode :**

Fail to open on demand

**Start Date :**

1997/01/01

**Data Version :**

2009/12/31

Total Number of Independent Failure Events: 3.00

Total Number of Common-Cause Failure Events: 0

### ALPHA FACTOR DISTRIBUTIONS

#### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8734960	0.9682380	0.9867710	0.99999360	1.0000000	1.3246E+01	4.3452E-01
$\alpha_2$	5.92E-05	3.18E-02	1.32E-02	1.27E-01	0.00E+00	4.3452E-01	1.3246E+01

#### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9068390	0.9672900	0.9760300	0.9978250	1.0000000	3.2555E+01	1.1009E+00
$\alpha_2$	7.91E-04	2.48E-02	1.62E-02	7.82E-02	0.00E+00	8.3366E-01	3.2822E+01
$\alpha_3$	2.80E-07	7.94E-03	1.61E-03	3.77E-02	0.00E+00	2.6722E-01	3.3389E+01

#### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9130680	0.9636200	0.9695110	0.9939910	1.0000000	4.9136E+01	1.8551E+00
$\alpha_2$	2.00E-03	2.41E-02	1.82E-02	6.63E-02	0.00E+00	1.2281E+00	4.9763E+01
$\alpha_3$	8.95E-06	7.93E-03	2.95E-03	3.27E-02	0.00E+00	4.0431E-01	5.0587E+01
$\alpha_4$	1.89E-08	4.37E-03	5.99E-04	2.19E-02	0.00E+00	2.2267E-01	5.0768E+01

#### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9318350	0.9655480	0.9685320	0.9890570	1.0000000	9.9161E+01	3.5382E+00
$\alpha_2$	3.97E-03	2.06E-02	1.76E-02	4.76E-02	0.00E+00	2.1142E+00	1.0059E+02
$\alpha_3$	4.65E-04	9.52E-03	6.58E-03	2.86E-02	0.00E+00	9.7738E-01	1.0172E+02
$\alpha_4$	2.40E-06	3.65E-03	1.23E-03	1.55E-02	0.00E+00	3.7439E-01	1.0232E+02
$\alpha_5$	5.81E-21	7.04E-04	3.98E-07	4.08E-03	0.00E+00	7.2277E-02	1.0263E+02

**High Pressure Coolant Injection and Reactor Core Isolation Cooling Air Operated Valves**

COMBINED HPCI AND RCIC AIR OPERATED VALVE FAIL TO CLOSE

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9351640	0.9655550	0.9680290	0.9874920	1.0000000	1.1994E+02	4.2787E+00
$\alpha_2$	3.71E-03	1.80E-02	1.55E-02	4.10E-02	0.00E+00	2.2392E+00	1.2198E+02
$\alpha_3$	6.48E-04	9.19E-03	6.73E-03	2.62E-02	0.00E+00	1.1418E+00	1.2308E+02
$\alpha_4$	4.26E-05	4.77E-03	2.50E-03	1.72E-02	0.00E+00	5.9222E-01	1.2363E+02
$\alpha_5$	7.48E-09	1.79E-03	2.43E-04	8.96E-03	0.00E+00	2.2220E-01	1.2400E+02
$\alpha_6$	1.14E-18	6.70E-04	1.17E-06	3.91E-03	0.00E+00	8.3237E-02	1.2414E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	3.00	3.00	3.00	3.00	3.00
$N_1$	0.0000	0.0000	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000	0.0000	0.0000
$N_4$			0.0000	0.0000	0.0000
$N_5$				0.0000	0.0000
$N_6$					0.0000

**1.4.4.2 COMBINED HPCI AND RCIC AIR OPERATED VALVE FAIL TO CLOSE**

System :

High pressure coolant injection

Reactor core isolation

Component :

Air Operated Valve

Failure Mode :

Fail to close (reseat) on demand

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

**High Pressure Coolant Injection and Reactor Core Isolation Cooling Air Operated Valves**

COMBINED HPCI AND RCIC AIR OPERATED VALVE FAIL TO CLOSE

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8386830	0.9593170	0.9828300	0.9999250	1.0000000	1.0246E+01	4.3452E-01
$\alpha_2$	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8979020	0.9640890	0.9736330	0.9976040	1.0000000	2.9555E+01	1.1009E+00
$\alpha_2$	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
$\alpha_3$	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9077330	0.9613450	0.9675780	0.9936050	1.0000000	4.6136E+01	1.8551E+00
$\alpha_2$	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
$\alpha_3$	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
$\alpha_4$	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9298110	0.9645110	0.9675740	0.9887220	1.0000000	9.6161E+01	3.5382E+00
$\alpha_2$	4.09E-03	2.12E-02	1.81E-02	4.90E-02	0.00E+00	2.1142E+00	9.7585E+01
$\alpha_3$	4.79E-04	9.80E-03	6.78E-03	2.95E-02	0.00E+00	9.7738E-01	9.8722E+01
$\alpha_4$	2.47E-06	3.76E-03	1.27E-03	1.59E-02	0.00E+00	3.7439E-01	9.9325E+01
$\alpha_5$	5.99E-21	7.25E-04	4.10E-07	4.20E-03	0.00E+00	7.2277E-02	9.9627E+01

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9335790	0.9647030	0.9672350	0.9871780	1.0000000	1.1694E+02	4.2787E+00
$\alpha_2$	3.80E-03	1.85E-02	1.59E-02	4.20E-02	0.00E+00	2.2392E+00	1.1898E+02
$\alpha_3$	6.64E-04	9.42E-03	6.89E-03	2.68E-02	0.00E+00	1.1418E+00	1.2008E+02
$\alpha_4$	4.37E-05	4.89E-03	2.56E-03	1.76E-02	0.00E+00	5.9222E-01	1.2063E+02
$\alpha_5$	7.67E-09	1.83E-03	2.49E-04	9.18E-03	0.00E+00	2.2220E-01	1.2100E+02
$\alpha_6$	1.16E-18	6.87E-04	1.20E-06	4.01E-03	0.00E+00	8.3237E-02	1.2114E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

**High Pressure Coolant Injection and Reactor Core Isolation Cooling Air Operated Valves**

COMBINED HPCI AND RCIC AIR OPERATED VALVE FAIL TO CLOSE

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>1-Beta</b>	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Beta</b>	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>Adj. Ind. Events</b>	0.00	0.00	0.00	0.00	0.00
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000

## 1.5 Check Valves

### 1.5.1 Pooled Check Valves

#### 1.5.1.1 CHECK VALVE FAIL TO OPEN ALL SYSTEMS SPAR: CKV-CC

Component : Check Valve  
 Failure Mode : Fail to open on demand  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 7.00

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9017830	0.9754240	0.9898730	0.9999510	1.0000000	1.7246E+01	4.3452E-01
$\alpha_2$	4.52E-05	2.46E-02	1.01E-02	9.82E-02	0.00E+00	4.3452E-01	1.7246E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9165860	0.9707650	0.9786210	0.9980670	1.0000000	3.6555E+01	1.1009E+00
$\alpha_2$	7.05E-04	2.21E-02	1.44E-02	7.00E-02	0.00E+00	8.3366E-01	3.6822E+01
$\alpha_3$	2.49E-07	7.10E-03	1.44E-03	3.37E-02	0.00E+00	2.6722E-01	3.7389E+01

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9192920	0.9662660	0.9717540	0.9944390	1.0000000	5.3136E+01	1.8551E+00
$\alpha_2$	1.85E-03	2.23E-02	1.68E-02	6.16E-02	0.00E+00	1.2281E+00	5.3763E+01
$\alpha_3$	8.29E-06	7.35E-03	2.73E-03	3.04E-02	0.00E+00	4.0431E-01	5.4587E+01
$\alpha_4$	1.75E-08	4.05E-03	5.55E-04	2.03E-02	0.00E+00	2.2267E-01	5.4768E+01

##### **CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9343580	0.9668390	0.9697150	0.9894740	1.0000000	1.0316E+02	3.5382E+00
$\alpha_2$	3.82E-03	1.98E-02	1.69E-02	4.58E-02	0.00E+00	2.1142E+00	1.0458E+02
$\alpha_3$	4.48E-04	9.16E-03	6.33E-03	2.75E-02	0.00E+00	9.7738E-01	1.0572E+02
$\alpha_4$	2.31E-06	3.51E-03	1.18E-03	1.49E-02	0.00E+00	3.7439E-01	1.0632E+02
$\alpha_5$	5.59E-21	6.77E-04	3.83E-07	3.92E-03	0.00E+00	7.2277E-02	1.0663E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9371630	0.9666300	0.9690330	0.9878880	1.0000000	1.2394E+02	4.2787E+00
$\alpha_2$	3.59E-03	1.75E-02	1.50E-02	3.97E-02	0.00E+00	2.2392E+00	1.2598E+02
$\alpha_3$	6.27E-04	8.91E-03	6.51E-03	2.54E-02	0.00E+00	1.1418E+00	1.2708E+02
$\alpha_4$	4.13E-05	4.62E-03	2.42E-03	1.67E-02	0.00E+00	5.9222E-01	1.2763E+02
$\alpha_5$	7.25E-09	1.73E-03	2.35E-04	8.68E-03	0.00E+00	2.2220E-01	1.2800E+02
$\alpha_6$	1.10E-18	6.49E-04	1.14E-06	3.79E-03	0.00E+00	8.3237E-02	1.2814E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9442790	0.9673660	0.9689360	0.9851010	1.0000000	1.9105E+02	6.4450E+00
$\alpha_2$	4.41E-03	1.56E-02	1.40E-02	3.23E-02	0.00E+00	3.0878E+00	1.9441E+02
$\alpha_3$	1.11E-03	8.26E-03	6.67E-03	2.08E-02	0.00E+00	1.6312E+00	1.9586E+02
$\alpha_4$	2.51E-04	5.01E-03	3.47E-03	1.50E-02	0.00E+00	9.8887E-01	1.9651E+02
$\alpha_5$	1.30E-05	2.64E-03	1.25E-03	9.98E-03	0.00E+00	5.2177E-01	1.9697E+02
$\alpha_6$	3.40E-10	9.43E-04	8.05E-05	4.95E-03	0.00E+00	1.8628E-01	1.9731E+02
$\alpha_7$	0.00E+00	1.47E-04	1.29E-13	5.54E-04	0.00E+00	2.9071E-02	1.9747E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9470850	0.9680050	0.9693380	0.9843870	1.0000000	2.2573E+02	7.4610E+00
$\alpha_2$	4.32E-03	1.43E-02	1.30E-02	2.90E-02	0.00E+00	3.3447E+00	2.2985E+02
$\alpha_3$	1.10E-03	7.45E-03	6.10E-03	1.84E-02	0.00E+00	1.7384E+00	2.3145E+02
$\alpha_4$	3.48E-04	4.92E-03	3.59E-03	1.40E-02	0.00E+00	1.1465E+00	2.3204E+02
$\alpha_5$	5.53E-05	3.04E-03	1.79E-03	1.03E-02	0.00E+00	7.0833E-01	2.3248E+02
$\alpha_6$	8.91E-07	1.57E-03	5.15E-04	6.73E-03	0.00E+00	3.6696E-01	2.3282E+02
$\alpha_7$	6.98E-14	5.27E-04	9.48E-06	3.00E-03	0.00E+00	1.2297E-01	2.3307E+02
$\alpha_8$	1.31E-42	1.42E-04	2.02E-12	6.00E-04	0.00E+00	3.3124E-02	2.3316E+02

**ALPHA FACTOR and MGL PARAMETERS**

<b>Alpha Factor</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>	<b>CCCG=7</b>	<b>CCCG=8</b>
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

**Pooled Check Valves**

CHECK VALVE FAIL TO REMAIN CLOSED ALL SYSTEMS SPAR:CKV-CO

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	1.00E+00						
<b>Beta</b>	0.00E+00						
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	7.00	7.00	7.00	7.00	7.00	7.00	7.00
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0000
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

**1.5.1.2 CHECK VALVE FAIL TO REMAIN CLOSED ALL SYSTEMS SPAR:CKV-CO**

Component :

Check Valve

Failure Mode :

Spurious operation open or close

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8386830	0.9593170	0.9828300	0.9999250	1.0000000	1.0246E+01	4.3452E-01
$\alpha_2$	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8979020	0.9640890	0.9736330	0.9976040	1.0000000	2.9555E+01	1.1009E+00
$\alpha_2$	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
$\alpha_3$	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

## Pooled Check Valves

CHECK VALVE FAIL TO REMAIN CLOSED ALL SYSTEMS SPAR:CKV-CO

**CCCG = 4**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9077330	0.9613450	0.9675780	0.9936050	1.0000000	4.6136E+01	1.8551E+00
$\alpha_2$	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
$\alpha_3$	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
$\alpha_4$	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9298110	0.9645110	0.9675740	0.9887220	1.0000000	9.6161E+01	3.5382E+00
$\alpha_2$	4.09E-03	2.12E-02	1.81E-02	4.90E-02	0.00E+00	2.1142E+00	9.7585E+01
$\alpha_3$	4.79E-04	9.80E-03	6.78E-03	2.95E-02	0.00E+00	9.7738E-01	9.8722E+01
$\alpha_4$	2.47E-06	3.76E-03	1.27E-03	1.59E-02	0.00E+00	3.7439E-01	9.9325E+01
$\alpha_5$	5.99E-21	7.25E-04	4.10E-07	4.20E-03	0.00E+00	7.2277E-02	9.9627E+01

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9335790	0.9647030	0.9672350	0.9871780	1.0000000	1.1694E+02	4.2787E+00
$\alpha_2$	3.80E-03	1.85E-02	1.59E-02	4.20E-02	0.00E+00	2.2392E+00	1.1898E+02
$\alpha_3$	6.64E-04	9.42E-03	6.89E-03	2.68E-02	0.00E+00	1.1418E+00	1.2008E+02
$\alpha_4$	4.37E-05	4.89E-03	2.56E-03	1.76E-02	0.00E+00	5.9222E-01	1.2063E+02
$\alpha_5$	7.67E-09	1.83E-03	2.49E-04	9.18E-03	0.00E+00	2.2220E-01	1.2100E+02
$\alpha_6$	1.16E-18	6.87E-04	1.20E-06	4.01E-03	0.00E+00	8.3237E-02	1.2114E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9422570	0.9661670	0.9677850	0.9845420	1.0000000	1.8405E+02	6.4450E+00
$\alpha_2$	4.57E-03	1.62E-02	1.45E-02	3.35E-02	0.00E+00	3.0878E+00	1.8741E+02
$\alpha_3$	1.15E-03	8.56E-03	6.91E-03	2.16E-02	0.00E+00	1.6312E+00	1.8886E+02
$\alpha_4$	2.60E-04	5.19E-03	3.59E-03	1.56E-02	0.00E+00	9.8887E-01	1.8951E+02
$\alpha_5$	1.35E-05	2.74E-03	1.30E-03	1.04E-02	0.00E+00	5.2177E-01	1.8997E+02
$\alpha_6$	3.53E-10	9.78E-04	8.35E-05	5.13E-03	0.00E+00	1.8628E-01	1.9031E+02
$\alpha_7$	0.00E+00	1.53E-04	1.34E-13	5.75E-04	0.00E+00	2.9071E-02	1.9047E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9454620	0.9670150	0.9683850	0.9838980	1.0000000	2.1873E+02	7.4610E+00
$\alpha_2$	4.45E-03	1.48E-02	1.34E-02	2.99E-02	0.00E+00	3.3447E+00	2.2285E+02
$\alpha_3$	1.14E-03	7.69E-03	6.29E-03	1.90E-02	0.00E+00	1.7384E+00	2.2445E+02
$\alpha_4$	3.59E-04	5.07E-03	3.71E-03	1.44E-02	0.00E+00	1.1465E+00	2.2504E+02
$\alpha_5$	5.70E-05	3.13E-03	1.84E-03	1.06E-02	0.00E+00	7.0833E-01	2.2548E+02
$\alpha_6$	9.18E-07	1.62E-03	5.31E-04	6.94E-03	0.00E+00	3.6696E-01	2.2582E+02
$\alpha_7$	7.20E-14	5.44E-04	9.78E-06	3.10E-03	0.00E+00	1.2297E-01	2.2607E+02
$\alpha_8$	1.35E-42	1.46E-04	2.09E-12	6.19E-04	0.00E+00	3.3124E-02	2.2616E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	0.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	0.00	0.00	0.00	0.00	0.00	0.00	0.00
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

**1.5.1.3 CKV FAIL TO REMAIN CLOSED (LEAKAGE) ALL SYSTEMS SPAR:CKV-CO**

Component : Check Valve  
Failure Mode : Fail to remain closed(detectable leakage)  
Start Date : 1997/01/01  
Data Version : 2009/12/31

Total Number of Independent Failure Events: 41.50

Total Number of Common-Cause Failure Events: 6

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8258380	0.9152060	0.9233350	0.9767230	0.8948440	3.0953E+01	2.8678E+00
$\alpha_2$	2.33E-02	8.48E-02	7.67E-02	1.74E-01	1.05E-01	2.8678E+00	3.0953E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8746850	0.9325620	0.9370580	0.9750670	0.9033820	5.9475E+01	4.3009E+00
$\alpha_2$	1.30E-02	4.68E-02	4.21E-02	9.65E-02	6.49E-02	2.9837E+00	6.0792E+01
$\alpha_3$	1.96E-03	2.07E-02	1.59E-02	5.57E-02	3.17E-02	1.3172E+00	6.2459E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8856410	0.9332760	0.9364480	0.9700700	0.9017700	8.4693E+01	6.0551E+00
$\alpha_2$	1.36E-02	4.11E-02	3.77E-02	8.00E-02	5.85E-02	3.7281E+00	8.7020E+01
$\alpha_3$	2.34E-03	1.77E-02	1.43E-02	4.47E-02	2.81E-02	1.6043E+00	8.9144E+01
$\alpha_4$	1.57E-04	7.96E-03	4.76E-03	2.67E-02	1.17E-02	7.2267E-01	9.0025E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9073810	0.9415620	0.9434970	0.9691410	0.8976530	1.4294E+02	8.8716E+00
$\alpha_2$	1.40E-02	3.42E-02	3.22E-02	6.14E-02	5.92E-02	5.1975E+00	1.4661E+02
$\alpha_3$	2.99E-03	1.47E-02	1.26E-02	3.34E-02	2.40E-02	2.2274E+00	1.4958E+02
$\alpha_4$	5.04E-04	7.41E-03	5.39E-03	2.12E-02	1.44E-02	1.1244E+00	1.5069E+02
$\alpha_5$	4.30E-07	2.12E-03	5.81E-04	9.48E-03	4.80E-03	3.2228E-01	1.5149E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9132090	0.9436940	0.9453070	0.9686610	0.9021690	1.7227E+02	1.0279E+01
$\alpha_2$	1.13E-02	2.80E-02	2.63E-02	5.06E-02	4.69E-02	5.1142E+00	1.7743E+02
$\alpha_3$	4.21E-03	1.58E-02	1.41E-02	3.34E-02	2.85E-02	2.8918E+00	1.7966E+02
$\alpha_4$	7.15E-04	7.35E-03	5.65E-03	1.98E-02	1.22E-02	1.3422E+00	1.8121E+02
$\alpha_5$	7.73E-05	3.96E-03	2.35E-03	1.33E-02	8.15E-03	7.2220E-01	1.8183E+02
$\alpha_6$	2.04E-09	1.14E-03	1.32E-04	5.82E-03	2.04E-03	2.0824E-01	1.8234E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9288810	0.9523280	0.9534770	0.9718420	0.9149660	2.4861E+02	1.2445E+01
$\alpha_2$	8.37E-03	2.04E-02	1.91E-02	3.65E-02	3.15E-02	5.3128E+00	2.5574E+02
$\alpha_3$	3.80E-03	1.27E-02	1.15E-02	2.58E-02	2.39E-02	3.3187E+00	2.5774E+02
$\alpha_4$	1.49E-03	7.95E-03	6.74E-03	1.86E-02	1.54E-02	2.0764E+00	2.5898E+02
$\alpha_5$	3.11E-04	4.39E-03	3.21E-03	1.25E-02	8.86E-03	1.1468E+00	2.5991E+02
$\alpha_6$	7.44E-06	1.91E-03	8.69E-04	7.34E-03	4.43E-03	4.9878E-01	2.6056E+02
$\alpha_7$	1.44E-17	3.51E-04	1.20E-06	2.05E-03	8.86E-04	9.1571E-02	2.6096E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9352050	0.9560050	0.9569940	0.9734230	0.9247920	2.9251E+02	1.3461E+01
$\alpha_2$	6.64E-03	1.66E-02	1.56E-02	3.01E-02	2.17E-02	5.0778E+00	3.0089E+02
$\alpha_3$	3.29E-03	1.09E-02	9.90E-03	2.22E-02	2.02E-02	3.3478E+00	3.0262E+02
$\alpha_4$	1.61E-03	7.57E-03	6.53E-03	1.71E-02	1.47E-02	2.3159E+00	3.0366E+02
$\alpha_5$	5.86E-04	4.93E-03	3.90E-03	1.28E-02	1.00E-02	1.5089E+00	3.0446E+02
$\alpha_6$	8.58E-05	2.73E-03	1.75E-03	8.71E-03	5.88E-03	8.3576E-01	3.0514E+02
$\alpha_7$	1.48E-07	1.01E-03	2.62E-04	4.59E-03	2.35E-03	3.1047E-01	3.0566E+02
$\alpha_8$	1.24E-23	2.11E-04	4.11E-08	1.20E-03	3.92E-04	6.4424E-02	3.0591E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.8948440	0.9033820	0.9017700	0.8976530	0.9021690	0.9149660	0.9247920
$\alpha_2$	1.05E-01	6.49E-02	5.85E-02	5.92E-02	4.69E-02	3.15E-02	2.17E-02
$\alpha_3$		3.17E-02	2.81E-02	2.40E-02	2.85E-02	2.39E-02	2.02E-02
$\alpha_4$			1.17E-02	1.44E-02	1.22E-02	1.54E-02	1.47E-02
$\alpha_5$				4.80E-03	8.15E-03	8.86E-03	1.00E-02
$\alpha_6$					2.04E-03	4.43E-03	5.88E-03
$\alpha_7$						8.86E-04	2.35E-03
$\alpha_8$							3.92E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	8.95E-01	9.03E-01	9.02E-01	8.98E-01	9.02E-01	9.15E-01	9.25E-01
<b>Beta</b>	1.05E-01	9.66E-02	9.82E-02	1.02E-01	9.78E-02	8.50E-02	7.52E-02
<b>Gamma</b>		3.28E-01	4.05E-01	4.22E-01	5.21E-01	6.29E-01	7.11E-01
<b>Delta</b>			2.94E-01	4.44E-01	4.40E-01	5.53E-01	6.23E-01
<b>Epsilon</b>				2.50E-01	4.55E-01	4.79E-01	5.60E-01
<b>Mu</b>					2.00E-01	3.75E-01	4.62E-01
<b>Upsilon</b>						1.67E-01	3.18E-01
<b>Sigma</b>							1.43E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	18.44	27.67	36.89	46.11	55.33	64.56	73.78
<b>N<sub>1</sub></b>	2.2667	2.2500	1.6667	0.6667	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	2.4333	2.1500	2.5000	3.0833	2.8750	2.2250	1.7331
<b>N<sub>3</sub></b>		1.0500	1.2000	1.2500	1.7500	1.6875	1.6094
<b>N<sub>4</sub></b>			0.5000	0.7500	0.7500	1.0875	1.1694
<b>N<sub>5</sub></b>				0.2500	0.5000	0.6250	0.8006
<b>N<sub>6</sub></b>					0.1250	0.3125	0.4688
<b>N<sub>7</sub></b>						0.0625	0.1875
<b>N<sub>8</sub></b>							0.0313

### 1.5.1.4 CHECK VALVE FAIL TO CLOSE ALL SYSTEMS SPAR:CKV-OO

Component :

Check Valve

Failure Mode :

Fail to close (reseat) on demand

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 34.00

Total Number of Common-Cause Failure Events: 2

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8631670	0.9467440	0.9573700	0.9938780	0.9385750	2.5679E+01	1.4445E+00
$\alpha_2$	6.12E-03	5.33E-02	4.26E-02	1.37E-01	6.14E-02	1.4445E+00	2.5679E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.91111470	0.96111330	0.9666100	0.9923520	0.9573830	5.2680E+01	2.1303E+00
$\alpha_2$	2.52E-03	2.49E-02	1.93E-02	6.61E-02	2.19E-02	1.3628E+00	5.3448E+01
$\alpha_3$	3.41E-04	1.40E-02	8.69E-03	4.58E-02	2.07E-02	7.6752E-01	5.4043E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9238860	0.9635160	0.9673230	0.9901170	0.9667880	7.6925E+01	2.9128E+00
$\alpha_2$	2.38E-03	1.92E-02	1.54E-02	4.92E-02	9.63E-03	1.5347E+00	7.8303E+01
$\alpha_3$	4.53E-04	1.13E-02	7.60E-03	3.50E-02	1.57E-02	9.0541E-01	7.8932E+01
$\alpha_4$	1.73E-05	5.92E-03	2.58E-03	2.31E-02	7.85E-03	4.7267E-01	7.9365E+01

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9385930	0.9667300	0.9689460	0.9873020	0.9723240	1.3461E+02	4.6326E+00
$\alpha_2$	3.60E-03	1.67E-02	1.45E-02	3.76E-02	5.47E-03	2.3306E+00	1.3691E+02
$\alpha_3$	9.65E-04	9.73E-03	7.51E-03	2.61E-02	9.56E-03	1.3553E+00	1.3789E+02
$\alpha_4$	1.20E-04	5.38E-03	3.27E-03	1.78E-02	9.48E-03	7.4939E-01	1.3849E+02
$\alpha_5$	1.19E-09	1.42E-03	1.42E-04	7.33E-03	3.16E-03	1.9728E-01	1.3905E+02

##### CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9428380	0.9678380	0.9696720	0.9865660	0.9758840	1.6302E+02	5.4173E+00
$\alpha_2$	3.25E-03	1.45E-02	1.26E-02	3.21E-02	4.14E-03	2.4346E+00	1.6600E+02
$\alpha_3$	8.68E-04	8.30E-03	6.45E-03	2.20E-02	5.42E-03	1.3975E+00	1.6704E+02
$\alpha_4$	2.72E-04	5.74E-03	3.94E-03	1.74E-02	7.94E-03	9.6722E-01	1.6747E+02
$\alpha_5$	8.11E-06	2.80E-03	1.21E-03	1.10E-02	5.30E-03	4.7220E-01	1.6797E+02
$\alpha_6$	4.43E-12	8.65E-04	3.23E-05	4.79E-03	1.32E-03	1.4574E-01	1.6829E+02

## Pooled Check Valves

CHECK VALVE FAIL TO CLOSE ALL SYSTEMS SPAR:CKV-OO

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9487750	0.9688850	0.9701490	0.9846690	0.9783170	2.3775E+02	7.6352E+00
$\alpha_2$	4.00E-03	1.34E-02	1.21E-02	2.73E-02	3.85E-03	3.2991E+00	2.4209E+02
$\alpha_3$	1.14E-03	7.33E-03	6.04E-03	1.79E-02	3.03E-03	1.7975E+00	2.4359E+02
$\alpha_4$	4.86E-04	5.30E-03	4.03E-03	1.45E-02	5.69E-03	1.3014E+00	2.4408E+02
$\alpha_5$	1.06E-04	3.40E-03	2.18E-03	1.08E-02	5.69E-03	8.3427E-01	2.4455E+02
$\alpha_6$	4.66E-07	1.40E-03	4.17E-04	6.11E-03	2.85E-03	3.4258E-01	2.4504E+02
$\alpha_7$	6.77E-25	2.46E-04	2.48E-08	1.38E-03	5.70E-04	6.0371E-02	2.4532E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9517130	0.9698750	0.9709520	0.9843510	0.9802170	2.8004E+02	8.6984E+00
$\alpha_2$	3.92E-03	1.24E-02	1.13E-02	2.46E-02	3.72E-03	3.5771E+00	2.8516E+02
$\alpha_3$	1.04E-03	6.41E-03	5.32E-03	1.55E-02	1.82E-03	1.8521E+00	2.8689E+02
$\alpha_4$	4.89E-04	4.78E-03	3.70E-03	1.28E-02	3.76E-03	1.3815E+00	2.8736E+02
$\alpha_5$	1.91E-04	3.54E-03	2.48E-03	1.05E-02	5.00E-03	1.0208E+00	2.8772E+02
$\alpha_6$	1.98E-05	2.08E-03	1.10E-03	7.48E-03	3.75E-03	6.0136E-01	2.8814E+02
$\alpha_7$	2.28E-09	7.51E-04	9.57E-05	3.79E-03	1.50E-03	2.1677E-01	2.8852E+02
$\alpha_8$	4.02E-30	1.69E-04	1.34E-09	8.90E-04	2.49E-04	4.8724E-02	2.8869E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9385750	0.9573830	0.9667880	0.9723240	0.9758840	0.9783170	0.9802170
$\alpha_2$	6.14E-02	2.19E-02	9.63E-03	5.47E-03	4.14E-03	3.85E-03	3.72E-03
$\alpha_3$		2.07E-02	1.57E-02	9.56E-03	5.42E-03	3.03E-03	1.82E-03
$\alpha_4$			7.85E-03	9.48E-03	7.94E-03	5.69E-03	3.76E-03
$\alpha_5$				3.16E-03	5.30E-03	5.69E-03	5.00E-03
$\alpha_6$					1.32E-03	2.85E-03	3.75E-03
$\alpha_7$						5.70E-04	1.50E-03
$\alpha_8$							2.49E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.39E-01	9.57E-01	9.67E-01	9.72E-01	9.76E-01	9.78E-01	9.80E-01
Beta	6.14E-02	4.26E-02	3.32E-02	2.77E-02	2.41E-02	2.17E-02	1.98E-02
Gamma		4.86E-01	7.10E-01	8.02E-01	8.28E-01	8.22E-01	8.12E-01
Delta			3.33E-01	5.70E-01	7.29E-01	8.30E-01	8.87E-01
Epsilon				2.50E-01	4.55E-01	6.15E-01	7.36E-01
Mu					2.00E-01	3.75E-01	5.24E-01
Upsilon						1.67E-01	3.18E-01
Sigma							1.43E-01

**BWR Residual Heat Removal Check Valves****BWR RHR CHECK VALVE FAIL TO OPEN**

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	15.11	22.67	30.22	37.78	45.33	52.89	60.44
N <sub>1</sub>	0.3229	0.4551	0.5691	0.6657	0.7457	0.8100	0.8717
N <sub>2</sub>	1.0100	0.5291	0.3066	0.2164	0.1954	0.2113	0.2324
N <sub>3</sub>		0.5003	0.5011	0.3779	0.2557	0.1663	0.1137
N <sub>4</sub>			0.2500	0.3750	0.3750	0.3125	0.2350
N <sub>5</sub>				0.1250	0.2500	0.3125	0.3125
N <sub>6</sub>					0.0625	0.1563	0.2344
N <sub>7</sub>						0.0313	0.0938
N <sub>8</sub>							0.0156

**1.5.2 BWR Residual Heat Removal Check Valves****1.5.2.1 BWR RHR CHECK VALVE FAIL TO OPEN**

**System :** Residual Heat Removal (LCI in BWRs, LPI in PWRs)  
**Component :** Check Valve  
**Failure Mode :** Fail to open on demand  
**Plant Type :** BWR  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8636860	0.9657330	0.9856730	0.9999380	1.0000000	1.2246E+01	4.3452E-01
$\alpha_2$	6.41E-05	3.43E-02	1.43E-02	1.36E-01	0.00E+00	4.3452E-01	1.2246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9040420	0.9662880	0.9752810	0.9977560	1.0000000	3.1555E+01	1.1009E+00
$\alpha_2$	8.16E-04	2.55E-02	1.67E-02	8.05E-02	0.00E+00	8.3366E-01	3.1822E+01
$\alpha_3$	2.88E-07	8.18E-03	1.66E-03	3.88E-02	0.00E+00	2.6722E-01	3.2389E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9113590	0.9628920	0.9688970	0.9938680	1.0000000	4.8136E+01	1.8551E+00
$\alpha_2$	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
$\alpha_3$	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
$\alpha_4$	1.93E-08	4.45E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9768E+01

**BWR Residual Heat Removal Check Valves****BWR RHR CHECK VALVE FAIL TO OPEN****CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9311740	0.9652090	0.9682200	0.9889480	1.0000000	9.8161E+01	3.5382E+00
$\alpha_2$	4.01E-03	2.08E-02	1.77E-02	4.80E-02	0.00E+00	2.1142E+00	9.9585E+01
$\alpha_3$	4.70E-04	9.61E-03	6.64E-03	2.89E-02	0.00E+00	9.7738E-01	1.0072E+02
$\alpha_4$	2.42E-06	3.68E-03	1.24E-03	1.56E-02	0.00E+00	3.7439E-01	1.0132E+02
$\alpha_5$	5.87E-21	7.11E-04	4.02E-07	4.12E-03	0.00E+00	7.2277E-02	1.0163E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9346440	0.9652760	0.9677640	0.9873890	1.0000000	1.1894E+02	4.2787E+00
$\alpha_2$	3.74E-03	1.82E-02	1.56E-02	4.13E-02	0.00E+00	2.2392E+00	1.2098E+02
$\alpha_3$	6.53E-04	9.27E-03	6.78E-03	2.64E-02	0.00E+00	1.1418E+00	1.2208E+02
$\alpha_4$	4.30E-05	4.81E-03	2.52E-03	1.73E-02	0.00E+00	5.9222E-01	1.2263E+02
$\alpha_5$	7.54E-09	1.80E-03	2.45E-04	9.04E-03	0.00E+00	2.2220E-01	1.2300E+02
$\alpha_6$	1.14E-18	6.76E-04	1.18E-06	3.94E-03	0.00E+00	8.3237E-02	1.2314E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9428470	0.9665190	0.9681250	0.9847050	1.0000000	1.8605E+02	6.4450E+00
$\alpha_2$	4.52E-03	1.60E-02	1.44E-02	3.32E-02	0.00E+00	3.0878E+00	1.8941E+02
$\alpha_3$	1.14E-03	8.47E-03	6.84E-03	2.14E-02	0.00E+00	1.6312E+00	1.9086E+02
$\alpha_4$	2.57E-04	5.14E-03	3.56E-03	1.54E-02	0.00E+00	9.8887E-01	1.9151E+02
$\alpha_5$	1.33E-05	2.71E-03	1.28E-03	1.02E-02	0.00E+00	5.2177E-01	1.9197E+02
$\alpha_6$	3.49E-10	9.68E-04	8.26E-05	5.08E-03	0.00E+00	1.8628E-01	1.9231E+02
$\alpha_7$	0.00E+00	1.51E-04	1.32E-13	5.69E-04	0.00E+00	2.9071E-02	1.9247E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9459360	0.9673040	0.9686640	0.9840410	1.0000000	2.2073E+02	7.4610E+00
$\alpha_2$	4.41E-03	1.47E-02	1.33E-02	2.97E-02	0.00E+00	3.3447E+00	2.2485E+02
$\alpha_3$	1.13E-03	7.62E-03	6.24E-03	1.88E-02	0.00E+00	1.7384E+00	2.2645E+02
$\alpha_4$	3.56E-04	5.02E-03	3.67E-03	1.43E-02	0.00E+00	1.1465E+00	2.2704E+02
$\alpha_5$	5.65E-05	3.10E-03	1.82E-03	1.05E-02	0.00E+00	7.0833E-01	2.2748E+02
$\alpha_6$	9.10E-07	1.61E-03	5.27E-04	6.88E-03	0.00E+00	3.6696E-01	2.2782E+02
$\alpha_7$	7.14E-14	5.39E-04	9.69E-06	3.07E-03	0.00E+00	1.2297E-01	2.2807E+02
$\alpha_8$	1.34E-42	1.45E-04	2.07E-12	6.14E-04	0.00E+00	3.3124E-02	2.2816E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	2.00	2.00	2.00	2.00	2.00	2.00	2.00
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

**1.5.2.2 BWR RHR CHECK VALVE FAIL TO CLOSE**

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Check Valve
Failure Mode :	Fail to close (reseat) on demand
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 6.00

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8959650	0.9739500	0.9892430	0.9999480	1.0000000	1.6246E+01	4.3452E-01
$\alpha_2$	4.81E-05	2.60E-02	1.08E-02	1.04E-01	0.00E+00	4.3452E-01	1.6246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9143470	0.9699670	0.9780280	0.9980130	1.0000000	3.5555E+01	1.1009E+00
$\alpha_2$	7.25E-04	2.27E-02	1.48E-02	7.18E-02	0.00E+00	8.3366E-01	3.5822E+01
$\alpha_3$	2.56E-07	7.29E-03	1.48E-03	3.46E-02	0.00E+00	2.6722E-01	3.6389E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9178250	0.9656410	0.9712250	0.9943340	1.0000000	5.2136E+01	1.8551E+00
$\alpha_2$	1.89E-03	2.27E-02	1.72E-02	6.27E-02	0.00E+00	1.2281E+00	5.2763E+01
$\alpha_3$	8.45E-06	7.49E-03	2.78E-03	3.09E-02	0.00E+00	4.0431E-01	5.3587E+01
$\alpha_4$	1.78E-08	4.12E-03	5.66E-04	2.07E-02	0.00E+00	2.2267E-01	5.3768E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9337450	0.9665250	0.9694270	0.9893730	1.0000000	1.0216E+02	3.5382E+00
$\alpha_2$	3.85E-03	2.00E-02	1.71E-02	4.62E-02	0.00E+00	2.1142E+00	1.0358E+02
$\alpha_3$	4.52E-04	9.25E-03	6.39E-03	2.78E-02	0.00E+00	9.7738E-01	1.0472E+02
$\alpha_4$	2.33E-06	3.54E-03	1.19E-03	1.50E-02	0.00E+00	3.7439E-01	1.0532E+02
$\alpha_5$	5.65E-21	6.84E-04	3.87E-07	3.96E-03	0.00E+00	7.2277E-02	1.0563E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9366750	0.9663680	0.9687880	0.9877920	1.0000000	1.2294E+02	4.2787E+00
$\alpha_2$	3.62E-03	1.76E-02	1.51E-02	4.00E-02	0.00E+00	2.2392E+00	1.2498E+02
$\alpha_3$	6.32E-04	8.98E-03	6.57E-03	2.55E-02	0.00E+00	1.1418E+00	1.2608E+02
$\alpha_4$	4.16E-05	4.66E-03	2.44E-03	1.68E-02	0.00E+00	5.9222E-01	1.2663E+02
$\alpha_5$	7.30E-09	1.75E-03	2.37E-04	8.75E-03	0.00E+00	2.2220E-01	1.2700E+02
$\alpha_6$	1.11E-18	6.54E-04	1.14E-06	3.82E-03	0.00E+00	8.3237E-02	1.2714E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9439980	0.9672000	0.9687770	0.9850250	1.0000000	1.9005E+02	6.4450E+00
$\alpha_2$	4.43E-03	1.57E-02	1.41E-02	3.25E-02	0.00E+00	3.0878E+00	1.9341E+02
$\alpha_3$	1.12E-03	8.30E-03	6.70E-03	2.10E-02	0.00E+00	1.6312E+00	1.9486E+02
$\alpha_4$	2.52E-04	5.03E-03	3.48E-03	1.51E-02	0.00E+00	9.8887E-01	1.9551E+02
$\alpha_5$	1.31E-05	2.66E-03	1.26E-03	1.00E-02	0.00E+00	5.2177E-01	1.9597E+02
$\alpha_6$	3.42E-10	9.48E-04	8.09E-05	4.98E-03	0.00E+00	1.8628E-01	1.9631E+02
$\alpha_7$	0.00E+00	1.48E-04	1.30E-13	5.57E-04	0.00E+00	2.9071E-02	1.9647E+02

**BWR Residual Heat Removal Check Valves****BWR RHR CHECK VALVE FAIL TO CLOSE****CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9468590	0.9678670	0.9692050	0.9843190	1.0000000	2.2473E+02	7.4610E+00
$\alpha_2$	4.33E-03	1.44E-02	1.30E-02	2.92E-02	0.00E+00	3.3447E+00	2.2885E+02
$\alpha_3$	1.11E-03	7.49E-03	6.13E-03	1.85E-02	0.00E+00	1.7384E+00	2.3045E+02
$\alpha_4$	3.50E-04	4.94E-03	3.61E-03	1.41E-02	0.00E+00	1.1465E+00	2.3104E+02
$\alpha_5$	5.55E-05	3.05E-03	1.79E-03	1.03E-02	0.00E+00	7.0833E-01	2.3148E+02
$\alpha_6$	8.95E-07	1.58E-03	5.17E-04	6.76E-03	0.00E+00	3.6696E-01	2.3182E+02
$\alpha_7$	7.01E-14	5.30E-04	9.53E-06	3.02E-03	0.00E+00	1.2297E-01	2.3207E+02
$\alpha_8$	1.31E-42	1.43E-04	2.03E-12	6.03E-04	0.00E+00	3.3124E-02	2.3216E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	1.00E+00						
<b>Beta</b>	0.00E+00						
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	6.00	6.00	6.00	6.00	6.00	6.00	6.00
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0000
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

### 1.5.3 PWR Auxiliary Feedwater Check Valves

#### 1.5.3.1 CHECK VALVE FAIL TO OPEN SPAR: AFW-CKV-CC

System :	Auxiliary feedwater
Component :	Check Valve
Failure Mode :	Fail to open on demand
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8636860	0.9657330	0.9856730	0.9999380	1.0000000	1.2246E+01	4.3452E-01
$\alpha_2$	6.41E-05	3.43E-02	1.43E-02	1.36E-01	0.00E+00	4.3452E-01	1.2246E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9040420	0.9662880	0.9752810	0.9977560	1.0000000	3.1555E+01	1.1009E+00
$\alpha_2$	8.16E-04	2.55E-02	1.67E-02	8.05E-02	0.00E+00	8.3366E-01	3.1822E+01
$\alpha_3$	2.88E-07	8.18E-03	1.66E-03	3.88E-02	0.00E+00	2.6722E-01	3.2389E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9113590	0.9628920	0.9688970	0.9938680	1.0000000	4.8136E+01	1.8551E+00
$\alpha_2$	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
$\alpha_3$	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
$\alpha_4$	1.93E-08	4.45E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9768E+01

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9311740	0.9652090	0.9682200	0.9889480	1.0000000	9.8161E+01	3.5382E+00
$\alpha_2$	4.01E-03	2.08E-02	1.77E-02	4.80E-02	0.00E+00	2.1142E+00	9.9585E+01
$\alpha_3$	4.70E-04	9.61E-03	6.64E-03	2.89E-02	0.00E+00	9.7738E-01	1.0072E+02
$\alpha_4$	2.42E-06	3.68E-03	1.24E-03	1.56E-02	0.00E+00	3.7439E-01	1.0132E+02
$\alpha_5$	5.87E-21	7.11E-04	4.02E-07	4.12E-03	0.00E+00	7.2277E-02	1.0163E+02

##### CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9346440	0.9652760	0.9677640	0.9873890	1.0000000	1.1894E+02	4.2787E+00
$\alpha_2$	3.74E-03	1.82E-02	1.56E-02	4.13E-02	0.00E+00	2.2392E+00	1.2098E+02
$\alpha_3$	6.53E-04	9.27E-03	6.78E-03	2.64E-02	0.00E+00	1.1418E+00	1.2208E+02
$\alpha_4$	4.30E-05	4.81E-03	2.52E-03	1.73E-02	0.00E+00	5.9222E-01	1.2263E+02
$\alpha_5$	7.54E-09	1.80E-03	2.45E-04	9.04E-03	0.00E+00	2.2220E-01	1.2300E+02
$\alpha_6$	1.14E-18	6.76E-04	1.18E-06	3.94E-03	0.00E+00	8.3237E-02	1.2314E+02

**PWR Auxiliary Feedwater Check Valves**  
**CHECK VALVE FAIL TO OPEN SPAR: AFW-CKV-CC**

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9428470	0.9665190	0.9681250	0.9847050	1.0000000	1.8605E+02	6.4450E+00
$\alpha_2$	4.52E-03	1.60E-02	1.44E-02	3.32E-02	0.00E+00	3.0878E+00	1.8941E+02
$\alpha_3$	1.14E-03	8.47E-03	6.84E-03	2.14E-02	0.00E+00	1.6312E+00	1.9086E+02
$\alpha_4$	2.57E-04	5.14E-03	3.56E-03	1.54E-02	0.00E+00	9.8887E-01	1.9151E+02
$\alpha_5$	1.33E-05	2.71E-03	1.28E-03	1.02E-02	0.00E+00	5.2177E-01	1.9197E+02
$\alpha_6$	3.49E-10	9.68E-04	8.26E-05	5.08E-03	0.00E+00	1.8628E-01	1.9231E+02
$\alpha_7$	0.00E+00	1.51E-04	1.32E-13	5.69E-04	0.00E+00	2.9071E-02	1.9247E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9459360	0.9673040	0.9686640	0.9840410	1.0000000	2.2073E+02	7.4610E+00
$\alpha_2$	4.41E-03	1.47E-02	1.33E-02	2.97E-02	0.00E+00	3.3447E+00	2.2485E+02
$\alpha_3$	1.13E-03	7.62E-03	6.24E-03	1.88E-02	0.00E+00	1.7384E+00	2.2645E+02
$\alpha_4$	3.56E-04	5.02E-03	3.67E-03	1.43E-02	0.00E+00	1.1465E+00	2.2704E+02
$\alpha_5$	5.65E-05	3.10E-03	1.82E-03	1.05E-02	0.00E+00	7.0833E-01	2.2748E+02
$\alpha_6$	9.10E-07	1.61E-03	5.27E-04	6.88E-03	0.00E+00	3.6696E-01	2.2782E+02
$\alpha_7$	7.14E-14	5.39E-04	9.69E-06	3.07E-03	0.00E+00	1.2297E-01	2.2807E+02
$\alpha_8$	1.34E-42	1.45E-04	2.07E-12	6.14E-04	0.00E+00	3.3124E-02	2.2816E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	1.00E+00						
<b>Beta</b>	0.00E+00						
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	2.00	2.00	2.00	2.00	2.00	2.00	2.00
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

### 1.5.3.2 CHECK VALVE FAIL TO CLOSE SPAR: AFW-CKV-OO

System :

Auxiliary feedwater

Component :

Check Valve

Failure Mode :

Fail to close (reseat) on demand

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 4.00

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8558670	0.9634250	0.9843130	0.9999230	0.9932110	1.1709E+01	4.4452E-01
$\alpha_2$	7.88E-05	3.66E-02	1.57E-02	1.44E-01	6.79E-03	4.4452E-01	1.1709E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9029900	0.9655930	0.9745390	0.9975700	0.9866030	3.1720E+01	1.1303E+00
$\alpha_2$	9.30E-04	2.63E-02	1.74E-02	8.18E-02	1.33E-02	8.6276E-01	3.1988E+01
$\alpha_3$	2.90E-07	8.14E-03	1.65E-03	3.86E-02	1.37E-04	2.6752E-01	3.2583E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9111300	0.9624270	0.9683240	0.9935330	0.9802180	4.8995E+01	1.9128E+00
$\alpha_2$	2.29E-03	2.52E-02	1.93E-02	6.84E-02	1.94E-02	1.2847E+00	4.9623E+01
$\alpha_3$	9.16E-06	7.96E-03	2.97E-03	3.28E-02	3.77E-04	4.0541E-01	5.0502E+01
$\alpha_4$	1.89E-08	4.37E-03	6.00E-04	2.19E-02	0.00E+00	2.2267E-01	5.0685E+01

## PWR Auxiliary Feedwater Check Valves

CHECK VALVE FAIL TO CLOSE SPAR: AFW-CKV-OO

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9309460	0.9648420	0.9678000	0.9886060	0.9739500	9.9687E+01	3.6325E+00
$\alpha_2$	4.32E-03	2.13E-02	1.83E-02	4.87E-02	2.52E-02	2.2056E+00	1.0111E+02
$\alpha_3$	4.67E-04	9.49E-03	6.57E-03	2.85E-02	8.01E-04	9.8028E-01	1.0234E+02
$\alpha_4$	2.38E-06	3.62E-03	1.22E-03	1.54E-02	0.00E+00	3.7439E-01	1.0295E+02
$\alpha_5$	5.78E-21	7.00E-04	3.96E-07	4.05E-03	0.00E+00	7.2277E-02	1.0325E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9343170	0.9648130	0.9672600	0.9869530	0.9678740	1.2112E+02	4.4173E+00
$\alpha_2$	4.14E-03	1.89E-02	1.64E-02	4.22E-02	3.08E-02	2.3721E+00	1.2317E+02
$\alpha_3$	6.51E-04	9.14E-03	6.70E-03	2.60E-02	1.32E-03	1.1475E+00	1.2439E+02
$\alpha_4$	4.22E-05	4.72E-03	2.47E-03	1.70E-02	0.00E+00	5.9222E-01	1.2495E+02
$\alpha_5$	7.40E-09	1.77E-03	2.40E-04	8.87E-03	0.00E+00	2.2220E-01	1.2532E+02
$\alpha_6$	1.12E-18	6.63E-04	1.16E-06	3.87E-03	0.00E+00	8.3237E-02	1.2545E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9424460	0.9660610	0.9676370	0.9842810	0.9620000	1.8886E+02	6.6350E+00
$\alpha_2$	4.94E-03	1.67E-02	1.51E-02	3.40E-02	3.60E-02	3.2678E+00	1.9223E+02
$\alpha_3$	1.14E-03	8.40E-03	6.79E-03	2.11E-02	2.00E-03	1.6412E+00	1.9385E+02
$\alpha_4$	2.54E-04	5.06E-03	3.50E-03	1.52E-02	0.00E+00	9.8887E-01	1.9451E+02
$\alpha_5$	1.31E-05	2.67E-03	1.26E-03	1.01E-02	0.00E+00	5.2177E-01	1.9497E+02
$\alpha_6$	3.44E-10	9.53E-04	8.14E-05	5.00E-03	0.00E+00	1.8628E-01	1.9531E+02
$\alpha_7$	0.00E+00	1.49E-04	1.30E-13	5.60E-04	0.00E+00	2.9071E-02	1.9547E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9454720	0.9667990	0.9681350	0.9835730	0.9582140	2.2417E+02	7.6983E+00
$\alpha_2$	4.86E-03	1.54E-02	1.40E-02	3.05E-02	3.82E-02	3.5615E+00	2.2831E+02
$\alpha_3$	1.14E-03	7.58E-03	6.22E-03	1.87E-02	3.50E-03	1.7583E+00	2.3011E+02
$\alpha_4$	3.51E-04	4.95E-03	3.62E-03	1.41E-02	1.06E-04	1.1471E+00	2.3072E+02
$\alpha_5$	5.56E-05	3.05E-03	1.80E-03	1.03E-02	0.00E+00	7.0833E-01	2.3116E+02
$\alpha_6$	8.96E-07	1.58E-03	5.18E-04	6.77E-03	0.00E+00	3.6696E-01	2.3150E+02
$\alpha_7$	7.02E-14	5.30E-04	9.54E-06	3.02E-03	0.00E+00	1.2297E-01	2.3175E+02
$\alpha_8$	1.32E-42	1.43E-04	2.04E-12	6.04E-04	0.00E+00	3.3124E-02	2.3184E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9932110	0.9866030	0.9802180	0.9739500	0.9678740	0.9620000	0.9582140
$\alpha_2$	6.79E-03	1.33E-02	1.94E-02	2.52E-02	3.08E-02	3.60E-02	3.82E-02
$\alpha_3$		1.37E-04	3.77E-04	8.01E-04	1.32E-03	2.00E-03	3.50E-03
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.06E-04
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.93E-01	9.87E-01	9.80E-01	9.74E-01	9.68E-01	9.62E-01	9.58E-01
Beta	6.79E-03	1.34E-02	1.98E-02	2.60E-02	3.21E-02	3.80E-02	4.18E-02
Gamma		1.02E-02	1.91E-02	3.08E-02	4.11E-02	5.26E-02	8.64E-02
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.93E-02
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	1.14	1.71	2.29	2.86	3.43	4.00	4.57
N <sub>1</sub>	0.3229	0.4551	0.5691	0.6657	0.7457	0.8100	0.8717
N <sub>2</sub>	0.0100	0.0291	0.0566	0.0914	0.1329	0.1800	0.2168
N <sub>3</sub>		0.0003	0.0011	0.0029	0.0057	0.0100	0.0199
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0006
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

**1.5.4 PWR High Pressure Safety Injection Check Valves****1.5.4.1 HIGH PRESSURE INJECTION CHECK VALVE FAIL TO OPEN**

System :

Chemical and volume control

High pressure injection

Component :

Check Valve

Failure Mode :

Fail to open on demand

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 3.00

Total Number of Common-Cause Failure Events: 0

## PWR High Pressure Safety Injection Check Valves

## HIGH PRESSURE INJECTION CHECK VALVE FAIL TO OPEN

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8734960	0.9682380	0.9867710	0.9999360	1.0000000	1.3246E+01	4.3452E-01
$\alpha_2$	5.92E-05	3.18E-02	1.32E-02	1.27E-01	0.00E+00	4.3452E-01	1.3246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9068390	0.9672900	0.9760300	0.9978250	1.0000000	3.2555E+01	1.1009E+00
$\alpha_2$	7.91E-04	2.48E-02	1.62E-02	7.82E-02	0.00E+00	8.3366E-01	3.2822E+01
$\alpha_3$	2.80E-07	7.94E-03	1.61E-03	3.77E-02	0.00E+00	2.6722E-01	3.3389E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9130680	0.9636200	0.9695110	0.9939910	1.0000000	4.9136E+01	1.8551E+00
$\alpha_2$	2.00E-03	2.41E-02	1.82E-02	6.63E-02	0.00E+00	1.2281E+00	4.9763E+01
$\alpha_3$	8.95E-06	7.93E-03	2.95E-03	3.27E-02	0.00E+00	4.0431E-01	5.0587E+01
$\alpha_4$	1.89E-08	4.37E-03	5.99E-04	2.19E-02	0.00E+00	2.2267E-01	5.0768E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9318350	0.9655480	0.9685320	0.9890570	1.0000000	9.9161E+01	3.5382E+00
$\alpha_2$	3.97E-03	2.06E-02	1.76E-02	4.76E-02	0.00E+00	2.1142E+00	1.0059E+02
$\alpha_3$	4.65E-04	9.52E-03	6.58E-03	2.86E-02	0.00E+00	9.7738E-01	1.0172E+02
$\alpha_4$	2.40E-06	3.65E-03	1.23E-03	1.55E-02	0.00E+00	3.7439E-01	1.0232E+02
$\alpha_5$	5.81E-21	7.04E-04	3.98E-07	4.08E-03	0.00E+00	7.2277E-02	1.0263E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9351640	0.9655550	0.9680290	0.9874920	1.0000000	1.1994E+02	4.2787E+00
$\alpha_2$	3.71E-03	1.80E-02	1.55E-02	4.10E-02	0.00E+00	2.2392E+00	1.2198E+02
$\alpha_3$	6.48E-04	9.19E-03	6.73E-03	2.62E-02	0.00E+00	1.1418E+00	1.2308E+02
$\alpha_4$	4.26E-05	4.77E-03	2.50E-03	1.72E-02	0.00E+00	5.9222E-01	1.2363E+02
$\alpha_5$	7.48E-09	1.79E-03	2.43E-04	8.96E-03	0.00E+00	2.2220E-01	1.2400E+02
$\alpha_6$	1.14E-18	6.70E-04	1.17E-06	3.91E-03	0.00E+00	8.3237E-02	1.2414E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

## PWR High Pressure Safety Injection Check Valves

## HIGH PRESSURE INJECTION CHECK VALVE FAIL TO CLOSE

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	3.00	3.00	3.00	3.00	3.00
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000
N <sub>6</sub>					0.0000

**1.5.4.2 HIGH PRESSURE INJECTION CHECK VALVE FAIL TO CLOSE**

System :

Chemical and volume control

High pressure injection

Component :

Check Valve

Failure Mode :

Fail to close (reseat) on demand

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 7.50

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9044540	0.9761000	0.9901620	0.9999520	1.0000000	1.7746E+01	4.3452E-01
$\alpha_2$	4.39E-05	2.39E-02	9.84E-03	9.55E-02	0.00E+00	4.3452E-01	1.7746E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9176630	0.9711480	0.9789060	0.9980930	1.0000000	3.7055E+01	1.1009E+00
$\alpha_2$	6.96E-04	2.18E-02	1.42E-02	6.91E-02	0.00E+00	8.3366E-01	3.7322E+01
$\alpha_3$	2.46E-07	7.00E-03	1.42E-03	3.32E-02	0.00E+00	2.6722E-01	3.7889E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9200060	0.9665700	0.9720120	0.9944910	1.0000000	5.3636E+01	1.8551E+00
$\alpha_2$	1.84E-03	2.21E-02	1.67E-02	6.10E-02	0.00E+00	1.2281E+00	5.4263E+01
$\alpha_3$	8.22E-06	7.29E-03	2.71E-03	3.01E-02	0.00E+00	4.0431E-01	5.5087E+01
$\alpha_4$	1.73E-08	4.01E-03	5.50E-04	2.01E-02	0.00E+00	2.2267E-01	5.5268E+01

## PWR High Pressure Safety Injection Check Valves

## HIGH PRESSURE INJECTION CHECK VALVE FAIL TO CLOSE

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9346610	0.9669930	0.9698570	0.9895240	1.0000000	1.0366E+02	3.5382E+00
$\alpha_2$	3.80E-03	1.97E-02	1.68E-02	4.56E-02	0.00E+00	2.1142E+00	1.0508E+02
$\alpha_3$	4.45E-04	9.12E-03	6.30E-03	2.74E-02	0.00E+00	9.7738E-01	1.0622E+02
$\alpha_4$	2.30E-06	3.49E-03	1.18E-03	1.48E-02	0.00E+00	3.7439E-01	1.0682E+02
$\alpha_5$	5.57E-21	6.74E-04	3.81E-07	3.90E-03	0.00E+00	7.2277E-02	1.0713E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9374050	0.9667600	0.9691540	0.9879360	1.0000000	1.2444E+02	4.2787E+00
$\alpha_2$	3.58E-03	1.74E-02	1.50E-02	3.95E-02	0.00E+00	2.2392E+00	1.2648E+02
$\alpha_3$	6.25E-04	8.87E-03	6.49E-03	2.53E-02	0.00E+00	1.1418E+00	1.2758E+02
$\alpha_4$	4.11E-05	4.60E-03	2.41E-03	1.66E-02	0.00E+00	5.9222E-01	1.2813E+02
$\alpha_5$	7.22E-09	1.73E-03	2.34E-04	8.65E-03	0.00E+00	2.2220E-01	1.2850E+02
$\alpha_6$	1.10E-18	6.47E-04	1.13E-06	3.77E-03	0.00E+00	8.3237E-02	1.2864E+02

**ALPHA FACTOR and MGL PARAMETERS**

<b>Alpha Factor</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

<b>MGL Parameter</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>
<b>1-Beta</b>	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
<b>Beta</b>	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00

<b>Avg. Impact Vector</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>
<b>Adj. Ind. Events</b>	7.50	7.50	7.50	7.50	7.50
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000

## 1.5.5 PWR Residual Heat Removal Check Valves

### 1.5.5.1 PWR RHR CHECK VALVE FAIL TO OPEN

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)		
Component :	Check Valve		
Failure Mode :	Fail to open on demand		
Plant Type :	PWR		
Start Date :	1997/01/01		
Data Version :	2009/12/31		

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

### ALPHA FACTOR DISTRIBUTIONS

#### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8386830	0.9593170	0.9828300	0.9999250	1.0000000	1.0246E+01	4.3452E-01
$\alpha_2$	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

#### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8979020	0.9640890	0.9736330	0.9976040	1.0000000	2.9555E+01	1.1009E+00
$\alpha_2$	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
$\alpha_3$	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

#### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9077330	0.9613450	0.9675780	0.9936050	1.0000000	4.6136E+01	1.8551E+00
$\alpha_2$	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
$\alpha_3$	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
$\alpha_4$	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

#### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9298110	0.9645110	0.9675740	0.9887220	1.0000000	9.6161E+01	3.5382E+00
$\alpha_2$	4.09E-03	2.12E-02	1.81E-02	4.90E-02	0.00E+00	2.1142E+00	9.7585E+01
$\alpha_3$	4.79E-04	9.80E-03	6.78E-03	2.95E-02	0.00E+00	9.7738E-01	9.8722E+01
$\alpha_4$	2.47E-06	3.76E-03	1.27E-03	1.59E-02	0.00E+00	3.7439E-01	9.9325E+01
$\alpha_5$	5.99E-21	7.25E-04	4.10E-07	4.20E-03	0.00E+00	7.2277E-02	9.9627E+01

#### CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9335790	0.9647030	0.9672350	0.9871780	1.0000000	1.1694E+02	4.2787E+00
$\alpha_2$	3.80E-03	1.85E-02	1.59E-02	4.20E-02	0.00E+00	2.2392E+00	1.1898E+02
$\alpha_3$	6.64E-04	9.42E-03	6.89E-03	2.68E-02	0.00E+00	1.1418E+00	1.2008E+02
$\alpha_4$	4.37E-05	4.89E-03	2.56E-03	1.76E-02	0.00E+00	5.9222E-01	1.2063E+02
$\alpha_5$	7.67E-09	1.83E-03	2.49E-04	9.18E-03	0.00E+00	2.2220E-01	1.2100E+02
$\alpha_6$	1.16E-18	6.87E-04	1.20E-06	4.01E-03	0.00E+00	8.3237E-02	1.2114E+02

## PWR Residual Heat Removal Check Valves

PWR RHR CHECK VALVE FAIL TO OPEN

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9422570	0.9661670	0.9677850	0.9845420	1.0000000	1.8405E+02	6.4450E+00
$\alpha_2$	4.57E-03	1.62E-02	1.45E-02	3.35E-02	0.00E+00	3.0878E+00	1.8741E+02
$\alpha_3$	1.15E-03	8.56E-03	6.91E-03	2.16E-02	0.00E+00	1.6312E+00	1.8886E+02
$\alpha_4$	2.60E-04	5.19E-03	3.59E-03	1.56E-02	0.00E+00	9.8887E-01	1.8951E+02
$\alpha_5$	1.35E-05	2.74E-03	1.30E-03	1.04E-02	0.00E+00	5.2177E-01	1.8997E+02
$\alpha_6$	3.53E-10	9.78E-04	8.35E-05	5.13E-03	0.00E+00	1.8628E-01	1.9031E+02
$\alpha_7$	0.00E+00	1.53E-04	1.34E-13	5.75E-04	0.00E+00	2.9071E-02	1.9047E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9454620	0.9670150	0.9683850	0.9838980	1.0000000	2.1873E+02	7.4610E+00
$\alpha_2$	4.45E-03	1.48E-02	1.34E-02	2.99E-02	0.00E+00	3.3447E+00	2.2285E+02
$\alpha_3$	1.14E-03	7.69E-03	6.29E-03	1.90E-02	0.00E+00	1.7384E+00	2.2445E+02
$\alpha_4$	3.59E-04	5.07E-03	3.71E-03	1.44E-02	0.00E+00	1.1465E+00	2.2504E+02
$\alpha_5$	5.70E-05	3.13E-03	1.84E-03	1.06E-02	0.00E+00	7.0833E-01	2.2548E+02
$\alpha_6$	9.18E-07	1.62E-03	5.31E-04	6.94E-03	0.00E+00	3.6696E-01	2.2582E+02
$\alpha_7$	7.20E-14	5.44E-04	9.78E-06	3.10E-03	0.00E+00	1.2297E-01	2.2607E+02
$\alpha_8$	1.35E-42	1.46E-04	2.09E-12	6.19E-04	0.00E+00	3.3124E-02	2.2616E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	0.00E+00						
<b>Beta</b>	0.00E+00						
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

## PWR Residual Heat Removal Check Valves

PWR RHR CHECK VALVE FAIL TO CLOSE

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	0.00	0.00	0.00	0.00	0.00	0.00	0.00
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

**1.5.5.2 PWR RHR CHECK VALVE FAIL TO CLOSE**

System :

Residual Heat Removal (LCI in BWRs, LPI in PWRs)

Component :

Check Valve

Failure Mode :

Fail to close (reseat) on demand

Plant Type :

PWR

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 6.50

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8989610	0.9747090	0.9895680	0.9999500	1.0000000	1.6746E+01	4.3452E-01
$\alpha_2$	4.66E-05	2.53E-02	1.04E-02	1.01E-01	0.00E+00	4.3452E-01	1.6746E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9154810	0.9703710	0.9783290	0.9980400	1.0000000	3.6055E+01	1.1009E+00
$\alpha_2$	7.15E-04	2.24E-02	1.46E-02	7.09E-02	0.00E+00	8.3366E-01	3.6322E+01
$\alpha_3$	2.53E-07	7.19E-03	1.45E-03	3.41E-02	0.00E+00	2.6722E-01	3.6889E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9185670	0.9659560	0.9714920	0.9943870	1.0000000	5.2636E+01	1.8551E+00
$\alpha_2$	1.87E-03	2.25E-02	1.70E-02	6.21E-02	0.00E+00	1.2281E+00	5.3263E+01
$\alpha_3$	8.37E-06	7.42E-03	2.76E-03	3.06E-02	0.00E+00	4.0431E-01	5.4087E+01
$\alpha_4$	1.77E-08	4.09E-03	5.60E-04	2.05E-02	0.00E+00	2.2267E-01	5.4268E+01

## PWR Residual Heat Removal Check Valves

PWR RHR CHECK VALVE FAIL TO CLOSE

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9340530	0.9666830	0.9695720	0.9894240	1.0000000	1.0266E+02	3.5382E+00
$\alpha_2$	3.84E-03	1.99E-02	1.70E-02	4.60E-02	0.00E+00	2.1142E+00	1.0408E+02
$\alpha_3$	4.50E-04	9.20E-03	6.36E-03	2.77E-02	0.00E+00	9.7738E-01	1.0522E+02
$\alpha_4$	2.32E-06	3.53E-03	1.19E-03	1.50E-02	0.00E+00	3.7439E-01	1.0582E+02
$\alpha_5$	5.62E-21	6.81E-04	3.85E-07	3.94E-03	0.00E+00	7.2277E-02	1.0613E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9369200	0.9664990	0.9689110	0.9878400	1.0000000	1.2344E+02	4.2787E+00
$\alpha_2$	3.60E-03	1.75E-02	1.51E-02	3.98E-02	0.00E+00	2.2392E+00	1.2548E+02
$\alpha_3$	6.30E-04	8.94E-03	6.54E-03	2.55E-02	0.00E+00	1.1418E+00	1.2658E+02
$\alpha_4$	4.15E-05	4.64E-03	2.43E-03	1.67E-02	0.00E+00	5.9222E-01	1.2713E+02
$\alpha_5$	7.27E-09	1.74E-03	2.36E-04	8.72E-03	0.00E+00	2.2220E-01	1.2750E+02
$\alpha_6$	1.10E-18	6.52E-04	1.14E-06	3.80E-03	0.00E+00	8.3237E-02	1.2764E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9441390	0.9672830	0.9688570	0.9850630	1.0000000	1.9055E+02	6.4450E+00
$\alpha_2$	4.42E-03	1.57E-02	1.41E-02	3.24E-02	0.00E+00	3.0878E+00	1.9391E+02
$\alpha_3$	1.12E-03	8.28E-03	6.69E-03	2.09E-02	0.00E+00	1.6312E+00	1.9536E+02
$\alpha_4$	2.52E-04	5.02E-03	3.48E-03	1.51E-02	0.00E+00	9.8887E-01	1.9601E+02
$\alpha_5$	1.30E-05	2.65E-03	1.25E-03	1.00E-02	0.00E+00	5.2177E-01	1.9647E+02
$\alpha_6$	3.41E-10	9.46E-04	8.07E-05	4.96E-03	0.00E+00	1.8628E-01	1.9681E+02
$\alpha_7$	0.00E+00	1.48E-04	1.29E-13	5.56E-04	0.00E+00	2.9071E-02	1.9697E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9469720	0.9679360	0.9692720	0.9843530	1.0000000	2.2523E+02	7.4610E+00
$\alpha_2$	4.32E-03	1.44E-02	1.30E-02	2.91E-02	0.00E+00	3.3447E+00	2.2935E+02
$\alpha_3$	1.11E-03	7.47E-03	6.11E-03	1.85E-02	0.00E+00	1.7384E+00	2.3095E+02
$\alpha_4$	3.49E-04	4.93E-03	3.60E-03	1.40E-02	0.00E+00	1.1465E+00	2.3154E+02
$\alpha_5$	5.54E-05	3.04E-03	1.79E-03	1.03E-02	0.00E+00	7.0833E-01	2.3198E+02
$\alpha_6$	8.93E-07	1.58E-03	5.16E-04	6.75E-03	0.00E+00	3.6696E-01	2.3232E+02
$\alpha_7$	7.00E-14	5.28E-04	9.50E-06	3.01E-03	0.00E+00	1.2297E-01	2.3257E+02
$\alpha_8$	1.31E-42	1.42E-04	2.03E-12	6.02E-04	0.00E+00	3.3124E-02	2.3266E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	6.50	6.50	6.50	6.50	6.50	6.50	6.50
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

BWR High Pressure Coolant Injection/Reactor Core Isolation Cooling Check Valves  
COMBINED HPCI AND RCIC CHECK VALVE FAIL TO OPEN

## 1.5.6 BWR High Pressure Coolant Injection/Reactor Core Isolation Cooling Check Valves

### 1.5.6.1 COMBINED HPCI AND RCIC CHECK VALVE FAIL TO OPEN

System : High pressure coolant injection  
 Component : Reactor core isolation  
 Failure Mode : Check Valve  
 Start Date : Fail to open on demand  
 Data Version : 1997/01/01  
 2009/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8386830	0.9593170	0.9828300	0.99999250	1.0000000	1.0246E+01	4.3452E-01
$\alpha_2$	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8979020	0.9640890	0.9736330	0.9976040	1.0000000	2.9555E+01	1.1009E+00
$\alpha_2$	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
$\alpha_3$	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9077330	0.9613450	0.9675780	0.9936050	1.0000000	4.6136E+01	1.8551E+00
$\alpha_2$	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
$\alpha_3$	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
$\alpha_4$	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9298110	0.9645110	0.9675740	0.9887220	1.0000000	9.6161E+01	3.5382E+00
$\alpha_2$	4.09E-03	2.12E-02	1.81E-02	4.90E-02	0.00E+00	2.1142E+00	9.7585E+01
$\alpha_3$	4.79E-04	9.80E-03	6.78E-03	2.95E-02	0.00E+00	9.7738E-01	9.8722E+01
$\alpha_4$	2.47E-06	3.76E-03	1.27E-03	1.59E-02	0.00E+00	3.7439E-01	9.9325E+01
$\alpha_5$	5.99E-21	7.25E-04	4.10E-07	4.20E-03	0.00E+00	7.2277E-02	9.9627E+01

**BWR High Pressure Coolant Injection/Reactor Core Isolation Cooling Check Valves****COMBINED HPCI AND RCIC CHECK VALVE FAIL TO CLOSE****CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9335790	0.9647030	0.9672350	0.9871780	1.0000000	1.1694E+02	4.2787E+00
$\alpha_2$	3.80E-03	1.85E-02	1.59E-02	4.20E-02	0.00E+00	2.2392E+00	1.1898E+02
$\alpha_3$	6.64E-04	9.42E-03	6.89E-03	2.68E-02	0.00E+00	1.1418E+00	1.2008E+02
$\alpha_4$	4.37E-05	4.89E-03	2.56E-03	1.76E-02	0.00E+00	5.9222E-01	1.2063E+02
$\alpha_5$	7.67E-09	1.83E-03	2.49E-04	9.18E-03	0.00E+00	2.2220E-01	1.2100E+02
$\alpha_6$	1.16E-18	6.87E-04	1.20E-06	4.01E-03	0.00E+00	8.3237E-02	1.2114E+02

**ALPHA FACTOR and MGL PARAMETERS**

<b>Alpha Factor</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

<b>MGL Parameter</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>
<b>1-Beta</b>	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Beta</b>	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00

<b>Avg. Impact Vector</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>
<b>Adj. Ind. Events</b>	0.00	0.00	0.00	0.00	0.00
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000

**1.5.6.2 COMBINED HPCI AND RCIC CHECK VALVE FAIL TO CLOSE****System :**

High pressure coolant injection

Reactor core isolation

**Component :**

Check Valve

**Failure Mode :**

Fail to close (reseat) on demand

**Start Date :**

1997/01/01

**Data Version :**

2009/12/31

Total Number of Independent Failure Events: 3.00

Total Number of Common-Cause Failure Events: 0

## BWR High Pressure Coolant Injection/Reactor Core Isolation Cooling Check Valves

COMBINED HPCI AND RCIC CHECK VALVE FAIL TO CLOSE

ALPHA FACTOR DISTRIBUTIONS**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8734960	0.9682380	0.9867710	0.9999360	1.0000000	1.3246E+01	4.3452E-01
$\alpha_2$	5.92E-05	3.18E-02	1.32E-02	1.27E-01	0.00E+00	4.3452E-01	1.3246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9068390	0.9672900	0.9760300	0.9978250	1.0000000	3.2555E+01	1.1009E+00
$\alpha_2$	7.91E-04	2.48E-02	1.62E-02	7.82E-02	0.00E+00	8.3366E-01	3.2822E+01
$\alpha_3$	2.80E-07	7.94E-03	1.61E-03	3.77E-02	0.00E+00	2.6722E-01	3.3389E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9130680	0.9636200	0.9695110	0.9939910	1.0000000	4.9136E+01	1.8551E+00
$\alpha_2$	2.00E-03	2.41E-02	1.82E-02	6.63E-02	0.00E+00	1.2281E+00	4.9763E+01
$\alpha_3$	8.95E-06	7.93E-03	2.95E-03	3.27E-02	0.00E+00	4.0431E-01	5.0587E+01
$\alpha_4$	1.89E-08	4.37E-03	5.99E-04	2.19E-02	0.00E+00	2.2267E-01	5.0768E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9318350	0.9655480	0.9685320	0.9890570	1.0000000	9.9161E+01	3.5382E+00
$\alpha_2$	3.97E-03	2.06E-02	1.76E-02	4.76E-02	0.00E+00	2.1142E+00	1.0059E+02
$\alpha_3$	4.65E-04	9.52E-03	6.58E-03	2.86E-02	0.00E+00	9.7738E-01	1.0172E+02
$\alpha_4$	2.40E-06	3.65E-03	1.23E-03	1.55E-02	0.00E+00	3.7439E-01	1.0232E+02
$\alpha_5$	5.81E-21	7.04E-04	3.98E-07	4.08E-03	0.00E+00	7.2277E-02	1.0263E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9351640	0.9655550	0.9680290	0.9874920	1.0000000	1.1994E+02	4.2787E+00
$\alpha_2$	3.71E-03	1.80E-02	1.55E-02	4.10E-02	0.00E+00	2.2392E+00	1.2198E+02
$\alpha_3$	6.48E-04	9.19E-03	6.73E-03	2.62E-02	0.00E+00	1.1418E+00	1.2308E+02
$\alpha_4$	4.26E-05	4.77E-03	2.50E-03	1.72E-02	0.00E+00	5.9222E-01	1.2363E+02
$\alpha_5$	7.48E-09	1.79E-03	2.43E-04	8.96E-03	0.00E+00	2.2220E-01	1.2400E+02
$\alpha_6$	1.14E-18	6.70E-04	1.17E-06	3.91E-03	0.00E+00	8.3237E-02	1.2414E+02

ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

**Check Valves**

2009

**BWR High Pressure Coolant Injection/Reactor Core Isolation Cooling Check Valves****COMBINED HPCI AND RCIC CHECK VALVE FAIL TO CLOSE**

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>1-Beta</b>	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
<b>Beta</b>	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>Adj. Ind. Events</b>	3.00	3.00	3.00	3.00	3.00
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000

## 1.6 Strainers, Trash Racks, and Filters

### 1.6.1 Pooled Strainers (Non-ESW)

#### 1.6.1.1 GENERIC CLEAN DISCHARGE STRAINER PLUGS

System :	Chemical and volume control Component cooling water Control rod drive High pressure injection Standby liquid control
Component :	Strainer
Failure Mode :	No flow/plugged
Component Group :	Passive filter/strainer
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8386830	0.9593170	0.9828300	0.9999250	0.9939490	1.0246E+01	4.3452E-01
$\alpha_2$	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8979020	0.9640890	0.9736330	0.9976040	0.9939490	2.9555E+01	1.1009E+00
$\alpha_2$	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
$\alpha_3$	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9077330	0.9613450	0.9675780	0.9936050	0.9939490	4.6136E+01	1.8551E+00
$\alpha_2$	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
$\alpha_3$	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
$\alpha_4$	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

##### **CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9298110	0.9645110	0.9675740	0.9887220	0.9939490	9.6161E+01	3.5382E+00
$\alpha_2$	4.09E-03	2.12E-02	1.81E-02	4.90E-02	0.00E+00	2.1142E+00	9.7585E+01
$\alpha_3$	4.79E-04	9.80E-03	6.78E-03	2.95E-02	0.00E+00	9.7738E-01	9.8722E+01
$\alpha_4$	2.47E-06	3.76E-03	1.27E-03	1.59E-02	0.00E+00	3.7439E-01	9.9325E+01
$\alpha_5$	5.99E-21	7.25E-04	4.10E-07	4.20E-03	0.00E+00	7.2277E-02	9.9627E+01

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9335790	0.9647030	0.9672350	0.9871780	0.9939490	1.1694E+02	4.2787E+00
$\alpha_2$	3.80E-03	1.85E-02	1.59E-02	4.20E-02	0.00E+00	2.2392E+00	1.1898E+02
$\alpha_3$	6.64E-04	9.42E-03	6.89E-03	2.68E-02	0.00E+00	1.1418E+00	1.2008E+02
$\alpha_4$	4.37E-05	4.89E-03	2.56E-03	1.76E-02	0.00E+00	5.9222E-01	1.2063E+02
$\alpha_5$	7.67E-09	1.83E-03	2.49E-04	9.18E-03	0.00E+00	2.2220E-01	1.2100E+02
$\alpha_6$	1.16E-18	6.87E-04	1.20E-06	4.01E-03	0.00E+00	8.3237E-02	1.2114E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9939490	0.9939490	0.9939490	0.9939490	0.9939490
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	0.00	0.00	0.00	0.00	0.00
$N_1$	0.0000	0.0000	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000	0.0000	0.0000
$N_4$			0.0000	0.0000	0.0000
$N_5$				0.0000	0.0000
$N_6$					0.0000

## 1.6.2 Emergency Service Water Strainers

### 1.6.2.1 SERVICE WATER TSA FTO NON ENVIRONMENTAL SPAR:TSA-FO

System :	Normally operating service water Standby service water
Component :	Strainer
Failure Mode :	Fail to Operate (Open/Close)
Component Group :	Traveling Screen
Prox. Cause :	State of other component Design error or inadequacy Manufacturing error or inadequacy Construction/installation error or inadequacy Setpoint drift Ambient environmental stress Inadequate procedure Inadequate maintenance Age/Wear Accidental human action Human action procedure Other Internal environment Internal to component, piece-part
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 28.00

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9304640	0.9824180	0.9925600	0.9999570	0.9988850	2.5213E+01	4.5122E-01
$\alpha_2$	4.01E-05	1.76E-02	7.44E-03	6.95E-02	1.11E-03	4.5122E-01	2.5213E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9388740	0.9783290	0.9839890	0.9984260	0.9977730	5.1955E+01	1.1509E+00
$\alpha_2$	6.25E-04	1.66E-02	1.11E-02	5.16E-02	2.23E-03	8.8366E-01	5.2222E+01
$\alpha_3$	1.76E-07	5.03E-03	1.01E-03	2.39E-02	0.00E+00	2.6722E-01	5.2839E+01

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9407000	0.9749000	0.9788490	0.9955910	0.9966560	7.5936E+01	1.9551E+00
$\alpha_2$	1.64E-03	1.71E-02	1.31E-02	4.59E-02	3.34E-03	1.3281E+00	7.6563E+01
$\alpha_3$	5.83E-06	5.19E-03	1.92E-03	2.14E-02	0.00E+00	4.0431E-01	7.7487E+01
$\alpha_4$	1.23E-08	2.86E-03	3.91E-04	1.43E-02	0.00E+00	2.2267E-01	7.7668E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9470910	0.9730130	0.9752850	0.9911730	0.9957140	1.3334E+02	3.6982E+00
$\alpha_2$	3.46E-03	1.66E-02	1.43E-02	3.75E-02	4.20E-03	2.2709E+00	1.3477E+02
$\alpha_3$	3.52E-04	7.16E-03	4.95E-03	2.15E-02	8.84E-05	9.8068E-01	1.3606E+02
$\alpha_4$	1.79E-06	2.73E-03	9.19E-04	1.16E-02	0.00E+00	3.7439E-01	1.3666E+02
$\alpha_5$	4.35E-21	5.27E-04	2.98E-07	3.05E-03	0.00E+00	7.2277E-02	1.3697E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9493950	0.9728200	0.9747010	0.9898230	0.9948070	1.6146E+02	4.5111E+00
$\alpha_2$	3.38E-03	1.48E-02	1.29E-02	3.28E-02	5.00E-03	2.4631E+00	1.6351E+02
$\alpha_3$	4.95E-04	6.93E-03	5.08E-03	1.97E-02	1.88E-04	1.1502E+00	1.6482E+02
$\alpha_4$	3.19E-05	3.57E-03	1.87E-03	1.29E-02	2.23E-06	5.9232E-01	1.6538E+02
$\alpha_5$	5.59E-09	1.34E-03	1.81E-04	6.71E-03	0.00E+00	2.2220E-01	1.6575E+02
$\alpha_6$	8.49E-19	5.02E-04	8.77E-07	2.93E-03	0.00E+00	8.3237E-02	1.6589E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9988850	0.9977730	0.9966560	0.9957140	0.9948070
$\alpha_2$	1.11E-03	2.23E-03	3.34E-03	4.20E-03	5.00E-03
$\alpha_3$		0.00E+00	0.00E+00	8.84E-05	1.88E-04
$\alpha_4$			0.00E+00	0.00E+00	2.23E-06
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>1-Beta</b>	9.99E-01	9.98E-01	9.97E-01	9.96E-01	9.95E-01
<b>Beta</b>	1.11E-03	2.23E-03	3.34E-03	4.29E-03	5.19E-03
<b>Gamma</b>		0.00E+00	0.00E+00	2.06E-02	3.66E-02
<b>Delta</b>			0.00E+00	0.00E+00	1.18E-02
<b>Epsilon</b>				0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>Adj. Ind. Events</b>	14.00	21.00	28.00	35.00	42.00
<b>N<sub>1</sub></b>	0.9667	1.4000	1.8000	2.1750	2.5230
<b>N<sub>2</sub></b>	0.0167	0.0500	0.1000	0.1567	0.2239
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0033	0.0084
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0001
<b>N<sub>5</sub></b>				0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000

### 1.6.2.2 SERVICE WATER TSA PLUG NON ENVIRONMENTAL SPAR:TSAP-G

<b>System :</b>	Normally operating service water Standby service water
<b>Component :</b>	Strainer
<b>Failure Mode :</b>	No flow/plugged
<b>Component Group :</b>	Traveling Screen
<b>Prox. Cause :</b>	State of other component Design error or inadequacy Manufacturing error or inadequacy Construction/installation error or inadequacy Setpoint drift Ambient environmental stress Inadequate procedure Inadequate maintenance Age/Wear Accidental human action Human action procedure Other Internal environment Internal to component, piece-part
<b>Start Date :</b>	1997/01/01
<b>Data Version :</b>	2009/12/31

Total Number of Independent Failure Events: 1.00

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8522320	0.9628000	0.9843830	0.9999320	1.0000000	1.1246E+01	4.3452E-01
$\alpha_2$	7.00E-05	3.72E-02	1.56E-02	1.48E-01	0.00E+00	4.3452E-01	1.1246E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9010680	0.9652240	0.9744830	0.9976820	1.0000000	3.0555E+01	1.1009E+00
$\alpha_2$	8.43E-04	2.63E-02	1.72E-02	8.30E-02	0.00E+00	8.3366E-01	3.0822E+01
$\alpha_3$	2.98E-07	8.44E-03	1.71E-03	4.00E-02	0.00E+00	2.6722E-01	3.1389E+01

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9095820	0.9621340	0.9682530	0.9937390	1.0000000	4.7136E+01	1.8551E+00
$\alpha_2$	2.09E-03	2.51E-02	1.89E-02	6.90E-02	0.00E+00	1.2281E+00	4.7763E+01
$\alpha_3$	9.32E-06	8.25E-03	3.07E-03	3.41E-02	0.00E+00	4.0431E-01	4.8587E+01
$\alpha_4$	1.97E-08	4.55E-03	6.24E-04	2.28E-02	0.00E+00	2.2267E-01	4.8768E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9304990	0.9648630	0.9678980	0.9888360	1.0000000	9.7161E+01	3.5382E+00
$\alpha_2$	4.05E-03	2.10E-02	1.79E-02	4.85E-02	0.00E+00	2.1142E+00	9.8585E+01
$\alpha_3$	4.74E-04	9.71E-03	6.71E-03	2.92E-02	0.00E+00	9.7738E-01	9.9722E+01
$\alpha_4$	2.45E-06	3.72E-03	1.25E-03	1.58E-02	0.00E+00	3.7439E-01	1.0032E+02
$\alpha_5$	5.93E-21	7.18E-04	4.06E-07	4.16E-03	0.00E+00	7.2277E-02	1.0063E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9341160	0.9649920	0.9674990	0.9872840	1.0000000	1.1794E+02	4.2787E+00
$\alpha_2$	3.77E-03	1.83E-02	1.58E-02	4.16E-02	0.00E+00	2.2392E+00	1.1998E+02
$\alpha_3$	6.58E-04	9.34E-03	6.84E-03	2.66E-02	0.00E+00	1.1418E+00	1.2108E+02
$\alpha_4$	4.33E-05	4.85E-03	2.54E-03	1.75E-02	0.00E+00	5.9222E-01	1.2163E+02
$\alpha_5$	7.60E-09	1.82E-03	2.47E-04	9.11E-03	0.00E+00	2.2220E-01	1.2200E+02
$\alpha_6$	1.15E-18	6.81E-04	1.19E-06	3.98E-03	0.00E+00	8.3237E-02	1.2214E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>1-Beta</b>	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
<b>Beta</b>	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>Adj. Ind. Events</b>	1.00	1.00	1.00	1.00	1.00
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000

### 1.6.2.3 SERVICE WATER STRAINER PLUG NON ENVIRONMENTAL SPAR:STR-PG

<b>System :</b>	Normally operating service water Standby service water
<b>Component :</b>	Strainer
<b>Failure Mode :</b>	High dP across filter No flow/plugged
<b>Component Group :</b>	Self-Cleaning filter/strainer
<b>Prox. Cause :</b>	State of other component Design error or inadequacy Manufacturing error or inadequacy Construction/installation error or inadequacy Setpoint drift Ambient environmental stress Inadequate procedure Inadequate maintenance Age/Wear Accidental human action Human action procedure Other Internal environment Internal to component, piece-part
<b>Start Date :</b>	1997/01/01
<b>Data Version :</b>	2009/12/31

Total Number of Independent Failure Events: 37.00

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9633370	0.9908870	0.9963330	0.9999820	1.0000000	4.7246E+01	4.3452E-01
$\alpha_2$	1.63E-05	9.11E-03	3.67E-03	3.67E-02	0.00E+00	4.3452E-01	4.7246E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9532560	0.9837280	0.9881890	0.9989340	1.0000000	6.6555E+01	1.1009E+00
$\alpha_2$	3.88E-04	1.23E-02	7.96E-03	3.91E-02	0.00E+00	8.3366E-01	6.6822E+01
$\alpha_3$	1.38E-07	3.95E-03	7.93E-04	1.87E-02	0.00E+00	2.6722E-01	6.7389E+01

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9474900	0.9781730	0.9818070	0.9964330	1.0000000	8.3136E+01	1.8551E+00
$\alpha_2$	1.19E-03	1.44E-02	1.09E-02	4.00E-02	0.00E+00	1.2281E+00	8.3763E+01
$\alpha_3$	5.34E-06	4.76E-03	1.76E-03	1.97E-02	0.00E+00	4.0431E-01	8.4587E+01
$\alpha_4$	1.13E-08	2.62E-03	3.58E-04	1.31E-02	0.00E+00	2.2267E-01	8.4768E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9486250	0.9741160	0.9763980	0.9918180	1.0000000	1.3316E+02	3.5382E+00
$\alpha_2$	2.97E-03	1.55E-02	1.32E-02	3.58E-02	0.00E+00	2.1142E+00	1.3458E+02
$\alpha_3$	3.49E-04	7.15E-03	4.93E-03	2.15E-02	0.00E+00	9.7738E-01	1.3572E+02
$\alpha_4$	1.80E-06	2.74E-03	9.22E-04	1.16E-02	0.00E+00	3.7439E-01	1.3632E+02
$\alpha_5$	4.36E-21	5.29E-04	2.99E-07	3.06E-03	0.00E+00	7.2277E-02	1.3663E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9489700	0.9729570	0.9749300	0.9902120	1.0000000	1.5394E+02	4.2787E+00
$\alpha_2$	2.90E-03	1.42E-02	1.22E-02	3.22E-02	0.00E+00	2.2392E+00	1.5598E+02
$\alpha_3$	5.07E-04	7.22E-03	5.27E-03	2.06E-02	0.00E+00	1.1418E+00	1.5708E+02
$\alpha_4$	3.34E-05	3.74E-03	1.96E-03	1.35E-02	0.00E+00	5.9222E-01	1.5763E+02
$\alpha_5$	5.87E-09	1.40E-03	1.90E-04	7.04E-03	0.00E+00	2.2220E-01	1.5800E+02
$\alpha_6$	8.91E-19	5.26E-04	9.20E-07	3.07E-03	0.00E+00	8.3237E-02	1.5814E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>1-Beta</b>	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
<b>Beta</b>	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>Adj. Ind. Events</b>	37.00	37.00	37.00	37.00	37.00
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000

### 1.6.3 Pooled Sump Strainers

#### 1.6.3.1 SUMP SUCTION PLUGGED

System :

Containment spray recirculation  
 High pressure core spray  
 High pressure coolant injection  
 Low pressure core spray  
 Reactor core isolation

Residual Heat Removal (LCI in BWRs, LPI in PWRs)

Component :

Strainer

Failure Mode :

High dP across filter

No flow/plugged

Component Group :

Sump Strainer Filter

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 1.50

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8581890	0.9643270	0.9850590	0.99999350	1.0000000	1.1746E+01	4.3452E-01
$\alpha_2$	6.69E-05	3.57E-02	1.49E-02	1.42E-01	0.00E+00	4.3452E-01	1.1746E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9025780	0.9657640	0.9748880	0.9977200	1.0000000	3.1055E+01	1.1009E+00
$\alpha_2$	8.29E-04	2.59E-02	1.69E-02	8.18E-02	0.00E+00	8.3366E-01	3.1322E+01
$\alpha_3$	2.93E-07	8.31E-03	1.69E-03	3.94E-02	0.00E+00	2.6722E-01	3.1889E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9104790	0.9625170	0.9685780	0.9938040	1.0000000	4.7636E+01	1.8551E+00
$\alpha_2$	2.06E-03	2.48E-02	1.87E-02	6.83E-02	0.00E+00	1.2281E+00	4.8263E+01
$\alpha_3$	9.23E-06	8.17E-03	3.04E-03	3.37E-02	0.00E+00	4.0431E-01	4.9087E+01
$\alpha_4$	1.95E-08	4.50E-03	6.18E-04	2.25E-02	0.00E+00	2.2267E-01	4.9268E+01

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9308380	0.9650370	0.9680620	0.9888920	1.0000000	9.7661E+01	3.5382E+00
$\alpha_2$	4.03E-03	2.09E-02	1.78E-02	4.83E-02	0.00E+00	2.1142E+00	9.9085E+01
$\alpha_3$	4.72E-04	9.66E-03	6.68E-03	2.90E-02	0.00E+00	9.7738E-01	1.0022E+02
$\alpha_4$	2.43E-06	3.70E-03	1.25E-03	1.57E-02	0.00E+00	3.7439E-01	1.0082E+02
$\alpha_5$	5.90E-21	7.14E-04	4.04E-07	4.14E-03	0.00E+00	7.2277E-02	1.0113E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9343810	0.9651340	0.9676320	0.9873370	1.0000000	1.1844E+02	4.2787E+00
$\alpha_2$	3.75E-03	1.82E-02	1.57E-02	4.15E-02	0.00E+00	2.2392E+00	1.2048E+02
$\alpha_3$	6.56E-04	9.30E-03	6.81E-03	2.65E-02	0.00E+00	1.1418E+00	1.2158E+02
$\alpha_4$	4.32E-05	4.83E-03	2.53E-03	1.74E-02	0.00E+00	5.9222E-01	1.2213E+02
$\alpha_5$	7.57E-09	1.81E-03	2.46E-04	9.07E-03	0.00E+00	2.2220E-01	1.2250E+02
$\alpha_6$	1.15E-18	6.78E-04	1.19E-06	3.96E-03	0.00E+00	8.3237E-02	1.2264E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	1.50	1.50	1.50	1.50	1.50
$N_1$	0.0000	0.0000	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000	0.0000	0.0000
$N_4$			0.0000	0.0000	0.0000
$N_5$				0.0000	0.0000
$N_6$					0.0000

## 1.6.4 PWR Containment Sump Strainers

### 1.6.4.1 CONTAINMENT SPRAY SUMP STRAINER PLUG STR-PG

System :	Containment spray recirculation
Component :	Strainer
Failure Mode :	High dP across filter No flow/plugged
Component Group :	Sump Strainer Filter
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8386830	0.9593170	0.9828300	0.9999250	1.0000000	1.0246E+01	4.3452E-01
$\alpha_2$	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2
$\alpha_1$	1.0000000
$\alpha_2$	0.00E+00

MGL Parameter	CCCG=2
1-Beta	0.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	0.00
$N_1$	0.0000
$N_2$	0.0000

## 1.6.5 BWR Suppression Pool Strainers

### 1.6.5.1 BWR RHR SUMP STRAINER PLUG

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Strainer
Failure Mode :	High dP across filter No flow/plugged
Component Group :	Sump Strainer Filter
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

### ALPHA FACTOR DISTRIBUTIONS

#### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8386830	0.9593170	0.9828300	0.9999250	1.0000000	1.0246E+01	4.3452E-01
$\alpha_2$	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

#### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8979020	0.9640890	0.9736330	0.9976040	1.0000000	2.9555E+01	1.1009E+00
$\alpha_2$	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
$\alpha_3$	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

#### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9077330	0.9613450	0.9675780	0.9936050	1.0000000	4.6136E+01	1.8551E+00
$\alpha_2$	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
$\alpha_3$	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
$\alpha_4$	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

#### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9298110	0.9645110	0.9675740	0.9887220	1.0000000	9.6161E+01	3.5382E+00
$\alpha_2$	4.09E-03	2.12E-02	1.81E-02	4.90E-02	0.00E+00	2.1142E+00	9.7585E+01
$\alpha_3$	4.79E-04	9.80E-03	6.78E-03	2.95E-02	0.00E+00	9.7738E-01	9.8722E+01
$\alpha_4$	2.47E-06	3.76E-03	1.27E-03	1.59E-02	0.00E+00	3.7439E-01	9.9325E+01
$\alpha_5$	5.99E-21	7.25E-04	4.10E-07	4.20E-03	0.00E+00	7.2277E-02	9.9627E+01

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9335790	0.9647030	0.9672350	0.9871780	1.0000000	1.1694E+02	4.2787E+00
$\alpha_2$	3.80E-03	1.85E-02	1.59E-02	4.20E-02	0.00E+00	2.2392E+00	1.1898E+02
$\alpha_3$	6.64E-04	9.42E-03	6.89E-03	2.68E-02	0.00E+00	1.1418E+00	1.2008E+02
$\alpha_4$	4.37E-05	4.89E-03	2.56E-03	1.76E-02	0.00E+00	5.9222E-01	1.2063E+02
$\alpha_5$	7.67E-09	1.83E-03	2.49E-04	9.18E-03	0.00E+00	2.2220E-01	1.2100E+02
$\alpha_6$	1.16E-18	6.87E-04	1.20E-06	4.01E-03	0.00E+00	8.3237E-02	1.2114E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	0.00	0.00	0.00	0.00	0.00
$N_1$	0.0000	0.0000	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000	0.0000	0.0000
$N_4$			0.0000	0.0000	0.0000
$N_5$				0.0000	0.0000
$N_6$					0.0000

## 1.6.6 Extreme Environmental Event CCF Distributions

### 1.6.6.1 CIRCULATING WATER TSA EXTREME ENVIRONMENTAL PLUG

System :	Circulating water system
Component :	Strainer
Failure Mode :	No flow/plugged
Component Group :	Traveling Screen
Prox. Cause :	Extreme environmental stress
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 22.00

Total Number of Common-Cause Failure Events: 17

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.5941800	0.7212010	0.7252630	0.8343090	0.6231850	2.6414E+01	1.0211E+01
$\alpha_2$	1.66E-01	2.79E-01	2.75E-01	4.06E-01	3.77E-01	1.0211E+01	2.6414E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.6957890	0.7858650	0.7889510	0.8653820	0.6114540	4.8709E+01	1.3272E+01
$\alpha_2$	4.29E-02	9.56E-02	9.13E-02	1.63E-01	1.63E-01	5.9266E+00	5.6055E+01
$\alpha_3$	5.92E-02	1.19E-01	1.14E-01	1.92E-01	2.26E-01	7.3458E+00	5.4636E+01

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.7345000	0.8083050	0.8107290	0.8738180	0.6095610	6.8662E+01	1.6284E+01
$\alpha_2$	3.56E-02	7.64E-02	7.31E-02	1.29E-01	1.42E-01	6.4924E+00	7.8453E+01
$\alpha_3$	2.91E-02	6.69E-02	6.35E-02	1.16E-01	1.43E-01	5.6853E+00	7.9260E+01
$\alpha_4$	1.72E-02	4.83E-02	4.48E-02	9.15E-02	1.05E-01	4.1060E+00	8.0840E+01

##### **CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8161210	0.8657800	0.8675010	0.9095760	0.6331790	1.2296E+02	1.9062E+01
$\alpha_2$	1.82E-02	4.15E-02	3.94E-02	7.21E-02	8.93E-02	5.8940E+00	1.3613E+02
$\alpha_3$	2.13E-02	4.62E-02	4.40E-02	7.82E-02	1.32E-01	6.5548E+00	1.3547E+02
$\alpha_4$	1.26E-02	3.29E-02	3.07E-02	6.05E-02	1.01E-01	4.6661E+00	1.3736E+02
$\alpha_5$	2.38E-03	1.37E-02	1.15E-02	3.26E-02	4.43E-02	1.9473E+00	1.4007E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8364060	0.8798650	0.8813680	0.9181990	0.6637240	1.4852E+02	2.0279E+01
$\alpha_2$	9.24E-03	2.55E-02	2.36E-02	4.80E-02	4.33E-02	4.2997E+00	1.6450E+02
$\alpha_3$	1.73E-02	3.80E-02	3.61E-02	6.48E-02	1.11E-01	6.4077E+00	1.6239E+02
$\alpha_4$	1.40E-02	3.30E-02	3.12E-02	5.83E-02	1.05E-01	5.5783E+00	1.6322E+02
$\alpha_5$	4.81E-03	1.76E-02	1.57E-02	3.68E-02	5.78E-02	2.9722E+00	1.6583E+02
$\alpha_6$	3.28E-04	6.05E-03	4.24E-03	1.79E-02	1.97E-02	1.0207E+00	1.6778E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.6231850	0.6114540	0.6095610	0.6331790	0.6637240
$\alpha_2$	3.77E-01	1.63E-01	1.42E-01	8.93E-02	4.33E-02
$\alpha_3$		2.26E-01	1.43E-01	1.32E-01	1.11E-01
$\alpha_4$			1.05E-01	1.01E-01	1.05E-01
$\alpha_5$				4.43E-02	5.78E-02
$\alpha_6$					1.97E-02

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	6.23E-01	6.11E-01	6.10E-01	6.33E-01	6.64E-01
Beta	3.77E-01	3.89E-01	3.90E-01	3.67E-01	3.36E-01
Gamma		5.82E-01	6.35E-01	7.57E-01	8.71E-01
Delta			4.24E-01	5.25E-01	6.22E-01
Epsilon				3.04E-01	4.25E-01
Mu					2.54E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	10.53	15.79	21.05	26.32	31.58
$N_1$	5.6381	3.3643	1.4762	0.4762	0.0000
$N_2$	9.7762	5.0929	5.2643	3.7798	2.0605
$N_3$		7.0786	5.2810	5.5774	5.2659
$N_4$			3.8833	4.2917	4.9861
$N_5$				1.8750	2.7500
$N_6$					0.9375

### 1.6.6.2 CIRCULATING WATER TSA NON ENVIRONMENTAL PLUG SPAR:CWS-PG

System :	Circulating water system
Component :	Strainer
Failure Mode :	No flow/plugged
Component Group :	Traveling Screen
Prox. Cause :	State of other component Design error or inadequacy Manufacturing error or inadequacy Construction/installation error or inadequacy Setpoint drift Ambient environmental stress Inadequate procedure Inadequate maintenance Age/Wear Accidental human action Human action procedure Other Internal environment Internal to component, piece-part Unknown
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 6.00

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8959650	0.9739500	0.9892430	0.9999480	1.0000000	1.6246E+01	4.3452E-01
$\alpha_2$	4.81E-05	2.60E-02	1.08E-02	1.04E-01	0.00E+00	4.3452E-01	1.6246E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9143470	0.9699670	0.9780280	0.9980130	1.0000000	3.5555E+01	1.1009E+00
$\alpha_2$	7.25E-04	2.27E-02	1.48E-02	7.18E-02	0.00E+00	8.3366E-01	3.5822E+01
$\alpha_3$	2.56E-07	7.29E-03	1.48E-03	3.46E-02	0.00E+00	2.6722E-01	3.6389E+01

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9178250	0.9656410	0.9712250	0.9943340	1.0000000	5.2136E+01	1.8551E+00
$\alpha_2$	1.89E-03	2.27E-02	1.72E-02	6.27E-02	0.00E+00	1.2281E+00	5.2763E+01
$\alpha_3$	8.45E-06	7.49E-03	2.78E-03	3.09E-02	0.00E+00	4.0431E-01	5.3587E+01
$\alpha_4$	1.78E-08	4.12E-03	5.66E-04	2.07E-02	0.00E+00	2.2267E-01	5.3768E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9337450	0.9665250	0.9694270	0.9893730	1.0000000	1.0216E+02	3.5382E+00
$\alpha_2$	3.85E-03	2.00E-02	1.71E-02	4.62E-02	0.00E+00	2.1142E+00	1.0358E+02
$\alpha_3$	4.52E-04	9.25E-03	6.39E-03	2.78E-02	0.00E+00	9.7738E-01	1.0472E+02
$\alpha_4$	2.33E-06	3.54E-03	1.19E-03	1.50E-02	0.00E+00	3.7439E-01	1.0532E+02
$\alpha_5$	5.65E-21	6.84E-04	3.87E-07	3.96E-03	0.00E+00	7.2277E-02	1.0563E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9366750	0.9663680	0.9687880	0.9877920	1.0000000	1.2294E+02	4.2787E+00
$\alpha_2$	3.62E-03	1.76E-02	1.51E-02	4.00E-02	0.00E+00	2.2392E+00	1.2498E+02
$\alpha_3$	6.32E-04	8.98E-03	6.57E-03	2.55E-02	0.00E+00	1.1418E+00	1.2608E+02
$\alpha_4$	4.16E-05	4.66E-03	2.44E-03	1.68E-02	0.00E+00	5.9222E-01	1.2663E+02
$\alpha_5$	7.30E-09	1.75E-03	2.37E-04	8.75E-03	0.00E+00	2.2220E-01	1.2700E+02
$\alpha_6$	1.11E-18	6.54E-04	1.14E-06	3.82E-03	0.00E+00	8.3237E-02	1.2714E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>1-Beta</b>	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
<b>Beta</b>	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
<b>Adj. Ind. Events</b>	6.00	6.00	6.00	6.00	6.00
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000

### 1.6.6.3 SERVICE WATER STRAINER PLUG ENVIRONMENTAL SPAR:STR-EE-PG

<b>System :</b>	Normally operating service water
<b>Component :</b>	Standby service water
<b>Failure Mode :</b>	Strainer
<b>Component Group :</b>	High dP across filter
<b>Prox. Cause :</b>	No flow/plugged
<b>Start Date :</b>	Self-Cleaning filter/strainer
<b>Data Version :</b>	Extreme environmental stress
	1997/01/01
	2009/12/31

Total Number of Independent Failure Events: 21.50

Total Number of Common-Cause Failure Events: 4

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8709670	0.9499780	0.9600910	0.9943320	0.9444340	2.7243E+01	1.4345E+00
$\alpha_2$	5.67E-03	5.00E-02	3.99E-02	1.29E-01	5.56E-02	1.4345E+00	2.7243E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8799610	0.9392060	0.9443380	0.9808800	0.9096790	5.3055E+01	3.4342E+00
$\alpha_2$	1.34E-02	5.02E-02	4.49E-02	1.05E-01	7.74E-02	2.8337E+00	5.3656E+01
$\alpha_3$	1.02E-04	1.06E-02	5.66E-03	3.80E-02	1.29E-02	6.0052E-01	5.5889E+01

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8964060	0.9435120	0.9471170	0.9783030	0.9179890	7.6917E+01	4.6050E+00
$\alpha_2$	8.26E-03	3.30E-02	2.92E-02	7.05E-02	4.35E-02	2.6864E+00	7.8836E+01
$\alpha_3$	2.09E-03	1.81E-02	1.43E-02	4.70E-02	3.19E-02	1.4737E+00	8.0048E+01
$\alpha_4$	1.12E-05	5.46E-03	2.24E-03	2.18E-02	6.63E-03	4.4487E-01	8.1077E+01

##### **CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9199240	0.9526280	0.9547810	0.9779870	0.9229340	1.3297E+02	6.6123E+00
$\alpha_2$	6.95E-03	2.34E-02	2.12E-02	4.75E-02	2.89E-02	3.2681E+00	1.3631E+02
$\alpha_3$	2.86E-03	1.50E-02	1.28E-02	3.49E-02	2.81E-02	2.0978E+00	1.3748E+02
$\alpha_4$	4.04E-04	7.35E-03	5.17E-03	2.17E-02	1.63E-02	1.0260E+00	1.3856E+02
$\alpha_5$	5.95E-09	1.58E-03	2.10E-04	7.93E-03	3.71E-03	2.2038E-01	1.3936E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9257860	0.9547680	0.9565620	0.9776260	0.9292550	1.6080E+02	7.6179E+00
$\alpha_2$	5.62E-03	1.92E-02	1.73E-02	3.91E-02	2.10E-02	3.2302E+00	1.6519E+02
$\alpha_3$	2.45E-03	1.27E-02	1.08E-02	2.93E-02	2.10E-02	2.1309E+00	1.6629E+02
$\alpha_4$	9.13E-04	8.45E-03	6.60E-03	2.23E-02	1.76E-02	1.4235E+00	1.6699E+02
$\alpha_5$	5.13E-05	3.87E-03	2.16E-03	1.35E-02	9.09E-03	6.5130E-01	1.6777E+02
$\alpha_6$	2.74E-10	1.08E-03	8.63E-05	5.71E-03	2.09E-03	1.8204E-01	1.6824E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9444340	0.9096790	0.9179890	0.9229340	0.9292550
$\alpha_2$	5.56E-02	7.74E-02	4.35E-02	2.89E-02	2.10E-02
$\alpha_3$		1.29E-02	3.19E-02	2.81E-02	2.10E-02
$\alpha_4$			6.63E-03	1.63E-02	1.76E-02
$\alpha_5$				3.71E-03	9.09E-03
$\alpha_6$					2.09E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.44E-01	9.10E-01	9.18E-01	9.23E-01	9.29E-01
Beta	5.56E-02	9.03E-02	8.20E-02	7.71E-02	7.07E-02
Gamma		1.43E-01	4.70E-01	6.25E-01	7.03E-01
Delta			1.72E-01	4.16E-01	5.79E-01
Epsilon				1.85E-01	3.88E-01
Mu					1.87E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	14.33	21.50	28.67	35.83	43.00
$N_1$	2.6667	2.0000	2.1111	0.9838	0.8623
$N_2$	1.0000	2.0000	1.4583	1.1539	0.9910
$N_3$		0.3333	1.0694	1.1204	0.9891
$N_4$			0.2222	0.6516	0.8313
$N_5$				0.1481	0.4291
$N_6$					0.0988

#### 1.6.6.4 SERVICE WATER TSA PLUG ENVIRONMENTAL SPAR:TS-EE-PG

System :

Circulating water system  
 Normally operating service water  
 Standby service water

Component :

Strainer

Failure Mode :

No flow/plugged

Component Group :

Traveling Screen

Prox. Cause :

Extreme environmental stress

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 27.00

Total Number of Common-Cause Failure Events: 18

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.6195240	0.7394500	0.7435090	0.8454920	0.6584530	2.9334E+01	1.0336E+01
$\alpha_2$	1.55E-01	2.61E-01	2.56E-01	3.80E-01	3.42E-01	1.0336E+01	2.9334E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.7096980	0.7953870	0.7983680	0.8708970	0.6506720	5.2808E+01	1.3585E+01
$\alpha_2$	4.29E-02	9.35E-02	8.94E-02	1.58E-01	1.50E-01	6.2078E+00	6.0185E+01
$\alpha_3$	5.54E-02	1.11E-01	1.07E-01	1.80E-01	1.99E-01	7.3770E+00	5.9016E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.7443840	0.8148940	0.8172170	0.8774700	0.6502190	7.3887E+01	1.6784E+01
$\alpha_2$	3.62E-02	7.57E-02	7.26E-02	1.26E-01	1.32E-01	6.8674E+00	8.3803E+01
$\alpha_3$	2.81E-02	6.41E-02	6.09E-02	1.11E-01	1.27E-01	5.8103E+00	8.4860E+01
$\alpha_4$	1.61E-02	4.53E-02	4.20E-02	8.58E-02	9.10E-02	4.1060E+00	8.6565E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8197410	0.8678780	0.8695230	0.9103950	0.6724880	1.2932E+02	1.9687E+01
$\alpha_2$	1.90E-02	4.21E-02	4.00E-02	7.21E-02	8.43E-02	6.2690E+00	1.4274E+02
$\alpha_3$	2.13E-02	4.54E-02	4.34E-02	7.64E-02	1.17E-01	6.7631E+00	1.4224E+02
$\alpha_4$	1.22E-02	3.16E-02	2.95E-02	5.81E-02	8.79E-02	4.7077E+00	1.4430E+02
$\alpha_5$	2.26E-03	1.31E-02	1.10E-02	3.11E-02	3.80E-02	1.9473E+00	1.4706E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8391590	0.8813440	0.8827820	0.9186200	0.7003500	1.5604E+02	2.1008E+01
$\alpha_2$	1.00E-02	2.63E-02	2.45E-02	4.86E-02	4.33E-02	4.6539E+00	1.7239E+02
$\alpha_3$	1.75E-02	3.77E-02	3.60E-02	6.38E-02	9.90E-02	6.6716E+00	1.7038E+02
$\alpha_4$	1.37E-02	3.21E-02	3.03E-02	5.64E-02	9.11E-02	5.6755E+00	1.7137E+02
$\alpha_5$	4.62E-03	1.69E-02	1.51E-02	3.52E-02	4.95E-02	2.9861E+00	1.7406E+02
$\alpha_6$	3.13E-04	5.77E-03	4.04E-03	1.71E-02	1.68E-02	1.0207E+00	1.7603E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.6584530	0.6506720	0.6502190	0.6724880	0.7003500
$\alpha_2$	3.42E-01	1.50E-01	1.32E-01	8.43E-02	4.33E-02
$\alpha_3$		1.99E-01	1.27E-01	1.17E-01	9.90E-02
$\alpha_4$			9.10E-02	8.79E-02	9.11E-02
$\alpha_5$				3.80E-02	4.95E-02
$\alpha_6$					1.68E-02

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	6.58E-01	6.51E-01	6.50E-01	6.72E-01	7.00E-01
Beta	3.42E-01	3.49E-01	3.50E-01	3.28E-01	3.00E-01
Gamma		5.70E-01	6.22E-01	7.43E-01	8.56E-01
Delta			4.18E-01	5.18E-01	6.14E-01
Epsilon				3.02E-01	4.21E-01
Mu					2.53E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	12.95	19.42	25.90	32.37	38.85
$N_1$	6.1381	3.8330	1.8512	0.7887	0.2500
$N_2$	9.9012	5.3741	5.6393	4.1548	2.4147
$N_3$		7.1098	5.4060	5.7857	5.5298
$N_4$			3.8833	4.3333	5.0833
$N_5$				1.8750	2.7639
$N_6$					0.9375

## 1.7 Heat Exchangers

### 1.7.1 PWR HEAT EXCHANGER LOSS OF HEAT TRANSFER

#### 1.7.1.1 PWR RHR HEAT EXCHANGER PLUG/LOSS OF HEAT TRANSFER

System :	Residual Heat Removal (LCI in BWRs, LPI in PWRs)
Component :	Heat Exchanger
Failure Mode :	High dP across filter Loss of heat transfer capabilities in heat exchangers No flow/plugged
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8636860	0.9657330	0.9856730	0.9999380	1.0000000	1.2246E+01	4.3452E-01
$\alpha_2$	6.41E-05	3.43E-02	1.43E-02	1.36E-01	0.00E+00	4.3452E-01	1.2246E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9040420	0.9662880	0.9752810	0.9977560	1.0000000	3.1555E+01	1.1009E+00
$\alpha_2$	8.16E-04	2.55E-02	1.67E-02	8.05E-02	0.00E+00	8.3366E-01	3.1822E+01
$\alpha_3$	2.88E-07	8.18E-03	1.66E-03	3.88E-02	0.00E+00	2.6722E-01	3.2389E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9113590	0.9628920	0.9688970	0.9938680	1.0000000	4.8136E+01	1.8551E+00
$\alpha_2$	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
$\alpha_3$	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
$\alpha_4$	1.93E-08	4.45E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9768E+01

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

Pooled Heat Exchanger Plugged or Failure to Transfer Heat

HEAT EXCHANGER PLUGGED ALL SYSTEMS NON ENVIRO SPAR:HTX-PG

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	2.00	2.00	2.00
N <sub>1</sub>	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000
N <sub>4</sub>			0.0000

## 1.7.2 Pooled Heat Exchanger Plugged or Failure to Transfer Heat

### 1.7.2.1 HEAT EXCHANGER PLUGGED ALL SYSTEMS NON ENVIRO SPAR:HTX-PG

Component :	Heat Exchanger
Failure Mode :	Loss of heat transfer capabilities in heat exchangers
Prox. Cause :	State of other component Design error or inadequacy Manufacturing error or inadequacy Construction/installation error or inadequacy Setpoint drift Ambient environmental stress Inadequate procedure Inadequate maintenance Age/Wear Accidental human action Human action procedure Other Internal environment Internal to component, piece-part Unknown
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 17.60

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8960240	0.9738850	0.9891220	0.9999450	0.9993930	1.6342E+01	4.3822E-01
$\alpha_2$	5.07E-05	2.61E-02	1.09E-02	1.04E-01	6.07E-04	4.3822E-01	1.6342E+01

**Containment Spray Heat Exchanger****CONTAINMENT SPRAY HTX LOSS OF HEAT TRANSFER****CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9205160	0.9720670	0.9795230	0.9981150	0.9988290	3.8683E+01	1.1116E+00
$\alpha_2$	7.01E-04	2.12E-02	1.39E-02	6.68E-02	1.16E-03	8.4426E-01	3.8950E+01
$\alpha_3$	2.37E-07	6.72E-03	1.36E-03	3.19E-02	1.09E-05	2.6732E-01	3.9527E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9255750	0.9688180	0.9738650	0.9947920	0.9982750	5.8290E+01	1.8761E+00
$\alpha_2$	1.78E-03	2.08E-02	1.57E-02	5.69E-02	1.68E-03	1.2486E+00	5.8917E+01
$\alpha_3$	7.64E-06	6.73E-03	2.50E-03	2.78E-02	4.11E-05	4.0481E-01	5.9761E+01
$\alpha_4$	1.60E-08	3.70E-03	5.07E-04	1.85E-02	0.00E+00	2.2267E-01	5.9943E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9993930	0.9988290	0.9982750
$\alpha_2$	6.07E-04	1.16E-03	1.68E-03
$\alpha_3$		1.09E-05	4.11E-05
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.99E-01	9.99E-01	9.98E-01
Beta	6.07E-04	1.17E-03	1.72E-03
Gamma		9.35E-03	2.38E-02
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	5.87	8.80	11.73
$N_1$	0.2260	0.3284	0.4242
$N_2$	0.0037	0.0106	0.0205
$N_3$		0.0001	0.0005
$N_4$			0.0000

**1.7.3 Containment Spray Heat Exchanger****1.7.3.1 CONTAINMENT SPRAY HTX LOSS OF HEAT TRANSFER**

System :	Containment spray recirculation
Component :	Heat Exchanger
Failure Mode :	Loss of heat transfer capabilities in heat exchangers No flow/plugged
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 2.50

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8687700	0.9670330	0.9862440	0.9999400	1.0000000	1.2746E+01	4.3452E-01
$\alpha_2$	6.16E-05	3.30E-02	1.38E-02	1.31E-01	0.00E+00	4.3452E-01	1.2746E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2
$\alpha_1$	1.0000000
$\alpha_2$	0.00E+00

MGL Parameter	CCCG=2
1-Beta	1.00E+00
Beta	0.00E+00

Avg. Impact Vector	CCCG=2
Adj. Ind. Events	2.50
$N_1$	0.0000
$N_2$	0.0000

**1.7.4 BWR Residual Heat Removal Heat Exchanger****1.7.4.1 BWR RHR HEAT EXCHANGER LOSS OF HEAT TRANSFER CAPABILITIES**

System : Residual Heat Removal (LCI in BWRs, LPI in PWRs)

Component : Heat Exchanger

Failure Mode : High dP across filter

Loss of heat transfer capabilities in heat exchangers

No flow/plugged

Plant Type : BWR

Start Date : 1997/01/01

Data Version : 2009/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8636860	0.9657330	0.9856730	0.9999380	1.0000000	1.2246E+01	4.3452E-01
$\alpha_2$	6.41E-05	3.43E-02	1.43E-02	1.36E-01	0.00E+00	4.3452E-01	1.2246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9040420	0.9662880	0.9752810	0.9977560	1.0000000	3.1555E+01	1.1009E+00
$\alpha_2$	8.16E-04	2.55E-02	1.67E-02	8.05E-02	0.00E+00	8.3366E-01	3.1822E+01
$\alpha_3$	2.88E-07	8.18E-03	1.66E-03	3.88E-02	0.00E+00	2.6722E-01	3.2389E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9113590	0.9628920	0.9688970	0.9938680	1.0000000	4.8136E+01	1.8551E+00
$\alpha_2$	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
$\alpha_3$	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
$\alpha_4$	1.93E-08	4.45E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9768E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	2.00	2.00	2.00
$N_1$	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000
$N_4$			0.0000

## 1.7.5 BWR Isolation Condenser Heat Exchanger

### 1.7.5.1 ISO CONDENSER HEAT EXCHANGER PLUG/LOSS OF HEAT TRANSFER

System :	Isolation condenser
Component :	Heat Exchanger
Failure Mode :	High dP across filter Loss of heat transfer capabilities in heat exchangers No flow/plugged
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 0.00

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8386830	0.9593170	0.9828300	0.9999250	1.0000000	1.0246E+01	4.3452E-01
$\alpha_2$	7.70E-05	4.07E-02	1.72E-02	1.61E-01	0.00E+00	4.3452E-01	1.0246E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8979020	0.9640890	0.9736330	0.9976040	1.0000000	2.9555E+01	1.1009E+00
$\alpha_2$	8.71E-04	2.72E-02	1.78E-02	8.57E-02	0.00E+00	8.3366E-01	2.9822E+01
$\alpha_3$	3.08E-07	8.72E-03	1.77E-03	4.13E-02	0.00E+00	2.6722E-01	3.0389E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9077330	0.9613450	0.9675780	0.9936050	1.0000000	4.6136E+01	1.8551E+00
$\alpha_2$	2.13E-03	2.56E-02	1.93E-02	7.04E-02	0.00E+00	1.2281E+00	4.6763E+01
$\alpha_3$	9.52E-06	8.42E-03	3.13E-03	3.48E-02	0.00E+00	4.0431E-01	4.7587E+01
$\alpha_4$	2.01E-08	4.64E-03	6.37E-04	2.32E-02	0.00E+00	2.2267E-01	4.7768E+01

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	0.00E+00	0.00E+00	0.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

**Component Cooling Heat Exchanger**

CCW HEAT EXCHANGER LOSS OF HEAT TRANSFER SPAR: CCW-HTX-PG

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	0.00	0.00	0.00
N <sub>1</sub>	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000
N <sub>4</sub>			0.0000

**1.7.6 Component Cooling Heat Exchanger****1.7.6.1 CCW HEAT EXCHANGER LOSS OF HEAT TRANSFER SPAR: CCW-HTX-PG**

System :

Component cooling water

Component :

Heat Exchanger

Failure Mode :

Fail to Operate (Open/Close)

Start Date :

1997/01/01

Data Version :

2009/12/31

Loss of heat transfer capabilities in heat exchangers

Total Number of Independent Failure Events: 18.60

Total Number of Common-Cause Failure Events: 2

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8886600	0.9684720	0.9827420	0.9996820	0.9799720	1.8579E+01	6.0482E-01
$\alpha_2$	3.20E-04	3.15E-02	1.73E-02	1.11E-01	2.00E-02	6.0482E-01	1.8579E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9066870	0.9626550	0.9695650	0.9949460	0.9591410	4.1543E+01	1.6116E+00
$\alpha_2$	3.10E-03	3.12E-02	2.42E-02	8.29E-02	4.09E-02	1.3443E+00	4.1810E+01
$\alpha_3$	2.18E-07	6.19E-03	1.25E-03	2.94E-02	8.00E-06	2.6732E-01	4.2887E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9066780	0.9552820	0.9599340	0.9879690	0.9374590	6.1440E+01	2.8761E+00
$\alpha_2$	7.30E-03	3.50E-02	3.02E-02	7.88E-02	6.25E-02	2.2486E+00	6.2067E+01
$\alpha_3$	7.15E-06	6.29E-03	2.34E-03	2.60E-02	3.06E-05	4.0481E-01	6.3911E+01
$\alpha_4$	1.49E-08	3.46E-03	4.74E-04	1.73E-02	0.00E+00	2.2267E-01	6.4093E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9799720	0.9591410	0.9374590
$\alpha_2$	2.00E-02	4.09E-02	6.25E-02
$\alpha_3$		8.00E-06	3.06E-05
$\alpha_4$			0.00E+00

**Heat** Exchangers

2009

**Component** Cooling Heat Exchanger

CCW HEAT EXCHANGER LOSS OF HEAT TRANSFER SPAR: CCW-HTX-PG

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.80E-01	9.59E-01	9.37E-01
Beta	2.00E-02	4.09E-02	6.25E-02
Gamma		1.96E-04	4.90E-04
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	7.44	11.16	14.88
N <sub>1</sub>	0.8927	0.8284	0.4242
N <sub>2</sub>	0.1703	0.5106	1.0205
N <sub>3</sub>		0.0001	0.0005
N <sub>4</sub>			0.0000

## 1.8 Safety and Relief Valves

### 1.8.1 Pooled Safety Valves

#### 1.8.1.1 SAFETY VALVES (DIRECT ACTING) FAIL TO OPEN ALL SYS

Component : Safety Valve (Single Acting)  
Failure Mode : Fail to open on demand  
Start Date : 1997/01/01  
Data Version : 2009/12/31

Total Number of Independent Failure Events: 4.00

Total Number of Common-Cause Failure Events: 2

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8474860	0.9613070	0.9834100	0.9999200	0.9890430	1.1004E+01	4.4292E-01
$\alpha_2$	8.19E-05	3.87E-02	1.66E-02	1.53E-01	1.10E-02	4.4292E-01	1.1004E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9000550	0.9645780	0.9738030	0.9975160	0.9777540	3.0667E+01	1.1262E+00
$\alpha_2$	9.46E-04	2.70E-02	1.79E-02	8.42E-02	2.22E-02	8.5896E-01	3.0934E+01
$\alpha_3$	2.96E-07	8.40E-03	1.71E-03	3.99E-02	0.00E+00	2.6722E-01	3.1526E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9088610	0.9614960	0.9675470	0.9934010	0.9663220	4.7585E+01	1.9056E+00
$\alpha_2$	2.33E-03	2.58E-02	1.98E-02	7.01E-02	3.37E-02	1.2786E+00	4.8212E+01
$\alpha_3$	9.23E-06	8.17E-03	3.04E-03	3.37E-02	0.00E+00	4.0431E-01	4.9086E+01
$\alpha_4$	1.95E-08	4.50E-03	6.18E-04	2.25E-02	0.00E+00	2.2267E-01	4.9268E+01

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9299010	0.9643290	0.9673370	0.9884610	0.9545700	9.7930E+01	3.6224E+00
$\alpha_2$	4.37E-03	2.16E-02	1.86E-02	4.94E-02	4.54E-02	2.1984E+00	9.9354E+01
$\alpha_3$	4.70E-04	9.62E-03	6.65E-03	2.89E-02	0.00E+00	9.7738E-01	1.0058E+02
$\alpha_4$	2.43E-06	3.69E-03	1.24E-03	1.57E-02	0.00E+00	3.7439E-01	1.0118E+02
$\alpha_5$	5.88E-21	7.12E-04	4.03E-07	4.12E-03	0.00E+00	7.2277E-02	1.0148E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9333380	0.9643080	0.9667930	0.9867860	0.9425600	1.1901E+02	4.4050E+00
$\alpha_2$	4.19E-03	1.92E-02	1.66E-02	4.28E-02	5.74E-02	2.3655E+00	1.2105E+02
$\alpha_3$	6.52E-04	9.25E-03	6.77E-03	2.63E-02	0.00E+00	1.1418E+00	1.2227E+02
$\alpha_4$	4.29E-05	4.80E-03	2.51E-03	1.73E-02	0.00E+00	5.9222E-01	1.2282E+02
$\alpha_5$	7.53E-09	1.80E-03	2.44E-04	9.02E-03	0.00E+00	2.2220E-01	1.2319E+02
$\alpha_6$	1.14E-18	6.74E-04	1.18E-06	3.94E-03	0.00E+00	8.3237E-02	1.2333E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9418130	0.9656960	0.9672920	0.9841250	0.9302780	1.8641E+02	6.6218E+00
$\alpha_2$	5.00E-03	1.69E-02	1.53E-02	3.44E-02	6.97E-02	3.2646E+00	1.8977E+02
$\alpha_3$	1.14E-03	8.45E-03	6.82E-03	2.13E-02	0.00E+00	1.6312E+00	1.9140E+02
$\alpha_4$	2.57E-04	5.12E-03	3.55E-03	1.54E-02	0.00E+00	9.8887E-01	1.9204E+02
$\alpha_5$	1.33E-05	2.70E-03	1.28E-03	1.02E-02	0.00E+00	5.2177E-01	1.9251E+02
$\alpha_6$	3.48E-10	9.65E-04	8.24E-05	5.07E-03	0.00E+00	1.8628E-01	1.9285E+02
$\alpha_7$	0.00E+00	1.51E-04	1.32E-13	5.67E-04	0.00E+00	2.9071E-02	1.9300E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9448170	0.9663980	0.9677450	0.9833740	0.9177140	2.2136E+02	7.6967E+00
$\alpha_2$	4.96E-03	1.56E-02	1.42E-02	3.10E-02	8.23E-02	3.5804E+00	2.2548E+02
$\alpha_3$	1.12E-03	7.59E-03	6.21E-03	1.88E-02	0.00E+00	1.7384E+00	2.2732E+02
$\alpha_4$	3.54E-04	5.01E-03	3.66E-03	1.43E-02	0.00E+00	1.1465E+00	2.2791E+02
$\alpha_5$	5.63E-05	3.09E-03	1.82E-03	1.05E-02	0.00E+00	7.0833E-01	2.2835E+02
$\alpha_6$	9.07E-07	1.60E-03	5.25E-04	6.85E-03	0.00E+00	3.6696E-01	2.2869E+02
$\alpha_7$	7.11E-14	5.37E-04	9.66E-06	3.06E-03	0.00E+00	1.2297E-01	2.2893E+02
$\alpha_8$	1.33E-42	1.45E-04	2.06E-12	6.11E-04	0.00E+00	3.3124E-02	2.2902E+02

**ALPHA FACTOR and MGL PARAMETERS**

<b>Alpha Factor</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>	<b>CCCG=7</b>	<b>CCCG=8</b>
$\alpha_1$	0.9890430	0.9777540	0.9663220	0.9545700	0.9425600	0.9302780	0.9177140
$\alpha_2$	1.10E-02	2.22E-02	3.37E-02	4.54E-02	5.74E-02	6.97E-02	8.23E-02
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.89E-01	9.78E-01	9.66E-01	9.55E-01	9.43E-01	9.30E-01	9.18E-01
Beta	1.10E-02	2.22E-02	3.37E-02	4.54E-02	5.74E-02	6.97E-02	8.23E-02
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	0.50	0.75	1.00	1.25	1.50	1.75	2.00
N <sub>1</sub>	0.2582	0.3620	0.4490	0.5192	0.5725	0.6090	0.6287
N <sub>2</sub>	0.0084	0.0253	0.0505	0.0842	0.1263	0.1768	0.2357
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

### 1.8.1.2 SAFETY VALVES (DIRECT ACTING) FAIL TO CLOSE ALL SYS

Component :

Safety Valve (Single Acting)

Failure Mode :

Fail to close (reseat) on demand

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 6.00

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8503880	0.9620610	0.9837560	0.9999220	0.9916300	1.1229E+01	4.4282E-01
$\alpha_2$	8.01E-05	3.79E-02	1.62E-02	1.50E-01	8.37E-03	4.4282E-01	1.1229E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9011190	0.9649650	0.9740980	0.9975450	0.9831080	3.1010E+01	1.1259E+00
$\alpha_2$	9.34E-04	2.67E-02	1.77E-02	8.33E-02	1.69E-02	8.5866E-01	3.1277E+01
$\alpha_3$	2.93E-07	8.32E-03	1.69E-03	3.94E-02	0.00E+00	2.6722E-01	3.1869E+01

## Pooled Safety Valves

SAFETY VALVES (DIRECT ACTING) FAIL TO CLOSE ALL SYS

**CCCG = 4**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9096840	0.9618530	0.9678530	0.9934660	0.9743590	4.8036E+01	1.9051E+00
$\alpha_2$	2.30E-03	2.56E-02	1.96E-02	6.95E-02	2.56E-02	1.2781E+00	4.8663E+01
$\alpha_3$	9.14E-06	8.10E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9537E+01
$\alpha_4$	1.93E-08	4.46E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9718E+01

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9302990	0.9645370	0.9675290	0.9885310	0.9656010	9.8499E+01	3.6215E+00
$\alpha_2$	4.34E-03	2.15E-02	1.85E-02	4.91E-02	3.44E-02	2.1975E+00	9.9923E+01
$\alpha_3$	4.68E-04	9.57E-03	6.62E-03	2.88E-02	0.00E+00	9.7738E-01	1.0114E+02
$\alpha_4$	2.41E-06	3.67E-03	1.24E-03	1.56E-02	0.00E+00	3.7439E-01	1.0175E+02
$\alpha_5$	5.85E-21	7.08E-04	4.00E-07	4.10E-03	0.00E+00	7.2277E-02	1.0205E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9337130	0.9645130	0.9669850	0.9868660	0.9565220	1.1969E+02	4.4037E+00
$\alpha_2$	4.16E-03	1.91E-02	1.65E-02	4.26E-02	4.35E-02	2.3642E+00	1.2173E+02
$\alpha_3$	6.48E-04	9.20E-03	6.73E-03	2.62E-02	0.00E+00	1.1418E+00	1.2295E+02
$\alpha_4$	4.27E-05	4.77E-03	2.50E-03	1.72E-02	0.00E+00	5.9222E-01	1.2350E+02
$\alpha_5$	7.49E-09	1.79E-03	2.43E-04	8.97E-03	0.00E+00	2.2220E-01	1.2387E+02
$\alpha_6$	1.14E-18	6.71E-04	1.17E-06	3.92E-03	0.00E+00	8.3237E-02	1.2401E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9420580	0.9658460	0.9674360	0.9841980	0.9474470	1.8721E+02	6.6200E+00
$\alpha_2$	4.97E-03	1.68E-02	1.52E-02	3.43E-02	5.26E-02	3.2628E+00	1.9057E+02
$\alpha_3$	1.13E-03	8.42E-03	6.80E-03	2.12E-02	0.00E+00	1.6312E+00	1.9220E+02
$\alpha_4$	2.56E-04	5.10E-03	3.53E-03	1.53E-02	0.00E+00	9.8887E-01	1.9284E+02
$\alpha_5$	1.32E-05	2.69E-03	1.27E-03	1.02E-02	0.00E+00	5.2177E-01	1.9331E+02
$\alpha_6$	3.47E-10	9.61E-04	8.21E-05	5.04E-03	0.00E+00	1.8628E-01	1.9364E+02
$\alpha_7$	0.00E+00	1.50E-04	1.31E-13	5.65E-04	0.00E+00	2.9071E-02	1.9380E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9450440	0.9665400	0.9678870	0.9834470	0.9380610	2.2226E+02	7.6943E+00
$\alpha_2$	4.94E-03	1.56E-02	1.42E-02	3.09E-02	6.19E-02	3.5780E+00	2.2638E+02
$\alpha_3$	1.12E-03	7.56E-03	6.19E-03	1.87E-02	0.00E+00	1.7384E+00	2.2822E+02
$\alpha_4$	3.53E-04	4.99E-03	3.64E-03	1.42E-02	0.00E+00	1.1465E+00	2.2881E+02
$\alpha_5$	5.61E-05	3.08E-03	1.81E-03	1.04E-02	0.00E+00	7.0833E-01	2.2925E+02
$\alpha_6$	9.03E-07	1.60E-03	5.22E-04	6.83E-03	0.00E+00	3.6696E-01	2.2959E+02
$\alpha_7$	7.08E-14	5.35E-04	9.62E-06	3.04E-03	0.00E+00	1.2297E-01	2.2983E+02
$\alpha_8$	1.33E-42	1.44E-04	2.05E-12	6.09E-04	0.00E+00	3.3124E-02	2.2992E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9916300	0.9831080	0.9743590	0.9656010	0.9565220	0.9474470	0.9380610
$\alpha_2$	8.37E-03	1.69E-02	2.56E-02	3.44E-02	4.35E-02	5.26E-02	6.19E-02
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.92E-01	9.83E-01	9.74E-01	9.66E-01	9.57E-01	9.47E-01	9.38E-01
Beta	8.37E-03	1.69E-02	2.56E-02	3.44E-02	4.35E-02	5.26E-02	6.19E-02
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	0.75	1.13	1.50	1.88	2.25	2.63	3.00
N <sub>1</sub>	0.2333	0.3250	0.4000	0.4583	0.5000	0.5250	0.5333
N <sub>2</sub>	0.0083	0.0250	0.0500	0.0833	0.1250	0.1750	0.2333
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

**1.8.2 PWR Steam Generator Safety Valves****1.8.2.1 PWR MAIN STEAM CODE SAFETIES FAIL TO OPEN**

System :	Main steam
Component :	Safety Valve (Single Acting)
Failure Mode :	Fail to open on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 2

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8441500	0.9604430	0.9830180	0.9999180	0.9837400	1.0754E+01	4.4292E-01
$\alpha_2$	8.39E-05	3.96E-02	1.70E-02	1.56E-01	1.63E-02	4.4292E-01	1.0754E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8989010	0.9641610	0.9734880	0.9974860	0.9670270	3.0297E+01	1.1262E+00
$\alpha_2$	9.57E-04	2.73E-02	1.81E-02	8.52E-02	3.30E-02	8.5896E-01	3.0564E+01
$\alpha_3$	3.00E-07	8.50E-03	1.73E-03	4.03E-02	0.00E+00	2.6722E-01	3.1156E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9079480	0.9611030	0.9672170	0.9933320	0.9494750	4.7085E+01	1.9056E+00
$\alpha_2$	2.35E-03	2.61E-02	2.00E-02	7.08E-02	5.05E-02	1.2786E+00	4.7712E+01
$\alpha_3$	9.32E-06	8.25E-03	3.07E-03	3.41E-02	0.00E+00	4.0431E-01	4.8586E+01
$\alpha_4$	1.97E-08	4.55E-03	6.24E-04	2.28E-02	0.00E+00	2.2267E-01	4.8768E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9837400	0.9670270	0.9494750
$\alpha_2$	1.63E-02	3.30E-02	5.05E-02
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.84E-01	9.67E-01	9.49E-01
Beta	1.63E-02	3.30E-02	5.05E-02
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	0.25	0.38	0.50
$N_1$	0.2582	0.3620	0.4490
$N_2$	0.0084	0.0253	0.0505
$N_3$		0.0000	0.0000
$N_4$			0.0000

### 1.8.2.2 PWR MAIN STEAM CODE SAFETIES FAIL TO CLOSE

System : Main steam  
 Component : Safety Valve (Single Acting)  
 Failure Mode : Fail to close (reseat) on demand  
 Plant Type : PWR  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 5.00

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8488640	0.9616670	0.9835770	0.9999210	0.9904770	1.1109E+01	4.4282E-01
$\alpha_2$	8.10E-05	3.83E-02	1.64E-02	1.51E-01	9.52E-03	4.4282E-01	1.1109E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9005410	0.9647570	0.9739410	0.9975300	0.9806200	3.0820E+01	1.1259E+00
$\alpha_2$	9.40E-04	2.69E-02	1.78E-02	8.38E-02	1.94E-02	8.5866E-01	3.1087E+01
$\alpha_3$	2.95E-07	8.36E-03	1.70E-03	3.97E-02	0.00E+00	2.6722E-01	3.1679E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9092380	0.9616620	0.9676890	0.9934320	0.9705880	4.7786E+01	1.9051E+00
$\alpha_2$	2.32E-03	2.57E-02	1.97E-02	6.98E-02	2.94E-02	1.2781E+00	4.8413E+01
$\alpha_3$	9.19E-06	8.14E-03	3.03E-03	3.36E-02	0.00E+00	4.0431E-01	4.9287E+01
$\alpha_4$	1.94E-08	4.48E-03	6.15E-04	2.25E-02	0.00E+00	2.2267E-01	4.9468E+01

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9300820	0.9644250	0.9674260	0.9884950	0.9603640	9.8179E+01	3.6215E+00
$\alpha_2$	4.36E-03	2.16E-02	1.85E-02	4.93E-02	3.96E-02	2.1975E+00	9.9603E+01
$\alpha_3$	4.69E-04	9.60E-03	6.64E-03	2.89E-02	0.00E+00	9.7738E-01	1.0082E+02
$\alpha_4$	2.42E-06	3.68E-03	1.24E-03	1.56E-02	0.00E+00	3.7439E-01	1.0143E+02
$\alpha_5$	5.86E-21	7.10E-04	4.02E-07	4.11E-03	0.00E+00	7.2277E-02	1.0173E+02

##### CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9335170	0.9644070	0.9668820	0.9868260	0.9501000	1.1932E+02	4.4037E+00
$\alpha_2$	4.18E-03	1.91E-02	1.66E-02	4.27E-02	4.99E-02	2.3642E+00	1.2136E+02
$\alpha_3$	6.50E-04	9.23E-03	6.75E-03	2.63E-02	0.00E+00	1.1418E+00	1.2258E+02
$\alpha_4$	4.28E-05	4.79E-03	2.51E-03	1.73E-02	0.00E+00	5.9222E-01	1.2313E+02
$\alpha_5$	7.51E-09	1.80E-03	2.44E-04	9.00E-03	0.00E+00	2.2220E-01	1.2350E+02
$\alpha_6$	1.14E-18	6.73E-04	1.18E-06	3.93E-03	0.00E+00	8.3237E-02	1.2364E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9419290	0.9657670	0.9673600	0.9841610	0.9394460	1.8676E+02	6.6200E+00
$\alpha_2$	4.98E-03	1.69E-02	1.52E-02	3.44E-02	6.06E-02	3.2628E+00	1.9012E+02
$\alpha_3$	1.14E-03	8.44E-03	6.81E-03	2.13E-02	0.00E+00	1.6312E+00	1.9175E+02
$\alpha_4$	2.56E-04	5.11E-03	3.54E-03	1.53E-02	0.00E+00	9.8887E-01	1.9239E+02
$\alpha_5$	1.33E-05	2.70E-03	1.28E-03	1.02E-02	0.00E+00	5.2177E-01	1.9286E+02
$\alpha_6$	3.48E-10	9.63E-04	8.23E-05	5.06E-03	0.00E+00	1.8628E-01	1.9319E+02
$\alpha_7$	0.00E+00	1.50E-04	1.32E-13	5.66E-04	0.00E+00	2.9071E-02	1.9335E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9449250	0.9664670	0.9678120	0.9834110	0.9285800	2.2176E+02	7.6943E+00
$\alpha_2$	4.95E-03	1.56E-02	1.42E-02	3.10E-02	7.14E-02	3.5780E+00	2.2588E+02
$\alpha_3$	1.12E-03	7.58E-03	6.20E-03	1.87E-02	0.00E+00	1.7384E+00	2.2772E+02
$\alpha_4$	3.54E-04	5.00E-03	3.65E-03	1.42E-02	0.00E+00	1.1465E+00	2.2831E+02
$\alpha_5$	5.62E-05	3.09E-03	1.81E-03	1.04E-02	0.00E+00	7.0833E-01	2.2875E+02
$\alpha_6$	9.05E-07	1.60E-03	5.24E-04	6.84E-03	0.00E+00	3.6696E-01	2.2909E+02
$\alpha_7$	7.10E-14	5.36E-04	9.64E-06	3.05E-03	0.00E+00	1.2297E-01	2.2933E+02
$\alpha_8$	1.33E-42	1.44E-04	2.06E-12	6.10E-04	0.00E+00	3.3124E-02	2.2942E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9904770	0.9806200	0.9705880	0.9603640	0.9501000	0.9394460	0.9285800
$\alpha_2$	9.52E-03	1.94E-02	2.94E-02	3.96E-02	4.99E-02	6.06E-02	7.14E-02
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.90E-01	9.81E-01	9.71E-01	9.60E-01	9.50E-01	9.39E-01	9.29E-01
<b>Beta</b>	9.52E-03	1.94E-02	2.94E-02	3.96E-02	4.99E-02	6.06E-02	7.14E-02
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	0.63	0.94	1.25	1.56	1.88	2.19	2.50
N <sub>1</sub>	0.2333	0.3250	0.4000	0.4583	0.5000	0.5250	0.5333
N <sub>2</sub>	0.0083	0.0250	0.0500	0.0833	0.1250	0.1750	0.2333
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

### 1.8.3 BWR Safety Relief Valves

#### 1.8.3.1 SAFETY RELIEF VALVE FAIL TO OPEN SPAR: SRV-CC

Component : Safety Relief Valve (Dual Actuation)  
Failure Mode : Fail to open on demand  
Plant Type : BWR  
Start Date : 1997/01/01  
Data Version : 2009/12/31

Total Number of Independent Failure Events: 18.50

Total Number of Common-Cause Failure Events: 3

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8782190	0.9684030	0.9856570	0.9999020	0.9905680	1.4583E+01	4.7582E-01
$\alpha_2$	9.98E-05	3.16E-02	1.43E-02	1.22E-01	9.43E-03	4.7582E-01	1.4583E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9099610	0.9672820	0.9752540	0.9973160	0.9823210	3.5950E+01	1.2160E+00
$\alpha_2$	1.15E-03	2.54E-02	1.75E-02	7.67E-02	1.70E-02	9.4436E-01	3.6222E+01
$\alpha_3$	3.04E-07	7.31E-03	1.52E-03	3.45E-02	6.76E-04	2.7162E-01	3.6894E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9156100	0.9634550	0.9687840	0.9930620	0.9752130	5.4532E+01	2.0685E+00
$\alpha_2$	2.76E-03	2.52E-02	1.98E-02	6.59E-02	2.28E-02	1.4247E+00	5.5176E+01
$\alpha_3$	1.09E-05	7.43E-03	2.89E-03	3.03E-02	1.92E-03	4.2081E-01	5.6180E+01
$\alpha_4$	1.73E-08	3.94E-03	5.42E-04	1.97E-02	3.48E-05	2.2297E-01	5.6378E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9323120	0.9649610	0.9677340	0.9881180	0.9691750	1.0651E+02	3.8675E+00
$\alpha_2$	4.85E-03	2.18E-02	1.90E-02	4.83E-02	2.71E-02	2.4036E+00	1.0797E+02
$\alpha_3$	4.95E-04	9.20E-03	6.46E-03	2.73E-02	3.59E-03	1.0157E+00	1.0936E+02
$\alpha_4$	2.30E-06	3.41E-03	1.15E-03	1.44E-02	1.40E-04	3.7589E-01	1.1000E+02
$\alpha_5$	5.41E-21	6.55E-04	3.70E-07	3.79E-03	0.00E+00	7.2277E-02	1.1031E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9351520	0.9646510	0.9669390	0.9863150	0.9641470	1.2921E+02	4.7349E+00
$\alpha_2$	4.75E-03	1.96E-02	1.72E-02	4.24E-02	3.00E-02	2.6204E+00	1.3132E+02
$\alpha_3$	7.23E-04	9.05E-03	6.75E-03	2.52E-02	5.54E-03	1.2123E+00	1.3273E+02
$\alpha_4$	4.12E-05	4.45E-03	2.35E-03	1.60E-02	3.54E-04	5.9672E-01	1.3335E+02
$\alpha_5$	6.93E-09	1.66E-03	2.25E-04	8.31E-03	0.00E+00	2.2220E-01	1.3372E+02
$\alpha_6$	1.05E-18	6.21E-04	1.09E-06	3.63E-03	0.00E+00	8.3237E-02	1.3386E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9426260	0.9657270	0.9672330	0.9836920	0.9600310	1.9821E+02	7.0344E+00
$\alpha_2$	5.47E-03	1.73E-02	1.58E-02	3.44E-02	3.16E-02	3.5538E+00	2.0169E+02
$\alpha_3$	1.26E-03	8.50E-03	6.96E-03	2.10E-02	7.65E-03	1.7440E+00	2.0350E+02
$\alpha_4$	2.51E-04	4.87E-03	3.39E-03	1.46E-02	7.19E-04	9.9947E-01	2.0424E+02
$\alpha_5$	1.25E-05	2.54E-03	1.20E-03	9.61E-03	0.00E+00	5.2177E-01	2.0472E+02
$\alpha_6$	3.27E-10	9.08E-04	7.75E-05	4.76E-03	0.00E+00	1.8628E-01	2.0506E+02
$\alpha_7$	0.00E+00	1.42E-04	1.24E-13	5.33E-04	0.00E+00	2.9071E-02	2.0522E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9453760	0.9663080	0.9675790	0.9828980	0.9567580	2.3476E+02	8.1853E+00
$\alpha_2$	5.39E-03	1.60E-02	1.47E-02	3.11E-02	3.22E-02	3.8842E+00	2.3906E+02
$\alpha_3$	1.31E-03	7.83E-03	6.53E-03	1.88E-02	9.77E-03	1.9020E+00	2.4104E+02
$\alpha_4$	3.54E-04	4.81E-03	3.53E-03	1.36E-02	1.27E-03	1.1677E+00	2.4178E+02
$\alpha_5$	5.31E-05	2.92E-03	1.71E-03	9.87E-03	0.00E+00	7.0833E-01	2.4224E+02
$\alpha_6$	8.55E-07	1.51E-03	4.94E-04	6.46E-03	0.00E+00	3.6696E-01	2.4258E+02
$\alpha_7$	6.70E-14	5.06E-04	9.10E-06	2.88E-03	0.00E+00	1.2297E-01	2.4282E+02
$\alpha_8$	1.26E-42	1.36E-04	1.94E-12	5.76E-04	0.00E+00	3.3124E-02	2.4291E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9905680	0.9823210	0.9752130	0.9691750	0.9641470	0.9600310	0.9567580
$\alpha_2$	9.43E-03	1.70E-02	2.28E-02	2.71E-02	3.00E-02	3.16E-02	3.22E-02
$\alpha_3$		6.76E-04	1.92E-03	3.59E-03	5.54E-03	7.65E-03	9.77E-03
$\alpha_4$			3.48E-05	1.40E-04	3.54E-04	7.19E-04	1.27E-03
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.91E-01	9.82E-01	9.75E-01	9.69E-01	9.64E-01	9.60E-01	9.57E-01
<b>Beta</b>	9.43E-03	1.77E-02	2.48E-02	3.08E-02	3.59E-02	4.00E-02	4.32E-02
<b>Gamma</b>		3.82E-02	7.87E-02	1.21E-01	1.64E-01	2.09E-01	2.55E-01
<b>Delta</b>			1.79E-02	3.77E-02	6.00E-02	8.59E-02	1.15E-01
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	3.70	5.55	7.40	9.25	11.10	12.95	14.80
<b>N<sub>1</sub></b>	0.6373	0.8453	0.9960	1.1003	1.1679	1.2072	1.2255
<b>N<sub>2</sub></b>	0.0413	0.1107	0.1966	0.2894	0.3812	0.4660	0.5395
<b>N<sub>3</sub></b>		0.0044	0.0165	0.0383	0.0705	0.1128	0.1636
<b>N<sub>4</sub></b>			0.0003	0.0015	0.0045	0.0106	0.0212
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0000
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

### 1.8.3.2 SAFETY RELIEF VALVE FAIL TO CLOSE SPAR: SRV-OO

**Component :** Safety Relief Valve (Dual Actuation)  
**Failure Mode :** Fail to close (reseat) on demand  
**Plant Type :** BWR  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 6.00

Total Number of Common-Cause Failure Events: 0

### ALPHA FACTOR DISTRIBUTIONS

#### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8959650	0.9739500	0.9892430	0.9999480	1.0000000	1.6246E+01	4.3452E-01
$\alpha_2$	4.81E-05	2.60E-02	1.08E-02	1.04E-01	0.00E+00	4.3452E-01	1.6246E+01

#### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9143470	0.9699670	0.9780280	0.9980130	1.0000000	3.5555E+01	1.1009E+00
$\alpha_2$	7.25E-04	2.27E-02	1.48E-02	7.18E-02	0.00E+00	8.3366E-01	3.5822E+01
$\alpha_3$	2.56E-07	7.29E-03	1.48E-03	3.46E-02	0.00E+00	2.6722E-01	3.6389E+01

#### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9178250	0.9656410	0.9712250	0.9943340	1.0000000	5.2136E+01	1.8551E+00
$\alpha_2$	1.89E-03	2.27E-02	1.72E-02	6.27E-02	0.00E+00	1.2281E+00	5.2763E+01
$\alpha_3$	8.45E-06	7.49E-03	2.78E-03	3.09E-02	0.00E+00	4.0431E-01	5.3587E+01
$\alpha_4$	1.78E-08	4.12E-03	5.66E-04	2.07E-02	0.00E+00	2.2267E-01	5.3768E+01

#### **CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9337450	0.9665250	0.9694270	0.9893730	1.0000000	1.0216E+02	3.5382E+00
$\alpha_2$	3.85E-03	2.00E-02	1.71E-02	4.62E-02	0.00E+00	2.1142E+00	1.0358E+02
$\alpha_3$	4.52E-04	9.25E-03	6.39E-03	2.78E-02	0.00E+00	9.7738E-01	1.0472E+02
$\alpha_4$	2.33E-06	3.54E-03	1.19E-03	1.50E-02	0.00E+00	3.7439E-01	1.0532E+02
$\alpha_5$	5.65E-21	6.84E-04	3.87E-07	3.96E-03	0.00E+00	7.2277E-02	1.0563E+02

#### **CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9366750	0.9663680	0.9687880	0.9877920	1.0000000	1.2294E+02	4.2787E+00
$\alpha_2$	3.62E-03	1.76E-02	1.51E-02	4.00E-02	0.00E+00	2.2392E+00	1.2498E+02
$\alpha_3$	6.32E-04	8.98E-03	6.57E-03	2.55E-02	0.00E+00	1.1418E+00	1.2608E+02
$\alpha_4$	4.16E-05	4.66E-03	2.44E-03	1.68E-02	0.00E+00	5.9222E-01	1.2663E+02
$\alpha_5$	7.30E-09	1.75E-03	2.37E-04	8.75E-03	0.00E+00	2.2220E-01	1.2700E+02
$\alpha_6$	1.11E-18	6.54E-04	1.14E-06	3.82E-03	0.00E+00	8.3237E-02	1.2714E+02

#### **CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9439980	0.9672000	0.9687770	0.9850250	1.0000000	1.9005E+02	6.4450E+00
$\alpha_2$	4.43E-03	1.57E-02	1.41E-02	3.25E-02	0.00E+00	3.0878E+00	1.9341E+02
$\alpha_3$	1.12E-03	8.30E-03	6.70E-03	2.10E-02	0.00E+00	1.6312E+00	1.9486E+02
$\alpha_4$	2.52E-04	5.03E-03	3.48E-03	1.51E-02	0.00E+00	9.8887E-01	1.9551E+02
$\alpha_5$	1.31E-05	2.66E-03	1.26E-03	1.00E-02	0.00E+00	5.2177E-01	1.9597E+02
$\alpha_6$	3.42E-10	9.48E-04	8.09E-05	4.98E-03	0.00E+00	1.8628E-01	1.9631E+02
$\alpha_7$	0.00E+00	1.48E-04	1.30E-13	5.57E-04	0.00E+00	2.9071E-02	1.9647E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9468590	0.9678670	0.9692050	0.9843190	1.0000000	2.2473E+02	7.4610E+00
$\alpha_2$	4.33E-03	1.44E-02	1.30E-02	2.92E-02	0.00E+00	3.3447E+00	2.2885E+02
$\alpha_3$	1.11E-03	7.49E-03	6.13E-03	1.85E-02	0.00E+00	1.7384E+00	2.3045E+02
$\alpha_4$	3.50E-04	4.94E-03	3.61E-03	1.41E-02	0.00E+00	1.1465E+00	2.3104E+02
$\alpha_5$	5.55E-05	3.05E-03	1.79E-03	1.03E-02	0.00E+00	7.0833E-01	2.3148E+02
$\alpha_6$	8.95E-07	1.58E-03	5.17E-04	6.76E-03	0.00E+00	3.6696E-01	2.3182E+02
$\alpha_7$	7.01E-14	5.30E-04	9.53E-06	3.02E-03	0.00E+00	1.2297E-01	2.3207E+02
$\alpha_8$	1.31E-42	1.43E-04	2.03E-12	6.03E-04	0.00E+00	3.3124E-02	2.3216E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	1.00E+00						
<b>Beta</b>	0.00E+00						
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	6.00	6.00	6.00	6.00	6.00	6.00	6.00
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0000
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

## 1.8.4 PWR Pressurizer Safety Valve

### 1.8.4.1 PWR PRESSURIZER CODE SAFETIES FAIL TO OPEN

System :	Reactor coolant
Component :	Safety Valve (Single Acting)
Failure Mode :	Fail to open on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 0

### ALPHA FACTOR DISTRIBUTIONS

#### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8636860	0.9657330	0.9856730	0.9999380	1.0000000	1.2246E+01	4.3452E-01
$\alpha_2$	6.41E-05	3.43E-02	1.43E-02	1.36E-01	0.00E+00	4.3452E-01	1.2246E+01

#### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9040420	0.9662880	0.9752810	0.9977560	1.0000000	3.1555E+01	1.1009E+00
$\alpha_2$	8.16E-04	2.55E-02	1.67E-02	8.05E-02	0.00E+00	8.3366E-01	3.1822E+01
$\alpha_3$	2.88E-07	8.18E-03	1.66E-03	3.88E-02	0.00E+00	2.6722E-01	3.2389E+01

#### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9113590	0.9628920	0.9688970	0.9938680	1.0000000	4.8136E+01	1.8551E+00
$\alpha_2$	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
$\alpha_3$	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
$\alpha_4$	1.93E-08	4.45E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9768E+01

#### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9311740	0.9652090	0.9682200	0.9889480	1.0000000	9.8161E+01	3.5382E+00
$\alpha_2$	4.01E-03	2.08E-02	1.77E-02	4.80E-02	0.00E+00	2.1142E+00	9.9585E+01
$\alpha_3$	4.70E-04	9.61E-03	6.64E-03	2.89E-02	0.00E+00	9.7738E-01	1.0072E+02
$\alpha_4$	2.42E-06	3.68E-03	1.24E-03	1.56E-02	0.00E+00	3.7439E-01	1.0132E+02
$\alpha_5$	5.87E-21	7.11E-04	4.02E-07	4.12E-03	0.00E+00	7.2277E-02	1.0163E+02

#### CCCG = 6

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9346440	0.9652760	0.9677640	0.9873890	1.0000000	1.1894E+02	4.2787E+00
$\alpha_2$	3.74E-03	1.82E-02	1.56E-02	4.13E-02	0.00E+00	2.2392E+00	1.2098E+02
$\alpha_3$	6.53E-04	9.27E-03	6.78E-03	2.64E-02	0.00E+00	1.1418E+00	1.2208E+02
$\alpha_4$	4.30E-05	4.81E-03	2.52E-03	1.73E-02	0.00E+00	5.9222E-01	1.2263E+02
$\alpha_5$	7.54E-09	1.80E-03	2.45E-04	9.04E-03	0.00E+00	2.2220E-01	1.2300E+02
$\alpha_6$	1.14E-18	6.76E-04	1.18E-06	3.94E-03	0.00E+00	8.3237E-02	1.2314E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9428470	0.9665190	0.9681250	0.9847050	1.0000000	1.8605E+02	6.4450E+00
$\alpha_2$	4.52E-03	1.60E-02	1.44E-02	3.32E-02	0.00E+00	3.0878E+00	1.8941E+02
$\alpha_3$	1.14E-03	8.47E-03	6.84E-03	2.14E-02	0.00E+00	1.6312E+00	1.9086E+02
$\alpha_4$	2.57E-04	5.14E-03	3.56E-03	1.54E-02	0.00E+00	9.8887E-01	1.9151E+02
$\alpha_5$	1.33E-05	2.71E-03	1.28E-03	1.02E-02	0.00E+00	5.2177E-01	1.9197E+02
$\alpha_6$	3.49E-10	9.68E-04	8.26E-05	5.08E-03	0.00E+00	1.8628E-01	1.9231E+02
$\alpha_7$	0.00E+00	1.51E-04	1.32E-13	5.69E-04	0.00E+00	2.9071E-02	1.9247E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9459360	0.9673040	0.9686640	0.9840410	1.0000000	2.2073E+02	7.4610E+00
$\alpha_2$	4.41E-03	1.47E-02	1.33E-02	2.97E-02	0.00E+00	3.3447E+00	2.2485E+02
$\alpha_3$	1.13E-03	7.62E-03	6.24E-03	1.88E-02	0.00E+00	1.7384E+00	2.2645E+02
$\alpha_4$	3.56E-04	5.02E-03	3.67E-03	1.43E-02	0.00E+00	1.1465E+00	2.2704E+02
$\alpha_5$	5.65E-05	3.10E-03	1.82E-03	1.05E-02	0.00E+00	7.0833E-01	2.2748E+02
$\alpha_6$	9.10E-07	1.61E-03	5.27E-04	6.88E-03	0.00E+00	3.6696E-01	2.2782E+02
$\alpha_7$	7.14E-14	5.39E-04	9.69E-06	3.07E-03	0.00E+00	1.2297E-01	2.2807E+02
$\alpha_8$	1.34E-42	1.45E-04	2.07E-12	6.14E-04	0.00E+00	3.3124E-02	2.2816E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	1.00E+00						
<b>Beta</b>	0.00E+00						
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	2.00	2.00	2.00	2.00	2.00	2.00	2.00
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

#### 1.8.4.2 PWR PRESSURIZER CODE SAFETIES FAIL TO CLOSE

System : Reactor coolant  
 Component : Safety Valve (Single Acting)  
 Failure Mode : Fail to open on demand  
 Plant Type : PWR  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 2.00

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8636860	0.9657330	0.9856730	0.9999380	1.0000000	1.2246E+01	4.3452E-01
$\alpha_2$	6.41E-05	3.43E-02	1.43E-02	1.36E-01	0.00E+00	4.3452E-01	1.2246E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9040420	0.9662880	0.9752810	0.9977560	1.0000000	3.1555E+01	1.1009E+00
$\alpha_2$	8.16E-04	2.55E-02	1.67E-02	8.05E-02	0.00E+00	8.3366E-01	3.1822E+01
$\alpha_3$	2.88E-07	8.18E-03	1.66E-03	3.88E-02	0.00E+00	2.6722E-01	3.2389E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9113590	0.9628920	0.9688970	0.9938680	1.0000000	4.8136E+01	1.8551E+00
$\alpha_2$	2.04E-03	2.46E-02	1.86E-02	6.77E-02	0.00E+00	1.2281E+00	4.8763E+01
$\alpha_3$	9.14E-06	8.09E-03	3.01E-03	3.34E-02	0.00E+00	4.0431E-01	4.9587E+01
$\alpha_4$	1.93E-08	4.45E-03	6.12E-04	2.23E-02	0.00E+00	2.2267E-01	4.9768E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	2.00	2.00	2.00
N <sub>1</sub>	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000
N <sub>4</sub>			0.0000

## 1.9 PORVs

### 1.9.1 Pooled PORVs

#### 1.9.1.1 POWER OPERATED RELIEF VALVES FAIL TO OPEN ALL SYSTEMS

Component :	Power Operated Relief Valve
Failure Mode :	Fail to open on demand
Op. Mode :	CCF Event Can Only Happen During Power Operation CCF Event May Occur During Both Power Operation & Shutdown
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 91.20

Total Number of Common-Cause Failure Events: 8

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9271650	0.9730840	0.9793580	0.9975380	0.9770370	4.6583E+01	1.2885E+00
$\alpha_2$	2.46E-03	2.69E-02	2.06E-02	7.28E-02	2.30E-02	1.2885E+00	4.6583E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9261210	0.9640610	0.9676230	0.9898060	0.9640450	8.2395E+01	3.0716E+00
$\alpha_2$	6.87E-03	2.94E-02	2.58E-02	6.41E-02	3.06E-02	2.5087E+00	8.2958E+01
$\alpha_3$	4.70E-05	6.59E-03	3.33E-03	2.42E-02	5.39E-03	5.6292E-01	8.4904E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9346400	0.9655630	0.9681170	0.9877590	0.9683630	1.1616E+02	4.1429E+00
$\alpha_2$	4.29E-03	1.96E-02	1.70E-02	4.39E-02	1.57E-02	2.3624E+00	1.1794E+02
$\alpha_3$	1.18E-03	1.15E-02	8.91E-03	3.06E-02	1.35E-02	1.3814E+00	1.1892E+02
$\alpha_4$	3.41E-06	3.32E-03	1.21E-03	1.38E-02	2.44E-03	3.9907E-01	1.1990E+02

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9446240	0.9680260	0.9696590	0.9858390	0.9719320	1.8340E+02	6.0577E+00
$\alpha_2$	4.27E-03	1.57E-02	1.40E-02	3.28E-02	9.55E-03	2.9713E+00	1.8649E+02
$\alpha_3$	1.68E-03	1.00E-02	8.36E-03	2.41E-02	1.03E-02	1.8993E+00	1.8756E+02
$\alpha_4$	2.88E-04	5.37E-03	3.76E-03	1.59E-02	7.16E-03	1.0169E+00	1.8844E+02
$\alpha_5$	7.66E-11	8.98E-04	5.82E-05	4.82E-03	1.09E-03	1.7018E-01	1.8929E+02

## Pooled PORVs

POWER OPERATED RELIEF VALVES FAIL TO OPEN ALL SYSTEMS

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9484620	0.9692530	0.9706120	0.9853950	0.9743990	2.2136E+02	7.0221E+00
$\alpha_2$	3.75E-03	1.34E-02	1.20E-02	2.78E-02	7.68E-03	3.0623E+00	2.2532E+02
$\alpha_3$	1.19E-03	7.77E-03	6.39E-03	1.91E-02	5.91E-03	1.7754E+00	2.2661E+02
$\alpha_4$	6.56E-04	6.18E-03	4.81E-03	1.64E-02	7.64E-03	1.4112E+00	2.2697E+02
$\alpha_5$	3.49E-05	2.81E-03	1.55E-03	9.85E-03	3.91E-03	6.4100E-01	2.2774E+02
$\alpha_6$	3.96E-13	5.79E-04	1.45E-05	3.26E-03	4.57E-04	1.3224E-01	2.2825E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9527840	0.9700630	0.9710570	0.9839610	0.9760240	3.0559E+02	9.4307E+00
$\alpha_2$	4.40E-03	1.28E-02	1.18E-02	2.46E-02	7.50E-03	4.0222E+00	3.1100E+02
$\alpha_3$	1.18E-03	6.46E-03	5.45E-03	1.52E-02	3.24E-03	2.0350E+00	3.1299E+02
$\alpha_4$	7.34E-04	5.29E-03	4.29E-03	1.33E-02	5.44E-03	1.6660E+00	3.1335E+02
$\alpha_5$	3.06E-04	3.85E-03	2.86E-03	1.08E-02	5.55E-03	1.2128E+00	3.1381E+02
$\alpha_6$	2.87E-06	1.41E-03	5.75E-04	5.65E-03	2.07E-03	4.4458E-01	3.1458E+02
$\alpha_7$	1.93E-29	1.59E-04	1.81E-09	8.47E-04	1.69E-04	5.0071E-02	3.1497E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9552050	0.9709020	0.9717540	0.9837030	0.9770990	3.5733E+02	1.0709E+01
$\alpha_2$	4.46E-03	1.21E-02	1.12E-02	2.27E-02	7.80E-03	4.4505E+00	3.6359E+02
$\alpha_3$	1.03E-03	5.57E-03	4.71E-03	1.31E-02	2.21E-03	2.0512E+00	3.6599E+02
$\alpha_4$	5.43E-04	4.27E-03	3.42E-03	1.09E-02	3.01E-03	1.5731E+00	3.6647E+02
$\alpha_5$	4.08E-04	3.84E-03	2.99E-03	1.02E-02	4.97E-03	1.4135E+00	3.6663E+02
$\alpha_6$	1.01E-04	2.49E-03	1.66E-03	7.68E-03	3.86E-03	9.1486E-01	3.6712E+02
$\alpha_7$	2.39E-08	7.23E-04	1.43E-04	3.43E-03	1.01E-03	2.6607E-01	3.6777E+02
$\alpha_8$	5.93E-36	1.09E-04	4.96E-11	5.25E-04	4.93E-05	4.0124E-02	3.6800E+02

**ALPHA FACTOR and MGL PARAMETERS**

<b>Alpha Factor</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>	<b>CCCG=7</b>	<b>CCCG=8</b>
$\alpha_1$	0.9770370	0.9640450	0.9683630	0.9719320	0.9743990	0.9760240	0.9770990
$\alpha_2$	2.30E-02	3.06E-02	1.57E-02	9.55E-03	7.68E-03	7.50E-03	7.80E-03
$\alpha_3$		5.39E-03	1.35E-02	1.03E-02	5.91E-03	3.24E-03	2.21E-03
$\alpha_4$			2.44E-03	7.16E-03	7.64E-03	5.44E-03	3.01E-03
$\alpha_5$				1.09E-03	3.91E-03	5.55E-03	4.97E-03
$\alpha_6$					4.57E-04	2.07E-03	3.86E-03
$\alpha_7$						1.69E-04	1.01E-03
$\alpha_8$							4.93E-05

## Pooled PORVs

## POWER OPERATED RELIEF VALVES FAIL TO CLOSE ALL SYSTEMS

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.77E-01	9.64E-01	9.68E-01	9.72E-01	9.74E-01	9.76E-01	9.77E-01
Beta	2.30E-02	3.60E-02	3.16E-02	2.81E-02	2.56E-02	2.40E-02	2.29E-02
Gamma		1.50E-01	5.04E-01	6.60E-01	7.00E-01	6.87E-01	6.60E-01
Delta			1.53E-01	4.45E-01	6.70E-01	8.03E-01	8.54E-01
Epsilon				1.32E-01	3.64E-01	5.89E-01	7.67E-01
Mu					1.05E-01	2.88E-01	4.97E-01
Upsilon						7.52E-02	2.15E-01
Sigma							4.66E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	33.16	49.75	66.33	82.91	99.49	116.07	132.65
N <sub>1</sub>	3.1765	3.0898	3.6969	4.3316	4.9292	5.4682	5.9489
N <sub>2</sub>	0.8540	1.6750	1.1343	0.8571	0.8231	0.9344	1.1058
N <sub>3</sub>		0.2957	0.9771	0.9219	0.6336	0.4038	0.3128
N <sub>4</sub>			0.1764	0.6425	0.8190	0.6771	0.4266
N <sub>5</sub>				0.0979	0.4188	0.6910	0.7052
N <sub>6</sub>					0.0490	0.2583	0.5479
N <sub>7</sub>						0.0210	0.1431
N <sub>8</sub>							0.0070

**1.9.1.2 POWER OPERATED RELIEF VALVES FAIL TO CLOSE ALL SYSTEMS**

Component :

Power Operated Relief Valve

Failure Mode :

Fail to close (reseat) on demand

Op. Mode :

CCF Event Can Only Happen During Power Operation

CCF Event May Occur During Both Power Operation &amp; Shutdown

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 27.00

Total Number of Common-Cause Failure Events: 1

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9280910	0.9820330	0.9926450	0.9999640	0.9998750	2.3843E+01	4.3622E-01
$\alpha_2$	3.35E-05	1.80E-02	7.36E-03	7.19E-02	1.25E-04	4.3622E-01	2.3843E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9380420	0.9783380	0.9842070	0.9985600	0.9997550	4.9945E+01	1.1059E+00
$\alpha_2$	5.30E-04	1.64E-02	1.07E-02	5.20E-02	2.45E-04	8.3866E-01	5.0212E+01
$\alpha_3$	1.83E-07	5.23E-03	1.05E-03	2.48E-02	0.00E+00	2.6722E-01	5.0784E+01

## Pooled PORVs

POWER OPERATED RELIEF VALVES FAIL TO CLOSE ALL SYSTEMS

**CCCG = 4**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9405030	0.9751920	0.9792780	0.9959030	0.9996320	7.3316E+01	1.8651E+00
$\alpha_2$	1.38E-03	1.65E-02	1.24E-02	4.54E-02	3.68E-04	1.2381E+00	7.3943E+01
$\alpha_3$	6.05E-06	5.38E-03	1.99E-03	2.22E-02	0.00E+00	4.0431E-01	7.4777E+01
$\alpha_4$	1.28E-08	2.96E-03	4.05E-04	1.48E-02	0.00E+00	2.2267E-01	7.4958E+01

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9473080	0.9734130	0.9757430	0.9915640	0.9995290	1.3013E+02	3.5542E+00
$\alpha_2$	3.09E-03	1.59E-02	1.36E-02	3.68E-02	4.62E-04	2.1299E+00	1.3155E+02
$\alpha_3$	3.57E-04	7.31E-03	5.05E-03	2.20E-02	8.83E-06	9.7768E-01	1.3271E+02
$\alpha_4$	1.84E-06	2.80E-03	9.42E-04	1.19E-02	0.00E+00	3.7439E-01	1.3331E+02
$\alpha_5$	4.46E-21	5.41E-04	3.05E-07	3.13E-03	0.00E+00	7.2277E-02	1.3361E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9499490	0.9734440	0.9753720	0.9903570	0.9994310	1.5769E+02	4.3019E+00
$\alpha_2$	2.90E-03	1.40E-02	1.20E-02	3.17E-02	5.49E-04	2.2616E+00	1.5973E+02
$\alpha_3$	4.97E-04	7.05E-03	5.16E-03	2.01E-02	1.96E-05	1.1426E+00	1.6085E+02
$\alpha_4$	3.27E-05	3.66E-03	1.91E-03	1.32E-02	0.00E+00	5.9222E-01	1.6140E+02
$\alpha_5$	5.73E-09	1.37E-03	1.86E-04	6.87E-03	0.00E+00	2.2220E-01	1.6177E+02
$\alpha_6$	8.70E-19	5.14E-04	8.98E-07	3.00E-03	0.00E+00	8.3237E-02	1.6191E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9535230	0.9727940	0.9741100	0.9875750	0.9993340	2.3158E+02	6.4767E+00
$\alpha_2$	3.72E-03	1.31E-02	1.18E-02	2.71E-02	6.33E-04	3.1179E+00	2.3494E+02
$\alpha_3$	9.25E-04	6.86E-03	5.54E-03	1.73E-02	3.36E-05	1.6328E+00	2.3642E+02
$\alpha_4$	2.08E-04	4.15E-03	2.87E-03	1.25E-02	0.00E+00	9.8887E-01	2.3707E+02
$\alpha_5$	1.08E-05	2.19E-03	1.04E-03	8.28E-03	0.00E+00	5.2177E-01	2.3753E+02
$\alpha_6$	2.82E-10	7.83E-04	6.68E-05	4.11E-03	0.00E+00	1.8628E-01	2.3787E+02
$\alpha_7$	0.00E+00	1.22E-04	1.07E-13	4.60E-04	0.00E+00	2.9071E-02	2.3803E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9557630	0.9732590	0.9743780	0.9869420	0.9992440	2.7304E+02	7.5021E+00
$\alpha_2$	3.66E-03	1.21E-02	1.09E-02	2.44E-02	7.08E-04	3.3832E+00	2.7716E+02
$\alpha_3$	9.19E-04	6.21E-03	5.08E-03	1.53E-02	4.60E-05	1.7409E+00	2.7880E+02
$\alpha_4$	2.89E-04	4.09E-03	2.99E-03	1.16E-02	1.84E-06	1.1466E+00	2.7940E+02
$\alpha_5$	4.59E-05	2.52E-03	1.48E-03	8.55E-03	0.00E+00	7.0833E-01	2.7983E+02
$\alpha_6$	7.40E-07	1.31E-03	4.28E-04	5.60E-03	0.00E+00	3.6696E-01	2.8018E+02
$\alpha_7$	5.80E-14	4.38E-04	7.88E-06	2.50E-03	0.00E+00	1.2297E-01	2.8042E+02
$\alpha_8$	1.09E-42	1.18E-04	1.68E-12	4.99E-04	0.00E+00	3.3124E-02	2.8051E+02

PWR Steam Generator PORV

PWR MAIN STEAM PORV FAIL TO OPEN SPAR: ADV-CC

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9998750	0.9997550	0.9996320	0.9995290	0.9994310	0.9993340	0.9992440
$\alpha_2$	1.25E-04	2.45E-04	3.68E-04	4.62E-04	5.49E-04	6.33E-04	7.08E-04
$\alpha_3$		0.00E+00	0.00E+00	8.83E-06	1.96E-05	3.36E-05	4.60E-05
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.84E-06
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	9.99E-01	9.99E-01	9.99E-01
Beta	1.25E-04	2.45E-04	3.68E-04	4.71E-04	5.69E-04	6.66E-04	7.56E-04
Gamma		0.00E+00	0.00E+00	1.88E-02	3.45E-02	5.05E-02	6.33E-02
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.85E-02
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	13.50	20.25	27.00	33.75	40.50	47.25	54.00
N <sub>1</sub>	0.0967	0.1400	0.1800	0.2175	0.2523	0.2845	0.3143
N <sub>2</sub>	0.0017	0.0050	0.0100	0.0157	0.0224	0.0301	0.0385
N <sub>3</sub>		0.0000	0.0000	0.0003	0.0008	0.0016	0.0025
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0001
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

**1.9.2 PWR Steam Generator PORV****1.9.2.1 PWR MAIN STEAM PORV FAIL TO OPEN SPAR: ADV-CC**

System :

Main steam

Component :

Power Operated Relief Valve

Failure Mode :

Fail to open on demand

Plant Type :

PWR

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 73.10

Total Number of Common-Cause Failure Events: 6

PWR Steam Generator PORV

PWR MAIN STEAM PORV FAIL TO OPEN SPAR: ADV-CC

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9051960	0.9650070	0.9731650	0.9968730	0.9673840	3.4982E+01	1.2685E+00
$\alpha_2$	3.13E-03	3.50E-02	2.68E-02	9.48E-02	3.26E-02	1.2685E+00	3.4982E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9087430	0.9556880	0.9600920	0.9875720	0.9488030	6.5039E+01	3.0156E+00
$\alpha_2$	8.29E-03	3.61E-02	3.16E-02	7.91E-02	4.33E-02	2.4547E+00	6.5600E+01
$\alpha_3$	5.80E-05	8.24E-03	4.16E-03	3.03E-02	7.85E-03	5.6092E-01	6.7494E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9207720	0.9584230	0.9615350	0.9854270	0.9555690	9.3090E+01	4.0383E+00
$\alpha_2$	4.88E-03	2.33E-02	2.01E-02	5.27E-02	2.11E-02	2.2652E+00	9.4863E+01
$\alpha_3$	1.44E-03	1.41E-02	1.10E-02	3.77E-02	1.97E-02	1.3742E+00	9.5754E+01
$\alpha_4$	4.21E-06	4.11E-03	1.49E-03	1.71E-02	3.59E-03	3.9887E-01	9.6729E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9361030	0.9632800	0.9651940	0.9839380	0.9612620	1.5464E+02	5.8948E+00
$\alpha_2$	4.59E-03	1.76E-02	1.56E-02	3.73E-02	1.17E-02	2.8255E+00	1.5771E+02
$\alpha_3$	1.94E-03	1.17E-02	9.77E-03	2.82E-02	1.49E-02	1.8831E+00	1.5865E+02
$\alpha_4$	3.40E-04	6.33E-03	4.43E-03	1.88E-02	1.05E-02	1.0160E+00	1.5952E+02
$\alpha_5$	9.05E-11	1.06E-03	6.87E-05	5.69E-03	1.61E-03	1.7018E-01	1.6036E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9408610	0.9649300	0.9665170	0.9835720	0.9653100	1.8692E+02	6.7935E+00
$\alpha_2$	3.90E-03	1.48E-02	1.32E-02	3.13E-02	8.64E-03	2.8655E+00	1.9085E+02
$\alpha_3$	1.34E-03	9.01E-03	7.39E-03	2.22E-02	8.34E-03	1.7462E+00	1.9197E+02
$\alpha_4$	7.71E-04	7.27E-03	5.66E-03	1.93E-02	1.13E-02	1.4087E+00	1.9230E+02
$\alpha_5$	4.12E-05	3.31E-03	1.83E-03	1.16E-02	5.78E-03	6.4090E-01	1.9307E+02
$\alpha_6$	4.67E-13	6.83E-04	1.71E-05	3.85E-03	6.76E-04	1.3224E-01	1.9358E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9472650	0.9667500	0.9678740	0.9823820	0.9680710	2.6549E+02	9.1313E+00
$\alpha_2$	4.53E-03	1.37E-02	1.26E-02	2.69E-02	8.16E-03	3.7742E+00	2.7085E+02
$\alpha_3$	1.28E-03	7.24E-03	6.09E-03	1.72E-02	4.25E-03	1.9891E+00	2.7263E+02
$\alpha_4$	8.36E-04	6.05E-03	4.90E-03	1.52E-02	7.99E-03	1.6609E+00	2.7296E+02
$\alpha_5$	3.51E-04	4.41E-03	3.29E-03	1.23E-02	8.21E-03	1.2124E+00	2.7341E+02
$\alpha_6$	3.29E-06	1.62E-03	6.60E-04	6.48E-03	3.07E-03	4.4458E-01	2.7418E+02
$\alpha_7$	2.21E-29	1.82E-04	2.07E-09	9.72E-04	2.50E-04	5.0071E-02	2.7457E+02

PWR Steam Generator PORV

PWR MAIN STEAM PORV FAIL TO OPEN SPAR: ADV-CC

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9502770	0.9678940	0.9688610	0.9822210	0.9699730	3.1159E+02	1.0336E+01
$\alpha_2$	4.55E-03	1.29E-02	1.19E-02	2.47E-02	8.44E-03	4.1529E+00	3.1777E+02
$\alpha_3$	1.09E-03	6.17E-03	5.18E-03	1.46E-02	2.58E-03	1.9850E+00	3.1994E+02
$\alpha_4$	6.12E-04	4.86E-03	3.88E-03	1.25E-02	4.36E-03	1.5640E+00	3.2036E+02
$\alpha_5$	4.66E-04	4.39E-03	3.41E-03	1.16E-02	7.36E-03	1.4127E+00	3.2051E+02
$\alpha_6$	1.16E-04	2.84E-03	1.90E-03	8.77E-03	5.72E-03	9.1486E-01	3.2101E+02
$\alpha_7$	2.74E-08	8.26E-04	1.63E-04	3.93E-03	1.49E-03	2.6607E-01	3.2166E+02
$\alpha_8$	6.78E-36	1.25E-04	5.67E-11	6.00E-04	7.31E-05	4.0124E-02	3.2189E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9673840	0.9488030	0.9555690	0.9612620	0.9653100	0.9680710	0.9699730
$\alpha_2$	3.26E-02	4.33E-02	2.11E-02	1.17E-02	8.64E-03	8.16E-03	8.44E-03
$\alpha_3$		7.85E-03	1.97E-02	1.49E-02	8.34E-03	4.25E-03	2.58E-03
$\alpha_4$			3.59E-03	1.05E-02	1.13E-02	7.99E-03	4.36E-03
$\alpha_5$				1.61E-03	5.78E-03	8.21E-03	7.36E-03
$\alpha_6$					6.76E-04	3.07E-03	5.72E-03
$\alpha_7$						2.50E-04	1.49E-03
$\alpha_8$							7.31E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.67E-01	9.49E-01	9.56E-01	9.61E-01	9.65E-01	9.68E-01	9.70E-01
<b>Beta</b>	3.26E-02	5.12E-02	4.44E-02	3.87E-02	3.47E-02	3.19E-02	3.00E-02
<b>Gamma</b>		1.53E-01	5.25E-01	6.98E-01	7.51E-01	7.44E-01	7.19E-01
<b>Delta</b>			1.54E-01	4.49E-01	6.80E-01	8.21E-01	8.81E-01
<b>Epsilon</b>				1.32E-01	3.64E-01	5.91E-01	7.71E-01
<b>Mu</b>					1.05E-01	2.88E-01	4.98E-01
<b>Upsilon</b>						7.52E-02	2.15E-01
<b>Sigma</b>							4.66E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	21.92	32.88	43.84	54.80	65.76	76.72	87.68
<b>N<sub>1</sub></b>	2.8165	2.6038	3.1137	3.6755	4.2206	4.7242	5.1836
<b>N<sub>2</sub></b>	0.8340	1.6210	1.0371	0.7113	0.6263	0.6864	0.8082
<b>N<sub>3</sub></b>		0.2937	0.9699	0.9057	0.6044	0.3579	0.2466
<b>N<sub>4</sub></b>			0.1762	0.6416	0.8165	0.6720	0.4175
<b>N<sub>5</sub></b>				0.0979	0.4187	0.6906	0.7044
<b>N<sub>6</sub></b>					0.0490	0.2583	0.5479
<b>N<sub>7</sub></b>						0.0210	0.1431
<b>N<sub>8</sub></b>							0.0070

PWR Steam Generator PORV

PWR MAIN STEAM PORV FAIL TO CLOSE SPAR: ADV-OO

### 1.9.2.2 PWR MAIN STEAM PORV FAIL TO CLOSE SPAR: ADV-OO

System :	Main steam
Component :	Power Operated Relief Valve
Failure Mode :	Fail to close (reseat) on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 22.00

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9199030	0.9799710	0.9917700	0.9999590	0.9998470	2.1343E+01	4.3622E-01
$\alpha_2$	3.75E-05	2.00E-02	8.23E-03	8.01E-02	1.53E-04	4.3622E-01	2.1343E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9331950	0.9766200	0.9829380	0.9984430	0.9997000	4.6195E+01	1.1059E+00
$\alpha_2$	5.72E-04	1.77E-02	1.15E-02	5.60E-02	3.00E-04	8.3866E-01	4.6462E+01
$\alpha_3$	1.98E-07	5.65E-03	1.14E-03	2.68E-02	0.00E+00	2.6722E-01	4.7034E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9363210	0.9734250	0.9777880	0.9956060	0.9995490	6.8316E+01	1.8651E+00
$\alpha_2$	1.48E-03	1.76E-02	1.33E-02	4.86E-02	4.51E-04	1.2381E+00	6.8943E+01
$\alpha_3$	6.48E-06	5.76E-03	2.13E-03	2.38E-02	0.00E+00	4.0431E-01	6.9777E+01
$\alpha_4$	1.37E-08	3.17E-03	4.34E-04	1.59E-02	0.00E+00	2.2267E-01	6.9958E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9447500	0.9721090	0.9745460	0.9911400	0.9994230	1.2388E+02	3.5542E+00
$\alpha_2$	3.24E-03	1.67E-02	1.43E-02	3.86E-02	5.66E-04	2.1299E+00	1.2530E+02
$\alpha_3$	3.75E-04	7.67E-03	5.30E-03	2.31E-02	1.08E-05	9.7768E-01	1.2646E+02
$\alpha_4$	1.93E-06	2.94E-03	9.89E-04	1.25E-02	0.00E+00	3.7439E-01	1.2706E+02
$\alpha_5$	4.68E-21	5.67E-04	3.21E-07	3.28E-03	0.00E+00	7.2277E-02	1.2736E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9475430	0.9721550	0.9741710	0.9898830	0.9993030	1.5019E+02	4.3019E+00
$\alpha_2$	3.04E-03	1.46E-02	1.26E-02	3.32E-02	6.73E-04	2.2616E+00	1.5223E+02
$\alpha_3$	5.21E-04	7.40E-03	5.41E-03	2.11E-02	2.40E-05	1.1426E+00	1.5335E+02
$\alpha_4$	3.42E-05	3.83E-03	2.01E-03	1.38E-02	0.00E+00	5.9222E-01	1.5390E+02
$\alpha_5$	6.01E-09	1.44E-03	1.95E-04	7.21E-03	0.00E+00	2.2220E-01	1.5427E+02
$\alpha_6$	9.12E-19	5.39E-04	9.42E-07	3.14E-03	0.00E+00	8.3237E-02	1.5441E+02

PWR Steam Generator PORV

PWR MAIN STEAM PORV FAIL TO CLOSE SPAR: ADV-OO

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9517690	0.9717550	0.9731190	0.9870960	0.9991830	2.2283E+02	6.4767E+00
$\alpha_2$	3.86E-03	1.36E-02	1.22E-02	2.81E-02	7.75E-04	3.1179E+00	2.2619E+02
$\alpha_3$	9.60E-04	7.12E-03	5.75E-03	1.80E-02	4.12E-05	1.6328E+00	2.2767E+02
$\alpha_4$	2.16E-04	4.31E-03	2.98E-03	1.29E-02	0.00E+00	9.8887E-01	2.2832E+02
$\alpha_5$	1.12E-05	2.28E-03	1.08E-03	8.60E-03	0.00E+00	5.2177E-01	2.2878E+02
$\alpha_6$	2.93E-10	8.12E-04	6.93E-05	4.26E-03	0.00E+00	1.8628E-01	2.2912E+02
$\alpha_7$	0.00E+00	1.27E-04	1.11E-13	4.77E-04	0.00E+00	2.9071E-02	2.2928E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9541360	0.9722700	0.9734240	0.9864510	0.9990730	2.6304E+02	7.5021E+00
$\alpha_2$	3.79E-03	1.25E-02	1.13E-02	2.53E-02	8.68E-04	3.3832E+00	2.6716E+02
$\alpha_3$	9.53E-04	6.43E-03	5.27E-03	1.59E-02	5.64E-05	1.7409E+00	2.6880E+02
$\alpha_4$	3.00E-04	4.24E-03	3.10E-03	1.21E-02	2.25E-06	1.1466E+00	2.6940E+02
$\alpha_5$	4.76E-05	2.62E-03	1.54E-03	8.86E-03	0.00E+00	7.0833E-01	2.6983E+02
$\alpha_6$	7.67E-07	1.36E-03	4.44E-04	5.80E-03	0.00E+00	3.6696E-01	2.7018E+02
$\alpha_7$	6.02E-14	4.55E-04	8.17E-06	2.59E-03	0.00E+00	1.2297E-01	2.7042E+02
$\alpha_8$	1.13E-42	1.22E-04	1.74E-12	5.17E-04	0.00E+00	3.3124E-02	2.7051E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9998470	0.9997000	0.9995490	0.9994230	0.9993030	0.9991830	0.9990730
$\alpha_2$	1.53E-04	3.00E-04	4.51E-04	5.66E-04	6.73E-04	7.75E-04	8.68E-04
$\alpha_3$		0.00E+00	0.00E+00	1.08E-05	2.40E-05	4.12E-05	5.64E-05
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.25E-06
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	1.00E+00	1.00E+00	1.00E+00	9.99E-01	9.99E-01	9.99E-01	9.99E-01
<b>Beta</b>	1.53E-04	3.00E-04	4.51E-04	5.77E-04	6.97E-04	8.17E-04	9.27E-04
<b>Gamma</b>		0.00E+00	0.00E+00	1.88E-02	3.45E-02	5.05E-02	6.33E-02
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.85E-02
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	11.00	16.50	22.00	27.50	33.00	38.50	44.00
N <sub>1</sub>	0.0967	0.1400	0.1800	0.2175	0.2523	0.2845	0.3143
N <sub>2</sub>	0.0017	0.0050	0.0100	0.0157	0.0224	0.0301	0.0385
N <sub>3</sub>		0.0000	0.0000	0.0003	0.0008	0.0016	0.0025
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0001
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

### 1.9.3 PWR Pressurizer Power Operated Relief Valves

#### 1.9.3.1 PRESSURIZER PORVS FAIL TO OPEN SPAR: PPR-SRV-CC

System : Reactor coolant  
 Component : Power Operated Relief Valve  
 Failure Mode : Fail to open on demand  
 Plant Type : PWR  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 16.10

Total Number of Common-Cause Failure Events: 2

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9339620	0.9832650	0.9928760	0.9999570	0.9987860	2.6706E+01	4.5452E-01
$\alpha_2$	3.98E-05	1.67E-02	7.13E-03	6.60E-02	1.21E-03	4.5452E-01	2.6706E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9411230	0.9790980	0.9845380	0.9984670	0.9977320	5.4191E+01	1.1569E+00
$\alpha_2$	6.09E-04	1.60E-02	1.07E-02	4.97E-02	2.19E-03	8.8766E-01	5.4460E+01
$\alpha_3$	1.84E-07	4.86E-03	9.92E-04	2.30E-02	8.10E-05	2.6922E-01	5.5079E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9427760	0.9757700	0.9795800	0.9957340	0.9968190	7.8919E+01	1.9597E+00
$\alpha_2$	1.57E-03	1.64E-02	1.26E-02	4.42E-02	2.96E-03	1.3253E+00	7.9553E+01
$\alpha_3$	6.42E-06	5.09E-03	1.92E-03	2.09E-02	2.19E-04	4.1151E-01	8.0467E+01
$\alpha_4$	1.20E-08	2.76E-03	3.77E-04	1.38E-02	6.08E-06	2.2287E-01	8.0656E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9987860	0.9977320	0.9968190
$\alpha_2$	1.21E-03	2.19E-03	2.96E-03
$\alpha_3$		8.10E-05	2.19E-04
$\alpha_4$			6.08E-06

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.99E-01	9.98E-01	9.97E-01
Beta	1.21E-03	2.27E-03	3.18E-03
Gamma		3.57E-02	7.07E-02
Delta			2.70E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	16.10	24.15	32.20
N <sub>1</sub>	0.3600	0.4860	0.5832
N <sub>2</sub>	0.0200	0.0540	0.0972
N <sub>3</sub>		0.0020	0.0072
N <sub>4</sub>			0.0002

**1.9.3.2 PWR PRESSURIZER PORVS FAIL TO CLOSE**

System :

Reactor coolant

Component :

Power Operated Relief Valve

Failure Mode :

Fail to close (reseat) on demand

Plant Type :

PWR

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 4.00

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8819910	0.9704020	0.9877120	0.9999410	1.0000000	1.4246E+01	4.3452E-01
$\alpha_2$	5.49E-05	2.96E-02	1.23E-02	1.18E-01	0.00E+00	4.3452E-01	1.4246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9094830	0.9682340	0.9767350	0.9978890	1.0000000	3.3555E+01	1.1009E+00
$\alpha_2$	7.68E-04	2.41E-02	1.57E-02	7.59E-02	0.00E+00	8.3366E-01	3.3822E+01
$\alpha_3$	2.71E-07	7.71E-03	1.56E-03	3.66E-02	0.00E+00	2.6722E-01	3.4389E+01

PWR Pressurizer Power Operated Relief Valves

PWR PRESSURIZER PORVS FAIL TO CLOSE

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9147120	0.9643190	0.9701040	0.9941100	1.0000000	5.0136E+01	1.8551E+00
$\alpha_2$	1.96E-03	2.36E-02	1.78E-02	6.51E-02	0.00E+00	1.2281E+00	5.0763E+01
$\alpha_3$	8.78E-06	7.78E-03	2.89E-03	3.21E-02	0.00E+00	4.0431E-01	5.1587E+01
$\alpha_4$	1.85E-08	4.28E-03	5.88E-04	2.15E-02	0.00E+00	2.2267E-01	5.1768E+01

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00
$\alpha_4$			0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00
Delta			0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	4.00	4.00	4.00
$N_1$	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000
$N_4$			0.0000

## 1.10 Main Steam Isolation Valves

### 1.10.1 PWR Main Steam Isolation Valves

#### 1.10.1.1 PWR MSIV FAIL TO OPEN

System :	Main steam
Component :	Main Steam Stop Valve
Failure Mode :	Fail to open on demand
Plant Type :	PWR
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 15.80

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9148400	0.9748620	0.9852180	0.9995830	0.9848940	2.6546E+01	6.8452E-01
$\alpha_2$	4.15E-04	2.51E-02	1.48E-02	8.52E-02	1.51E-02	6.8452E-01	2.6546E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9271210	0.9710140	0.9764980	0.9961420	0.9796540	5.3630E+01	1.6009E+00
$\alpha_2$	1.76E-03	2.19E-02	1.64E-02	6.07E-02	1.53E-02	1.2087E+00	5.4022E+01
$\alpha_3$	6.52E-06	7.10E-03	2.55E-03	2.96E-02	5.09E-03	3.9222E-01	5.4839E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9313440	0.9684260	0.9722240	0.9925010	0.9788710	7.7986E+01	2.5426E+00
$\alpha_2$	2.64E-03	1.99E-02	1.61E-02	5.03E-02	1.15E-02	1.6031E+00	7.8925E+01
$\alpha_3$	1.10E-04	8.13E-03	4.57E-03	2.82E-02	7.68E-03	6.5431E-01	7.9874E+01
$\alpha_4$	2.37E-07	3.54E-03	7.99E-04	1.65E-02	1.92E-03	2.8517E-01	8.0243E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9417530	0.9689600	0.9711640	0.9886230	0.9799200	1.3582E+02	4.3509E+00
$\alpha_2$	3.89E-03	1.73E-02	1.51E-02	3.84E-02	7.72E-03	2.4267E+00	1.3774E+02
$\alpha_3$	8.31E-04	9.20E-03	7.00E-03	2.51E-02	7.72E-03	1.2899E+00	1.3888E+02
$\alpha_4$	2.03E-05	3.79E-03	1.82E-03	1.42E-02	3.86E-03	5.3069E-01	1.3964E+02
$\alpha_5$	1.20E-15	7.39E-04	5.42E-06	4.29E-03	7.73E-04	1.0358E-01	1.4007E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9451830	0.9695200	0.9713460	0.9876040	0.9815910	1.6443E+02	5.1694E+00
$\alpha_2$	3.33E-03	1.46E-02	1.27E-02	3.22E-02	4.84E-03	2.4736E+00	1.6713E+02
$\alpha_3$	9.61E-04	8.57E-03	6.74E-03	2.25E-02	6.46E-03	1.4543E+00	1.6815E+02
$\alpha_4$	1.48E-04	4.87E-03	3.12E-03	1.56E-02	4.84E-03	8.2662E-01	1.6877E+02
$\alpha_5$	3.18E-07	1.86E-03	4.95E-04	8.38E-03	1.94E-03	3.1600E-01	1.6928E+02
$\alpha_6$	2.46E-16	5.83E-04	3.23E-06	3.39E-03	3.22E-04	9.8837E-02	1.6950E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9503810	0.9700850	0.9713450	0.9854750	0.9833460	2.3940E+02	7.3825E+00
$\alpha_2$	3.87E-03	1.32E-02	1.19E-02	2.69E-02	2.92E-03	3.2519E+00	2.4353E+02
$\alpha_3$	1.29E-03	7.72E-03	6.43E-03	1.85E-02	4.86E-03	1.9046E+00	2.4488E+02
$\alpha_4$	4.42E-04	5.12E-03	3.86E-03	1.41E-02	4.86E-03	1.2623E+00	2.4552E+02
$\alpha_5$	4.49E-05	2.78E-03	1.60E-03	9.52E-03	2.92E-03	6.8587E-01	2.4610E+02
$\alpha_6$	1.09E-08	9.76E-04	1.58E-04	4.78E-03	9.72E-04	2.4098E-01	2.4654E+02
$\alpha_7$	1.22E-38	1.49E-04	1.61E-11	6.83E-04	1.39E-04	3.6871E-02	2.4675E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9531740	0.9709840	0.9720570	0.9851200	0.9849680	2.8196E+02	8.4260E+00
$\alpha_2$	3.67E-03	1.19E-02	1.08E-02	2.39E-02	1.70E-03	3.4541E+00	2.8693E+02
$\alpha_3$	1.17E-03	6.74E-03	5.65E-03	1.60E-02	3.41E-03	1.9572E+00	2.8843E+02
$\alpha_4$	5.25E-04	4.89E-03	3.81E-03	1.29E-02	4.26E-03	1.4199E+00	2.8897E+02
$\alpha_5$	1.35E-04	3.19E-03	2.15E-03	9.81E-03	3.41E-03	9.2713E-01	2.8946E+02
$\alpha_6$	4.97E-06	1.64E-03	7.16E-04	6.41E-03	1.70E-03	4.7636E-01	2.8991E+02
$\alpha_7$	8.04E-12	5.31E-04	2.45E-05	2.91E-03	4.88E-04	1.5427E-01	2.9023E+02
$\alpha_8$	1.45E-38	1.27E-04	1.48E-11	5.84E-04	6.08E-05	3.7024E-02	2.9035E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9848940	0.9796540	0.9788710	0.9799200	0.9815910	0.9833460	0.9849680
$\alpha_2$	1.51E-02	1.53E-02	1.15E-02	7.72E-03	4.84E-03	2.92E-03	1.70E-03
$\alpha_3$		5.09E-03	7.68E-03	7.72E-03	6.46E-03	4.86E-03	3.41E-03
$\alpha_4$			1.92E-03	3.86E-03	4.84E-03	4.86E-03	4.26E-03
$\alpha_5$				7.73E-04	1.94E-03	2.92E-03	3.41E-03
$\alpha_6$					3.22E-04	9.72E-04	1.70E-03
$\alpha_7$						1.39E-04	4.88E-04
$\alpha_8$							6.08E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.85E-01	9.80E-01	9.79E-01	9.80E-01	9.82E-01	9.83E-01	9.85E-01
<b>Beta</b>	1.51E-02	2.03E-02	2.11E-02	2.01E-02	1.84E-02	1.67E-02	1.50E-02
<b>Gamma</b>		2.50E-01	4.55E-01	6.15E-01	7.37E-01	8.25E-01	8.87E-01
<b>Delta</b>			2.00E-01	3.75E-01	5.24E-01	6.46E-01	7.44E-01
<b>Epsilon</b>				1.67E-01	3.18E-01	4.53E-01	5.71E-01
<b>Mu</b>					1.43E-01	2.76E-01	3.98E-01
<b>Upsilon</b>						1.25E-01	2.43E-01
<b>Sigma</b>							1.11E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	15.80	23.70	31.60	39.50	47.40	55.30	63.20
<b>N<sub>1</sub></b>	0.5000	0.3750	0.2500	0.1563	0.0938	0.0547	0.0313
<b>N<sub>2</sub></b>	0.2500	0.3750	0.3750	0.3125	0.2344	0.1641	0.1094
<b>N<sub>3</sub></b>		0.1250	0.2500	0.3125	0.3125	0.2734	0.2188
<b>N<sub>4</sub></b>			0.0625	0.1563	0.2344	0.2734	0.2734
<b>N<sub>5</sub></b>				0.0313	0.0938	0.1641	0.2188
<b>N<sub>6</sub></b>					0.0156	0.0547	0.1094
<b>N<sub>7</sub></b>						0.0078	0.0313
<b>N<sub>8</sub></b>							0.0039

### 1.10.1.2 PWR MSIV FAIL TO CLOSE

System : Main steam  
 Component : Main Steam Stop Valve  
 Failure Mode : Fail to close (reseat) on demand  
 Plant Type : PWR  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 26.30

Total Number of Common-Cause Failure Events: 4

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8722360	0.9553240	0.9673570	0.9971950	0.9520950	2.2833E+01	1.0678E+00
$\alpha_2$	2.80E-03	4.47E-02	3.26E-02	1.28E-01	4.79E-02	1.0678E+00	2.2833E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8864920	0.9466730	0.9525750	0.9866350	0.9186570	4.7060E+01	2.6509E+00
$\alpha_2$	9.15E-03	4.44E-02	3.84E-02	1.00E-01	7.22E-02	2.2087E+00	4.7502E+01
$\alpha_3$	1.77E-05	8.90E-03	3.65E-03	3.56E-02	9.18E-03	4.4222E-01	4.9269E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8868610	0.9387530	0.9427560	0.9769490	0.8945780	6.8093E+01	4.4426E+00
$\alpha_2$	1.38E-02	4.55E-02	4.14E-02	9.14E-02	8.45E-02	3.3031E+00	6.9232E+01
$\alpha_3$	3.99E-04	1.18E-02	7.69E-03	3.71E-02	1.83E-02	8.5431E-01	7.1681E+01
$\alpha_4$	2.63E-07	3.93E-03	8.87E-04	1.83E-02	2.55E-03	2.8517E-01	7.2250E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9148130	0.9497250	0.9520290	0.9767770	0.9004790	1.2312E+02	6.5175E+00
$\alpha_2$	9.61E-03	2.90E-02	2.66E-02	5.66E-02	5.50E-02	3.7600E+00	1.2588E+02
$\alpha_3$	3.16E-03	1.64E-02	1.40E-02	3.79E-02	3.83E-02	2.1232E+00	1.2751E+02
$\alpha_4$	2.20E-05	4.09E-03	1.97E-03	1.54E-02	5.22E-03	5.3069E-01	1.2911E+02
$\alpha_5$	1.30E-15	7.99E-04	5.86E-06	4.64E-03	1.05E-03	1.0358E-01	1.2953E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9218390	0.9525950	0.9545120	0.9767990	0.9110170	1.4909E+02	7.4193E+00
$\alpha_2$	5.84E-03	2.02E-02	1.82E-02	4.15E-02	2.63E-02	3.1680E+00	1.5334E+02
$\alpha_3$	4.95E-03	1.85E-02	1.65E-02	3.90E-02	4.98E-02	2.8987E+00	1.5361E+02
$\alpha_4$	2.62E-04	5.99E-03	4.06E-03	1.83E-02	9.79E-03	9.3772E-01	1.5557E+02
$\alpha_5$	3.45E-07	2.02E-03	5.37E-04	9.08E-03	2.66E-03	3.1600E-01	1.5619E+02
$\alpha_6$	2.67E-16	6.32E-04	3.50E-06	3.67E-03	4.42E-04	9.8837E-02	1.5641E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9344590	0.9581080	0.9594270	0.9772670	0.9203290	2.2145E+02	9.6826E+00
$\alpha_2$	5.51E-03	1.65E-02	1.52E-02	3.23E-02	1.81E-02	3.8232E+00	2.2731E+02
$\alpha_3$	3.50E-03	1.29E-02	1.15E-02	2.69E-02	3.30E-02	2.9741E+00	2.2816E+02
$\alpha_4$	1.35E-03	8.15E-03	6.79E-03	1.96E-02	2.20E-02	1.8846E+00	2.2925E+02
$\alpha_5$	6.12E-05	3.13E-03	1.86E-03	1.05E-02	4.95E-03	7.2287E-01	2.3041E+02
$\alpha_6$	1.16E-08	1.04E-03	1.69E-04	5.10E-03	1.35E-03	2.4098E-01	2.3089E+02
$\alpha_7$	1.30E-38	1.60E-04	1.72E-11	7.29E-04	1.92E-04	3.6871E-02	2.3110E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9392500	0.9603970	0.9615230	0.9777070	0.9278360	2.6138E+02	1.0778E+01
$\alpha_2$	4.95E-03	1.45E-02	1.33E-02	2.81E-02	1.32E-02	3.9516E+00	2.6821E+02
$\alpha_3$	2.58E-03	1.01E-02	8.98E-03	2.17E-02	2.23E-02	2.7622E+00	2.6940E+02
$\alpha_4$	1.62E-03	8.08E-03	6.91E-03	1.85E-02	2.29E-02	2.1987E+00	2.6996E+02
$\alpha_5$	3.31E-04	4.36E-03	3.22E-03	1.23E-02	1.04E-02	1.1858E+00	2.7097E+02
$\alpha_6$	6.26E-06	1.80E-03	8.02E-04	6.95E-03	2.65E-03	4.8866E-01	2.7167E+02
$\alpha_7$	8.58E-12	5.67E-04	2.62E-05	3.10E-03	6.81E-04	1.5427E-01	2.7200E+02
$\alpha_8$	1.54E-38	1.36E-04	1.58E-11	6.23E-04	8.48E-05	3.7024E-02	2.7212E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9520950	0.9186570	0.8945780	0.9004790	0.9110170	0.9203290	0.9278360
$\alpha_2$	4.79E-02	7.22E-02	8.45E-02	5.50E-02	2.63E-02	1.81E-02	1.32E-02
$\alpha_3$		9.18E-03	1.83E-02	3.83E-02	4.98E-02	3.30E-02	2.23E-02
$\alpha_4$			2.55E-03	5.22E-03	9.79E-03	2.20E-02	2.29E-02
$\alpha_5$				1.05E-03	2.66E-03	4.95E-03	1.04E-02
$\alpha_6$					4.42E-04	1.35E-03	2.65E-03
$\alpha_7$						1.92E-04	6.81E-04
$\alpha_8$							8.48E-05

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.52E-01	9.19E-01	8.95E-01	9.00E-01	9.11E-01	9.20E-01	9.28E-01
<b>Beta</b>	4.79E-02	8.13E-02	1.05E-01	9.95E-02	8.90E-02	7.97E-02	7.22E-02
<b>Gamma</b>		1.13E-01	1.98E-01	4.48E-01	7.04E-01	7.73E-01	8.17E-01
<b>Delta</b>			1.22E-01	1.41E-01	2.06E-01	4.63E-01	6.22E-01
<b>Epsilon</b>				1.67E-01	2.40E-01	2.27E-01	3.76E-01
<b>Mu</b>					1.43E-01	2.37E-01	2.47E-01
<b>Upsilon</b>						1.25E-01	2.24E-01
<b>Sigma</b>							1.11E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	10.52	15.78	21.04	26.30	31.56	36.82	42.08
<b>N<sub>1</sub></b>	2.0667	1.7250	0.9167	0.6563	0.5938	0.5797	0.5713
<b>N<sub>2</sub></b>	0.6333	1.3750	2.0750	1.6458	0.9288	0.7354	0.6069
<b>N<sub>3</sub></b>		0.1750	0.4500	1.1458	1.7569	1.3429	1.0238
<b>N<sub>4</sub></b>			0.0625	0.1563	0.3455	0.8957	1.0522
<b>N<sub>5</sub></b>				0.0313	0.0938	0.2011	0.4775
<b>N<sub>6</sub></b>					0.0156	0.0547	0.1217
<b>N<sub>7</sub></b>						0.0078	0.0313
<b>N<sub>8</sub></b>							0.0039

## 1.10.2BWR Main Steam Isolation Valves

### 1.10.2.1 BWR MSIV FAIL TO OPEN

Component :	Main Steam Stop Valve
Failure Mode :	Fail to open on demand
Plant Type :	BWR
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 3.50

Total Number of Common-Cause Failure Events: 1

### ALPHA FACTOR DISTRIBUTIONS

#### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8513580	0.9625750	0.9842830	0.9999310	1.0000000	1.1176E+01	4.3452E-01
$\alpha_2$	7.04E-05	3.74E-02	1.57E-02	1.49E-01	0.00E+00	4.3452E-01	1.1176E+01

#### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9022300	0.9656380	0.9747930	0.9977110	0.9999280	3.0940E+01	1.1010E+00
$\alpha_2$	8.33E-04	2.60E-02	1.70E-02	8.21E-02	7.22E-05	8.3376E-01	3.1207E+01
$\alpha_3$	2.94E-07	8.34E-03	1.69E-03	3.96E-02	0.00E+00	2.6722E-01	3.1774E+01

#### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9110910	0.9627760	0.9687980	0.9938470	0.9998920	4.7986E+01	1.8553E+00
$\alpha_2$	2.05E-03	2.46E-02	1.86E-02	6.79E-02	1.08E-04	1.2283E+00	4.8613E+01
$\alpha_3$	9.16E-06	8.11E-03	3.02E-03	3.35E-02	0.00E+00	4.0431E-01	4.9437E+01
$\alpha_4$	1.93E-08	4.47E-03	6.13E-04	2.24E-02	0.00E+00	2.2267E-01	4.9619E+01

#### **CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9313770	0.9653120	0.9683150	0.9889800	0.9998270	9.8475E+01	3.5386E+00
$\alpha_2$	4.00E-03	2.07E-02	1.77E-02	4.79E-02	1.73E-04	2.1146E+00	9.9899E+01
$\alpha_3$	4.68E-04	9.58E-03	6.62E-03	2.88E-02	0.00E+00	9.7738E-01	1.0104E+02
$\alpha_4$	2.41E-06	3.67E-03	1.24E-03	1.56E-02	0.00E+00	3.7439E-01	1.0164E+02
$\alpha_5$	5.85E-21	7.09E-04	4.01E-07	4.10E-03	0.00E+00	7.2277E-02	1.0194E+02

#### **CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9350450	0.9654900	0.9679680	0.9874670	0.9998200	1.1972E+02	4.2792E+00
$\alpha_2$	3.72E-03	1.81E-02	1.55E-02	4.10E-02	1.80E-04	2.2397E+00	1.2176E+02
$\alpha_3$	6.49E-04	9.21E-03	6.74E-03	2.62E-02	0.00E+00	1.1418E+00	1.2286E+02
$\alpha_4$	4.27E-05	4.78E-03	2.50E-03	1.72E-02	0.00E+00	5.9222E-01	1.2341E+02
$\alpha_5$	7.49E-09	1.79E-03	2.43E-04	8.98E-03	0.00E+00	2.2220E-01	1.2378E+02
$\alpha_6$	1.14E-18	6.71E-04	1.17E-06	3.92E-03	0.00E+00	8.3237E-02	1.2392E+02

#### **CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9432010	0.9667270	0.9683250	0.9848010	0.9997530	1.8728E+02	6.4458E+00
$\alpha_2$	4.49E-03	1.59E-02	1.43E-02	3.30E-02	2.47E-04	3.0886E+00	1.9064E+02
$\alpha_3$	1.14E-03	8.42E-03	6.80E-03	2.12E-02	0.00E+00	1.6312E+00	1.9209E+02
$\alpha_4$	2.56E-04	5.10E-03	3.53E-03	1.53E-02	0.00E+00	9.8887E-01	1.9274E+02
$\alpha_5$	1.32E-05	2.69E-03	1.28E-03	1.02E-02	0.00E+00	5.2177E-01	1.9320E+02
$\alpha_6$	3.47E-10	9.62E-04	8.21E-05	5.05E-03	0.00E+00	1.8628E-01	1.9354E+02
$\alpha_7$	0.00E+00	1.50E-04	1.31E-13	5.65E-04	0.00E+00	2.9071E-02	1.9370E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9463270	0.9675410	0.9688920	0.9841570	0.9997300	2.2243E+02	7.4620E+00
$\alpha_2$	4.38E-03	1.46E-02	1.32E-02	2.95E-02	2.70E-04	3.3457E+00	2.2655E+02
$\alpha_3$	1.12E-03	7.56E-03	6.19E-03	1.87E-02	0.00E+00	1.7384E+00	2.2815E+02
$\alpha_4$	3.53E-04	4.99E-03	3.65E-03	1.42E-02	0.00E+00	1.1465E+00	2.2875E+02
$\alpha_5$	5.61E-05	3.08E-03	1.81E-03	1.04E-02	0.00E+00	7.0833E-01	2.2918E+02
$\alpha_6$	9.03E-07	1.60E-03	5.23E-04	6.83E-03	0.00E+00	3.6696E-01	2.2953E+02
$\alpha_7$	7.08E-14	5.35E-04	9.62E-06	3.05E-03	0.00E+00	1.2297E-01	2.2977E+02
$\alpha_8$	1.33E-42	1.44E-04	2.05E-12	6.09E-04	0.00E+00	3.3124E-02	2.2986E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	0.9999280	0.9998920	0.9998270	0.9998200	0.9997530	0.9997300
$\alpha_2$	0.00E+00	7.22E-05	1.08E-04	1.73E-04	1.80E-04	2.47E-04	2.70E-04
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	1.00E+00						
<b>Beta</b>	0.00E+00	7.22E-05	1.08E-04	1.73E-04	1.80E-04	2.47E-04	2.70E-04
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	0.88	1.31	1.75	2.19	2.63	3.06	3.50
<b>N<sub>1</sub></b>	0.0499	0.0748	0.0996	0.1243	0.1489	0.1735	0.1980
<b>N<sub>2</sub></b>	0.0000	0.0001	0.0002	0.0004	0.0005	0.0008	0.0010
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0000
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

### 1.10.2.2 BWR MSIV FAIL TO CLOSE

**Component :** Main Steam Stop Valve  
**Failure Mode :** Fail to close (reseat) on demand  
**Plant Type :** BWR  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 9.00  
Total Number of Common-Cause Failure Events: 2

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8651700	0.9648640	0.9838790	0.9998860	0.9849080	1.3157E+01	4.7912E-01
$\alpha_2$	1.16E-04	3.51E-02	1.61E-02	1.35E-01	1.51E-02	4.7912E-01	1.3157E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9036240	0.9647480	0.9731720	0.9970110	0.9693660	3.3792E+01	1.2348E+00
$\alpha_2$	1.34E-03	2.76E-02	1.93E-02	8.25E-02	3.06E-02	9.6756E-01	3.4059E+01
$\alpha_3$	2.69E-07	7.63E-03	1.54E-03	3.62E-02	0.00E+00	2.6722E-01	3.4760E+01

##### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9095910	0.9604830	0.9660640	0.9922520	0.9532640	5.1600E+01	2.1230E+00
$\alpha_2$	3.32E-03	2.78E-02	2.22E-02	7.16E-02	4.67E-02	1.4960E+00	5.2227E+01
$\alpha_3$	8.49E-06	7.53E-03	2.80E-03	3.11E-02	0.00E+00	4.0431E-01	5.3319E+01
$\alpha_4$	1.79E-08	4.14E-03	5.69E-04	2.08E-02	0.00E+00	2.2267E-01	5.3500E+01

##### **CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9285140	0.9626750	0.9655350	0.9870620	0.9367570	1.0277E+02	3.9846E+00
$\alpha_2$	5.71E-03	2.40E-02	2.11E-02	5.22E-02	6.32E-02	2.5606E+00	1.0419E+02
$\alpha_3$	4.47E-04	9.16E-03	6.33E-03	2.75E-02	0.00E+00	9.7738E-01	1.0578E+02
$\alpha_4$	2.31E-06	3.51E-03	1.18E-03	1.49E-02	0.00E+00	3.7439E-01	1.0638E+02
$\alpha_5$	5.59E-21	6.77E-04	3.83E-07	3.92E-03	0.00E+00	7.2277E-02	1.0668E+02

##### **CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9307480	0.9618040	0.9641580	0.9848090	0.9196190	1.2460E+02	4.9483E+00
$\alpha_2$	6.03E-03	2.25E-02	2.00E-02	4.71E-02	8.04E-02	2.9088E+00	1.2664E+02
$\alpha_3$	6.21E-04	8.81E-03	6.45E-03	2.51E-02	0.00E+00	1.1418E+00	1.2841E+02
$\alpha_4$	4.09E-05	4.57E-03	2.39E-03	1.65E-02	0.00E+00	5.9222E-01	1.2896E+02
$\alpha_5$	7.17E-09	1.72E-03	2.33E-04	8.59E-03	0.00E+00	2.2220E-01	1.2933E+02
$\alpha_6$	1.09E-18	6.43E-04	1.12E-06	3.75E-03	0.00E+00	8.3237E-02	1.2947E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9389120	0.9630990	0.9646360	0.9820470	0.9020120	1.9268E+02	7.3825E+00
$\alpha_2$	6.97E-03	2.01E-02	1.85E-02	3.87E-02	9.80E-02	4.0253E+00	1.9604E+02
$\alpha_3$	1.10E-03	8.15E-03	6.58E-03	2.06E-02	0.00E+00	1.6312E+00	1.9843E+02
$\alpha_4$	2.48E-04	4.94E-03	3.42E-03	1.48E-02	0.00E+00	9.8887E-01	1.9907E+02
$\alpha_5$	1.28E-05	2.61E-03	1.23E-03	9.86E-03	0.00E+00	5.2177E-01	1.9954E+02
$\alpha_6$	3.36E-10	9.31E-04	7.95E-05	4.89E-03	0.00E+00	1.8628E-01	1.9988E+02
$\alpha_7$	0.00E+00	1.45E-04	1.27E-13	5.47E-04	0.00E+00	2.9071E-02	2.0003E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9411920	0.9632360	0.9645350	0.9808530	0.8837210	2.2823E+02	8.7110E+00
$\alpha_2$	7.32E-03	1.94E-02	1.81E-02	3.60E-02	1.16E-01	4.5947E+00	2.3235E+02
$\alpha_3$	1.09E-03	7.34E-03	6.00E-03	1.81E-02	0.00E+00	1.7384E+00	2.3520E+02
$\alpha_4$	3.43E-04	4.84E-03	3.54E-03	1.38E-02	0.00E+00	1.1465E+00	2.3579E+02
$\alpha_5$	5.44E-05	2.99E-03	1.76E-03	1.01E-02	0.00E+00	7.0833E-01	2.3623E+02
$\alpha_6$	8.77E-07	1.55E-03	5.07E-04	6.62E-03	0.00E+00	3.6696E-01	2.3657E+02
$\alpha_7$	6.87E-14	5.19E-04	9.33E-06	2.95E-03	0.00E+00	1.2297E-01	2.3682E+02
$\alpha_8$	1.29E-42	1.40E-04	1.99E-12	5.91E-04	0.00E+00	3.3124E-02	2.3691E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9849080	0.9693660	0.9532640	0.9367570	0.9196190	0.9020120	0.8837210
$\alpha_2$	1.51E-02	3.06E-02	4.67E-02	6.32E-02	8.04E-02	9.80E-02	1.16E-01
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.85E-01	9.69E-01	9.53E-01	9.37E-01	9.20E-01	9.02E-01	8.84E-01
<b>Beta</b>	1.51E-02	3.06E-02	4.67E-02	6.32E-02	8.04E-02	9.80E-02	1.16E-01
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

**Main** Steam Isolation Valves  
**BWR** Main Steam Isolation Valves  
BWR MSIV FAIL TO CLOSE

2009

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	2.25	3.38	4.50	5.63	6.75	7.88	9.00
<b>N<sub>1</sub></b>	0.6607	0.8571	0.9643	0.9821	0.9107	0.7500	0.5000
<b>N<sub>2</sub></b>	0.0446	0.1339	0.2679	0.4464	0.6696	0.9375	1.2500
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0000
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

## 1.11 Generators

### 1.11.1 Emergency Diesel Generators

#### 1.11.1.1 EMERGENCY DIESEL GENERATOR SPAR:DGN-FS

System :	Emergency power supply
Component :	Generator
Failure Mode :	Fail to start
Component Group :	Emergency Diesel Generator
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 191.40

Total Number of Common-Cause Failure Events: 4

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9731360	0.9877550	0.9892860	0.9971370	0.9893020	2.0445E+02	2.5345E+00
$\alpha_2$	2.87E-03	1.22E-02	1.07E-02	2.69E-02	1.07E-02	2.5345E+00	2.0445E+02

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9788070	0.9895150	0.9905110	0.9968220	0.9921870	3.1908E+02	3.3809E+00
$\alpha_2$	1.24E-03	6.52E-03	5.54E-03	1.52E-02	4.35E-03	2.1037E+00	3.2036E+02
$\alpha_3$	3.49E-04	3.96E-03	2.99E-03	1.09E-02	3.46E-03	1.2772E+00	3.2118E+02

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9810650	0.9899640	0.9907040	0.9963380	0.9935010	4.3185E+02	4.3781E+00
$\alpha_2$	1.02E-03	5.08E-03	4.34E-03	1.16E-02	2.54E-03	2.2141E+00	4.3401E+02
$\alpha_3$	3.63E-04	3.30E-03	2.58E-03	8.71E-03	2.67E-03	1.4403E+00	4.3479E+02
$\alpha_4$	3.25E-05	1.66E-03	9.86E-04	5.57E-03	1.29E-03	7.2367E-01	4.3550E+02

#### ALPHA FACTOR and MGL PARAMETERS

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9893020	0.9921870	0.9935010
$\alpha_2$	1.07E-02	4.35E-03	2.54E-03
$\alpha_3$		3.46E-03	2.67E-03
$\alpha_4$			1.29E-03

**Emergency Diesel Generators**

EMERGENCY DIESEL GENERATOR SPAR:DGN-LR

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.89E-01	9.92E-01	9.94E-01
Beta	1.07E-02	7.81E-03	6.50E-03
Gamma		4.43E-01	6.09E-01
Delta			3.26E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	191.40	287.10	382.80
N <sub>1</sub>	2.8000	2.4300	2.9160
N <sub>2</sub>	2.1000	1.2700	0.9860
N <sub>3</sub>		1.0100	1.0360
N <sub>4</sub>			0.5010

**1.11.1.2 EMERGENCY DIESEL GENERATOR SPAR:DGN-LR**

**System :** Emergency power supply  
**Component :** Generator  
**Failure Mode :** Fail to Load/Run  
**Component Group :** Emergency Diesel Generator  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 190.50

Total Number of Common-Cause Failure Events: 3

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9773540	0.9934810	0.9963370	0.9999130	0.9975410	9.9904E+01	6.5552E-01
$\alpha_2$	8.91E-05	6.52E-03	3.67E-03	2.26E-02	2.46E-03	6.5552E-01	9.9904E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9738830	0.9893970	0.9913010	0.9984140	0.9951660	1.6340E+02	1.7511E+00
$\alpha_2$	1.03E-03	8.95E-03	7.06E-03	2.33E-02	4.79E-03	1.4775E+00	1.6367E+02
$\alpha_3$	7.33E-08	1.66E-03	3.46E-04	7.80E-03	4.76E-05	2.7362E-01	1.6488E+02

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9715350	0.9861950	0.9875990	0.9960680	0.9928610	2.2376E+02	3.1323E+00
$\alpha_2$	2.50E-03	1.09E-02	9.54E-03	2.42E-02	7.01E-03	2.4822E+00	2.2441E+02
$\alpha_3$	2.97E-06	1.88E-03	7.35E-04	7.63E-03	1.25E-04	4.2661E-01	2.2647E+02
$\alpha_4$	4.42E-09	9.85E-04	1.35E-04	4.93E-03	4.47E-06	2.2347E-01	2.2667E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9975410	0.9951660	0.9928610
$\alpha_2$	2.46E-03	4.79E-03	7.01E-03
$\alpha_3$		4.76E-05	1.25E-04
$\alpha_4$			4.47E-06

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.98E-01	9.95E-01	9.93E-01
Beta	2.46E-03	4.83E-03	7.14E-03
Gamma		9.84E-03	1.81E-02
Delta			3.46E-02

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	87.99	131.99	175.98
N <sub>1</sub>	1.6680	1.8582	1.6415
N <sub>2</sub>	0.2210	0.6438	1.2541
N <sub>3</sub>		0.0064	0.0223
N <sub>4</sub>			0.0008

**1.11.1.3 EMERGENCY DIESEL GENERATOR SPAR:DGN-FR**

System : Emergency power supply  
 Component : Generator  
 Failure Mode : Fail to run  
 Component Group : Emergency Diesel Generator  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 125.10

Total Number of Common-Cause Failure Events: 4

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9724340	0.9894730	0.9917210	0.9988200	0.9919990	1.3671E+02	1.4545E+00
$\alpha_2$	1.18E-03	1.05E-02	8.28E-03	2.76E-02	8.00E-03	1.4545E+00	1.3671E+02

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9773680	0.9901890	0.9916340	0.9980750	0.9944180	2.1769E+02	2.1569E+00
$\alpha_2$	6.51E-04	6.31E-03	4.89E-03	1.68E-02	2.93E-03	1.3877E+00	2.1846E+02
$\alpha_3$	8.47E-05	3.50E-03	2.15E-03	1.15E-02	2.65E-03	7.6922E-01	2.1908E+02

**Emergency Diesel Generators**

EMERGENCY DIESEL GENERATOR SPAR:DGN-FR

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9792880	0.9901300	0.9911950	0.9973310	0.9956150	2.9692E+02	2.9597E+00
$\alpha_2$	6.69E-04	5.25E-03	4.20E-03	1.34E-02	1.38E-03	1.5753E+00	2.9830E+02
$\alpha_3$	1.23E-04	3.04E-03	2.03E-03	9.40E-03	2.01E-03	9.1151E-01	2.9897E+02
$\alpha_4$	4.59E-06	1.58E-03	6.83E-04	6.17E-03	9.93E-04	4.7287E-01	2.9941E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4
$\alpha_1$	0.9919990	0.9944180	0.9956150
$\alpha_2$	8.00E-03	2.93E-03	1.38E-03
$\alpha_3$		2.65E-03	2.01E-03
$\alpha_4$			9.93E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4
1-Beta	9.92E-01	9.94E-01	9.96E-01
Beta	8.00E-03	5.58E-03	4.39E-03
Gamma		4.75E-01	6.86E-01
Delta			3.30E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4
Adj. Ind. Events	125.10	187.65	250.20
$N_1$	1.3600	0.4860	0.5832
$N_2$	1.0200	0.5540	0.3472
$N_3$		0.5020	0.5072
$N_4$			0.2502

## 1.12 Vacuum Breakers

### 1.12.1BWR Pressure Suppression Vacuum Breakers

#### 1.12.1.1 CONTAINMENT VACUUM RELIEF CHECK FAIL TO OPEN

System : Vapor suppression  
Component : Vacuum Breaker  
Failure Mode : Fail to open on demand  
Start Date : 1997/01/01  
Data Version : 2009/12/31

Total Number of Independent Failure Events: 6.50

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8566110	0.9592790	0.9775730	0.9995900	0.9591760	1.4163E+01	6.0122E-01
$\alpha_2$	4.09E-04	4.07E-02	2.24E-02	1.43E-01	4.08E-02	6.0122E-01	1.4163E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8906250	0.9561820	0.9642460	0.9941010	0.9149660	3.4935E+01	1.6009E+00
$\alpha_2$	3.59E-03	3.65E-02	2.84E-02	9.72E-02	8.50E-02	1.3337E+00	3.5202E+01
$\alpha_3$	2.57E-07	7.31E-03	1.48E-03	3.47E-02	0.00E+00	2.6722E-01	3.6269E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8927040	0.9485490	0.9538680	0.9861960	0.8666670	5.2636E+01	2.8551E+00
$\alpha_2$	8.33E-03	4.02E-02	3.47E-02	9.05E-02	1.33E-01	2.2281E+00	5.3263E+01
$\alpha_3$	8.22E-06	7.29E-03	2.71E-03	3.01E-02	0.00E+00	4.0431E-01	5.5087E+01
$\alpha_4$	1.73E-08	4.01E-03	5.50E-04	2.01E-02	0.00E+00	2.2267E-01	5.5268E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9228590	0.9582990	0.9610830	0.9842280	0.8904710	1.0429E+02	4.5383E+00
$\alpha_2$	6.59E-03	2.56E-02	2.27E-02	5.43E-02	7.30E-02	2.7809E+00	1.0605E+02
$\alpha_3$	1.12E-03	1.20E-02	9.21E-03	3.26E-02	3.65E-02	1.3107E+00	1.0752E+02
$\alpha_4$	2.26E-06	3.44E-03	1.16E-03	1.46E-02	0.00E+00	3.7439E-01	1.0845E+02
$\alpha_5$	5.48E-21	6.64E-04	3.76E-07	3.85E-03	0.00E+00	7.2277E-02	1.0876E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9286410	0.9600010	0.9623050	0.9834780	0.9069850	1.2669E+02	5.2786E+00
$\alpha_2$	5.06E-03	2.03E-02	1.80E-02	4.37E-02	4.13E-02	2.6836E+00	1.2928E+02
$\alpha_3$	1.56E-03	1.20E-02	9.66E-03	3.06E-02	4.13E-02	1.5862E+00	1.3038E+02
$\alpha_4$	9.48E-05	5.33E-03	3.13E-03	1.81E-02	1.03E-02	7.0332E-01	1.3127E+02
$\alpha_5$	7.04E-09	1.68E-03	2.28E-04	8.44E-03	0.00E+00	2.2220E-01	1.3175E+02
$\alpha_6$	1.07E-18	6.31E-04	1.10E-06	3.68E-03	0.00E+00	8.3237E-02	1.3189E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9591760	0.9149660	0.8666670	0.8904710	0.9069850
$\alpha_2$	4.08E-02	8.50E-02	1.33E-01	7.30E-02	4.13E-02
$\alpha_3$		0.00E+00	0.00E+00	3.65E-02	4.13E-02
$\alpha_4$			0.00E+00	0.00E+00	1.03E-02
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.59E-01	9.15E-01	8.67E-01	8.90E-01	9.07E-01
Beta	4.08E-02	8.50E-02	1.33E-01	1.10E-01	9.30E-02
Gamma		0.00E+00	0.00E+00	3.33E-01	5.56E-01
Delta			0.00E+00	0.00E+00	2.00E-01
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	3.25	4.88	6.50	8.13	9.75
$N_1$	0.6667	0.5000	0.0000	0.0000	0.0000
$N_2$	0.1667	0.5000	1.0000	0.6667	0.4444
$N_3$		0.0000	0.0000	0.3333	0.4444
$N_4$			0.0000	0.0000	0.1111
$N_5$				0.0000	0.0000
$N_6$					0.0000

## 1.13 AC Power Distribution Breakers

### 1.13.1480 Vac Circuit Breakers

#### 1.13.1.1 480 V CIRCUIT BREAKERS FAIL TO OPEN

**System :** Plant ac power  
**Component :** Circuit Breaker  
**Failure Mode :** Fail to open on demand  
**Component Group :** 480 Volt  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 12.20

Total Number of Common-Cause Failure Events: 3

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8569670	0.9631330	0.9835330	0.9999000	0.9845840	1.2117E+01	4.6382E-01
$\alpha_2$	1.02E-04	3.69E-02	1.65E-02	1.43E-01	1.54E-02	4.6382E-01	1.2117E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9020750	0.9647310	0.9735280	0.9972720	0.9717420	3.2282E+01	1.1802E+00
$\alpha_2$	1.11E-03	2.72E-02	1.84E-02	8.30E-02	2.67E-02	9.0866E-01	3.2554E+01
$\alpha_3$	3.37E-07	8.11E-03	1.69E-03	3.83E-02	1.53E-03	2.7152E-01	3.3191E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9098400	0.9613370	0.9671440	0.9929600	0.9612270	4.9684E+01	1.9982E+00
$\alpha_2$	2.64E-03	2.62E-02	2.04E-02	6.98E-02	3.46E-02	1.3557E+00	5.0326E+01
$\alpha_3$	1.16E-05	8.11E-03	3.14E-03	3.31E-02	4.04E-03	4.1921E-01	5.1263E+01
$\alpha_4$	1.93E-08	4.32E-03	5.97E-04	2.16E-02	1.63E-04	2.2327E-01	5.1459E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9299200	0.9639950	0.9669240	0.9880420	0.9527340	1.0050E+02	3.7537E+00
$\alpha_2$	4.66E-03	2.20E-02	1.90E-02	4.96E-02	3.96E-02	2.2948E+00	1.0196E+02
$\alpha_3$	5.13E-04	9.68E-03	6.78E-03	2.88E-02	7.04E-03	1.0095E+00	1.0324E+02
$\alpha_4$	2.50E-06	3.62E-03	1.23E-03	1.53E-02	5.71E-04	3.7699E-01	1.0388E+02
$\alpha_5$	6.06E-21	6.94E-04	3.97E-07	4.02E-03	2.19E-05	7.2377E-02	1.0418E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9332260	0.9639100	0.9663270	0.9863230	0.9461430	1.2207E+02	4.5705E+00
$\alpha_2$	4.46E-03	1.95E-02	1.70E-02	4.30E-02	4.24E-02	2.4687E+00	1.2417E+02
$\alpha_3$	7.36E-04	9.45E-03	7.02E-03	2.65E-02	1.02E-02	1.1969E+00	1.2544E+02
$\alpha_4$	4.45E-05	4.73E-03	2.50E-03	1.70E-02	1.26E-03	5.9902E-01	1.2604E+02
$\alpha_5$	7.52E-09	1.76E-03	2.39E-04	8.80E-03	7.38E-05	2.2260E-01	1.2642E+02
$\alpha_6$	1.11E-18	6.57E-04	1.15E-06	3.84E-03	0.00E+00	8.3237E-02	1.2656E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9416240	0.9653650	0.9669290	0.9837550	0.9409400	1.8994E+02	6.8145E+00
$\alpha_2$	5.16E-03	1.71E-02	1.55E-02	3.45E-02	4.34E-02	3.3595E+00	1.9340E+02
$\alpha_3$	1.26E-03	8.71E-03	7.11E-03	2.16E-02	1.32E-02	1.7138E+00	1.9504E+02
$\alpha_4$	2.64E-04	5.10E-03	3.55E-03	1.52E-02	2.21E-03	1.0027E+00	1.9575E+02
$\alpha_5$	1.32E-05	2.66E-03	1.26E-03	1.00E-02	2.08E-04	5.2307E-01	1.9623E+02
$\alpha_6$	3.45E-10	9.47E-04	8.10E-05	4.97E-03	1.60E-05	1.8638E-01	1.9657E+02
$\alpha_7$	0.00E+00	1.48E-04	1.29E-13	5.56E-04	0.00E+00	2.9071E-02	1.9673E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9446540	0.9661050	0.9674280	0.9830370	0.9370500	2.2537E+02	7.9069E+00
$\alpha_2$	5.04E-03	1.56E-02	1.43E-02	3.09E-02	4.32E-02	3.6504E+00	2.2963E+02
$\alpha_3$	1.28E-03	7.94E-03	6.58E-03	1.92E-02	1.60E-02	1.8516E+00	2.3143E+02
$\alpha_4$	3.71E-04	5.02E-03	3.69E-03	1.42E-02	3.36E-03	1.1703E+00	2.3211E+02
$\alpha_5$	5.64E-05	3.05E-03	1.80E-03	1.03E-02	4.24E-04	7.1133E-01	2.3257E+02
$\alpha_6$	8.94E-07	1.57E-03	5.16E-04	6.73E-03	2.82E-05	3.6716E-01	2.3291E+02
$\alpha_7$	6.98E-14	5.27E-04	9.48E-06	3.00E-03	0.00E+00	1.2297E-01	2.3315E+02
$\alpha_8$	1.31E-42	1.42E-04	2.02E-12	6.00E-04	0.00E+00	3.3124E-02	2.3324E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9845840	0.9717420	0.9612270	0.9527340	0.9461430	0.9409400	0.9370500
$\alpha_2$	1.54E-02	2.67E-02	3.46E-02	3.96E-02	4.24E-02	4.34E-02	4.32E-02
$\alpha_3$		1.53E-03	4.04E-03	7.04E-03	1.02E-02	1.32E-02	1.60E-02
$\alpha_4$			1.63E-04	5.71E-04	1.26E-03	2.21E-03	3.36E-03
$\alpha_5$				2.19E-05	7.38E-05	2.08E-04	4.24E-04
$\alpha_6$					0.00E+00	1.60E-05	2.82E-05
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.85E-01	9.72E-01	9.61E-01	9.53E-01	9.46E-01	9.41E-01	9.37E-01
<b>Beta</b>	1.54E-02	2.83E-02	3.88E-02	4.73E-02	5.39E-02	5.91E-02	6.29E-02
<b>Gamma</b>		5.42E-02	1.08E-01	1.62E-01	2.14E-01	2.65E-01	3.14E-01
<b>Delta</b>			3.87E-02	7.76E-02	1.16E-01	1.55E-01	1.93E-01
<b>Epsilon</b>				3.70E-02	5.56E-02	9.21E-02	1.19E-01
<b>Mu</b>					0.00E+00	7.14E-02	6.25E-02
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	1.53	2.29	3.05	3.81	4.58	5.34	6.10
<b>N<sub>1</sub></b>	0.3413	0.4370	0.4976	0.5318	0.5463	0.5468	0.5375
<b>N<sub>2</sub></b>	0.0293	0.0750	0.1276	0.1806	0.2295	0.2717	0.3057
<b>N<sub>3</sub></b>		0.0043	0.0149	0.0321	0.0551	0.0826	0.1132
<b>N<sub>4</sub></b>			0.0006	0.0026	0.0068	0.0138	0.0238
<b>N<sub>5</sub></b>				0.0001	0.0004	0.0013	0.0030
<b>N<sub>6</sub></b>					0.0000	0.0001	0.0002
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

### 1.13.1.2 480 V CIRCUIT BREAKERS FAIL TO CLOSE

System : Plant ac power  
 Component : Circuit Breaker  
 Failure Mode : Fail to close (reset) on demand  
 Component Group : 480 Volt  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 47.10

Total Number of Common-Cause Failure Events: 1

#### ALPHA FACTOR DISTRIBUTIONS

##### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8937690	0.9728420	0.9881360	0.9999320	0.9959940	1.6461E+01	4.5952E-01
$\alpha_2$	7.00E-05	2.72E-02	1.19E-02	1.06E-01	4.01E-03	4.5952E-01	1.6461E+01

##### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9181350	0.9706750	0.9781100	0.9977720	0.9923380	3.8803E+01	1.1723E+00
$\alpha_2$	9.08E-04	2.26E-02	1.53E-02	6.94E-02	7.47E-03	9.0326E-01	3.9072E+01
$\alpha_3$	2.53E-07	6.73E-03	1.38E-03	3.19E-02	1.93E-04	2.6902E-01	3.9706E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9228250	0.9670280	0.9720460	0.9940480	0.9890450	5.8387E+01	1.9908E+00
$\alpha_2$	2.26E-03	2.25E-02	1.74E-02	5.99E-02	1.04E-02	1.3567E+00	5.9021E+01
$\alpha_3$	8.61E-06	6.81E-03	2.58E-03	2.80E-02	5.73E-04	4.1141E-01	5.9966E+01
$\alpha_4$	1.59E-08	3.69E-03	5.05E-04	1.85E-02	0.00E+00	2.2267E-01	6.0155E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9364710	0.9674040	0.9700750	0.9891950	0.9861070	1.1137E+02	3.7525E+00
$\alpha_2$	4.28E-03	2.01E-02	1.74E-02	4.51E-02	1.27E-02	2.3106E+00	1.1281E+02
$\alpha_3$	4.42E-04	8.65E-03	6.02E-03	2.58E-02	1.16E-03	9.9528E-01	1.1413E+02
$\alpha_4$	2.14E-06	3.25E-03	1.10E-03	1.38E-02	0.00E+00	3.7439E-01	1.1475E+02
$\alpha_5$	5.18E-21	6.28E-04	3.55E-07	3.63E-03	0.00E+00	7.2277E-02	1.1505E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9392680	0.9671900	0.9693970	0.9875640	0.9835410	1.3508E+02	4.5823E+00
$\alpha_2$	4.17E-03	1.80E-02	1.57E-02	3.94E-02	1.45E-02	2.5071E+00	1.3716E+02
$\alpha_3$	6.34E-04	8.43E-03	6.23E-03	2.38E-02	1.94E-03	1.1775E+00	1.3848E+02
$\alpha_4$	3.79E-05	4.24E-03	2.22E-03	1.53E-02	0.00E+00	5.9222E-01	1.3907E+02
$\alpha_5$	6.65E-09	1.59E-03	2.16E-04	7.97E-03	0.00E+00	2.2220E-01	1.3944E+02
$\alpha_6$	1.01E-18	5.96E-04	1.04E-06	3.48E-03	0.00E+00	8.3237E-02	1.3958E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9455890	0.9677050	0.9691700	0.9848290	0.9813610	2.0511E+02	6.8450E+00
$\alpha_2$	4.96E-03	1.62E-02	1.47E-02	3.25E-02	1.57E-02	3.4253E+00	2.0853E+02
$\alpha_3$	1.14E-03	7.99E-03	6.51E-03	1.99E-02	2.91E-03	1.6937E+00	2.1026E+02
$\alpha_4$	2.34E-04	4.67E-03	3.23E-03	1.40E-02	0.00E+00	9.8887E-01	2.1097E+02
$\alpha_5$	1.21E-05	2.46E-03	1.17E-03	9.30E-03	0.00E+00	5.2177E-01	2.1143E+02
$\alpha_6$	3.17E-10	8.79E-04	7.50E-05	4.61E-03	0.00E+00	1.8628E-01	2.1177E+02
$\alpha_7$	0.00E+00	1.37E-04	1.20E-13	5.16E-04	0.00E+00	2.9071E-02	2.1193E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9481760	0.9682380	0.9694790	0.9840700	0.9795500	2.4268E+02	7.9610E+00
$\alpha_2$	4.90E-03	1.49E-02	1.37E-02	2.93E-02	1.64E-02	3.7447E+00	2.4690E+02
$\alpha_3$	1.17E-03	7.33E-03	6.07E-03	1.78E-02	4.09E-03	1.8384E+00	2.4880E+02
$\alpha_4$	3.24E-04	4.57E-03	3.34E-03	1.30E-02	0.00E+00	1.1465E+00	2.4949E+02
$\alpha_5$	5.14E-05	2.83E-03	1.66E-03	9.56E-03	0.00E+00	7.0833E-01	2.4993E+02
$\alpha_6$	8.28E-07	1.46E-03	4.79E-04	6.26E-03	0.00E+00	3.6696E-01	2.5027E+02
$\alpha_7$	6.50E-14	4.91E-04	8.82E-06	2.79E-03	0.00E+00	1.2297E-01	2.5052E+02
$\alpha_8$	1.22E-42	1.32E-04	1.88E-12	5.58E-04	0.00E+00	3.3124E-02	2.5061E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9959940	0.9923380	0.9890450	0.9861070	0.9835410	0.9813610	0.9795500
$\alpha_2$	4.01E-03	7.47E-03	1.04E-02	1.27E-02	1.45E-02	1.57E-02	1.64E-02
$\alpha_3$		1.93E-04	5.73E-04	1.16E-03	1.94E-03	2.91E-03	4.09E-03
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.96E-01	9.92E-01	9.89E-01	9.86E-01	9.84E-01	9.81E-01	9.80E-01
<b>Beta</b>	4.01E-03	7.66E-03	1.10E-02	1.39E-02	1.65E-02	1.86E-02	2.04E-02
<b>Gamma</b>		2.52E-02	5.23E-02	8.35E-02	1.18E-01	1.56E-01	2.00E-01
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	5.89	8.83	11.78	14.72	17.66	20.61	23.55
<b>N<sub>1</sub></b>	0.3250	0.4179	0.4714	0.4911	0.4821	0.4500	0.4000
<b>N<sub>2</sub></b>	0.0250	0.0696	0.1286	0.1964	0.2679	0.3375	0.4000
<b>N<sub>3</sub></b>		0.0018	0.0071	0.0179	0.0357	0.0625	0.1000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0000
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

### 1.13.1.3 480 V CIRCUIT BREAKERS SPURIOUS ACTUATION

**System :** Plant ac power  
**Component :** Circuit Breaker  
**Failure Mode :** Spurious operation open or close  
**Component Group :** 480 Volt  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 41.70

Total Number of Common-Cause Failure Events: 0

### ALPHA FACTOR DISTRIBUTIONS

#### **CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9666160	0.9917050	0.9966670	0.9999840	1.0000000	5.1946E+01	4.3452E-01
$\alpha_2$	1.49E-05	8.30E-03	3.34E-03	3.34E-02	0.00E+00	4.3452E-01	5.1946E+01

#### **CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9562690	0.9847850	0.9889640	0.9990030	1.0000000	7.1255E+01	1.1009E+00
$\alpha_2$	3.63E-04	1.15E-02	7.44E-03	3.66E-02	0.00E+00	8.3366E-01	7.1522E+01
$\alpha_3$	1.29E-07	3.69E-03	7.41E-04	1.75E-02	0.00E+00	2.6722E-01	7.2089E+01

#### **CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9502160	0.9793170	0.9827670	0.9966230	1.0000000	8.7836E+01	1.8551E+00
$\alpha_2$	1.13E-03	1.37E-02	1.03E-02	3.79E-02	0.00E+00	1.2281E+00	8.8463E+01
$\alpha_3$	5.06E-06	4.51E-03	1.67E-03	1.86E-02	0.00E+00	4.0431E-01	8.9287E+01
$\alpha_4$	1.07E-08	2.48E-03	3.39E-04	1.24E-02	0.00E+00	2.2267E-01	8.9468E+01

#### **CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9503170	0.9749770	0.9771860	0.9920940	1.0000000	1.3786E+02	3.5382E+00
$\alpha_2$	2.87E-03	1.50E-02	1.27E-02	3.46E-02	0.00E+00	2.1142E+00	1.3928E+02
$\alpha_3$	3.37E-04	6.91E-03	4.77E-03	2.08E-02	0.00E+00	9.7738E-01	1.4042E+02
$\alpha_4$	1.74E-06	2.65E-03	8.91E-04	1.12E-02	0.00E+00	3.7439E-01	1.4102E+02
$\alpha_5$	4.22E-21	5.11E-04	2.89E-07	2.96E-03	0.00E+00	7.2277E-02	1.4133E+02

#### **CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9504290	0.9737370	0.9756560	0.9904980	1.0000000	1.5864E+02	4.2787E+00
$\alpha_2$	2.82E-03	1.37E-02	1.18E-02	3.13E-02	0.00E+00	2.2392E+00	1.6068E+02
$\alpha_3$	4.93E-04	7.01E-03	5.12E-03	2.00E-02	0.00E+00	1.1418E+00	1.6178E+02
$\alpha_4$	3.25E-05	3.64E-03	1.90E-03	1.31E-02	0.00E+00	5.9222E-01	1.6233E+02
$\alpha_5$	5.70E-09	1.36E-03	1.85E-04	6.83E-03	0.00E+00	2.2220E-01	1.6270E+02
$\alpha_6$	8.65E-19	5.11E-04	8.93E-07	2.98E-03	0.00E+00	8.3237E-02	1.6284E+02

#### **CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9525430	0.9722430	0.9735910	0.9873510	1.0000000	2.2575E+02	6.4450E+00
$\alpha_2$	3.74E-03	1.33E-02	1.19E-02	2.75E-02	0.00E+00	3.0878E+00	2.2911E+02
$\alpha_3$	9.46E-04	7.03E-03	5.67E-03	1.77E-02	0.00E+00	1.6312E+00	2.3056E+02
$\alpha_4$	2.13E-04	4.26E-03	2.95E-03	1.28E-02	0.00E+00	9.8887E-01	2.3121E+02
$\alpha_5$	1.10E-05	2.25E-03	1.06E-03	8.49E-03	0.00E+00	5.2177E-01	2.3167E+02
$\alpha_6$	2.89E-10	8.02E-04	6.85E-05	4.21E-03	0.00E+00	1.8628E-01	2.3201E+02
$\alpha_7$	0.00E+00	1.25E-04	1.10E-13	4.71E-04	0.00E+00	2.9071E-02	2.3217E+02

**AC Power Distribution Breakers**  
**480 Vac Circuit Breakers**  
**480 V CIRCUIT BREAKERS SPURIOUS ACTUATION**

2009

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9538880	0.9721490	0.9733140	0.9864240	1.0000000	2.6043E+02	7.4610E+00
$\alpha_2$	3.75E-03	1.25E-02	1.13E-02	2.53E-02	0.00E+00	3.3447E+00	2.6455E+02
$\alpha_3$	9.60E-04	6.49E-03	5.31E-03	1.61E-02	0.00E+00	1.7384E+00	2.6615E+02
$\alpha_4$	3.03E-04	4.28E-03	3.13E-03	1.22E-02	0.00E+00	1.1465E+00	2.6674E+02
$\alpha_5$	4.81E-05	2.64E-03	1.55E-03	8.95E-03	0.00E+00	7.0833E-01	2.6718E+02
$\alpha_6$	7.75E-07	1.37E-03	4.48E-04	5.86E-03	0.00E+00	3.6696E-01	2.6752E+02
$\alpha_7$	6.08E-14	4.59E-04	8.25E-06	2.61E-03	0.00E+00	1.2297E-01	2.6777E+02
$\alpha_8$	1.14E-42	1.24E-04	1.76E-12	5.22E-04	0.00E+00	3.3124E-02	2.6786E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	1.00E+00						
<b>Beta</b>	0.00E+00						
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	41.70	41.70	41.70	41.70	41.70	41.70	41.70
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0000
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

### 1.13.24160 vac and 6.9Kva Distribution Circuit Breakers

#### 1.13.2.1 ACP 4160 AND 6.9 CIRCUIT BREAKERS FAIL TO OPEN SPAR: CRB-CC

**System :** Plant ac power  
**Component :** Circuit Breaker  
**Failure Mode :** Fail to open on demand  
**Component Group :** 4160 - 6900 Volt  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 13.10

Total Number of Common-Cause Failure Events: 2

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8652340	0.9649380	0.9839770	0.9998890	0.9854700	1.3128E+01	4.7702E-01
$\alpha_2$	1.13E-04	3.51E-02	1.60E-02	1.35E-01	1.45E-02	4.7702E-01	1.3128E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9038740	0.9649100	0.9733480	0.9970590	0.9707210	3.3762E+01	1.2278E+00
$\alpha_2$	1.31E-03	2.74E-02	1.91E-02	8.22E-02	2.92E-02	9.6026E-01	3.4030E+01
$\alpha_3$	2.72E-07	7.65E-03	1.55E-03	3.63E-02	6.92E-05	2.6752E-01	3.4722E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9099680	0.9607400	0.9663330	0.9923650	0.9556340	5.1575E+01	2.1076E+00
$\alpha_2$	3.23E-03	2.76E-02	2.19E-02	7.12E-02	4.41E-02	1.4793E+00	5.2203E+01
$\alpha_3$	8.71E-06	7.56E-03	2.82E-03	3.12E-02	2.28E-04	4.0561E-01	5.3277E+01
$\alpha_4$	1.79E-08	4.15E-03	5.69E-04	2.08E-02	0.00E+00	2.2267E-01	5.3460E+01

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9288440	0.9629180	0.9657800	0.9872090	0.9402440	1.0275E+02	3.9569E+00
$\alpha_2$	5.58E-03	2.37E-02	2.08E-02	5.18E-02	5.93E-02	2.5299E+00	1.0418E+02
$\alpha_3$	4.52E-04	9.19E-03	6.36E-03	2.76E-02	4.28E-04	9.8038E-01	1.0573E+02
$\alpha_4$	2.31E-06	3.51E-03	1.18E-03	1.49E-02	0.00E+00	3.7439E-01	1.0633E+02
$\alpha_5$	5.59E-21	6.77E-04	3.83E-07	3.92E-03	0.00E+00	7.2277E-02	1.0663E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9311890	0.9621350	0.9644910	0.9850170	0.9245270	1.2460E+02	4.9037E+00
$\alpha_2$	5.83E-03	2.21E-02	1.97E-02	4.66E-02	7.47E-02	2.8582E+00	1.2665E+02
$\alpha_3$	6.31E-04	8.86E-03	6.49E-03	2.52E-02	7.12E-04	1.1477E+00	1.2836E+02
$\alpha_4$	4.09E-05	4.57E-03	2.40E-03	1.65E-02	1.21E-05	5.9232E-01	1.2891E+02
$\alpha_5$	7.17E-09	1.72E-03	2.33E-04	8.60E-03	0.00E+00	2.2220E-01	1.2928E+02
$\alpha_6$	1.09E-18	6.43E-04	1.12E-06	3.75E-03	0.00E+00	8.3237E-02	1.2942E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9393260	0.9634210	0.9649600	0.9822750	0.9084560	1.9269E+02	7.3160E+00
$\alpha_2$	6.74E-03	1.97E-02	1.82E-02	3.81E-02	9.05E-02	3.9484E+00	1.9606E+02
$\alpha_3$	1.12E-03	8.21E-03	6.63E-03	2.07E-02	1.06E-03	1.6413E+00	1.9836E+02
$\alpha_4$	2.48E-04	4.95E-03	3.42E-03	1.48E-02	3.15E-05	9.8917E-01	1.9902E+02
$\alpha_5$	1.28E-05	2.61E-03	1.24E-03	9.86E-03	0.00E+00	5.2177E-01	1.9948E+02
$\alpha_6$	3.36E-10	9.31E-04	7.95E-05	4.89E-03	0.00E+00	1.8628E-01	1.9982E+02
$\alpha_7$	0.00E+00	1.45E-04	1.27E-13	5.47E-04	0.00E+00	2.9071E-02	1.9998E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9416830	0.9636260	0.9649210	0.9811390	0.8920460	2.2828E+02	8.6169E+00
$\alpha_2$	7.04E-03	1.89E-02	1.76E-02	3.54E-02	1.06E-01	4.4843E+00	2.3241E+02
$\alpha_3$	1.11E-03	7.40E-03	6.07E-03	1.83E-02	1.47E-03	1.7541E+00	2.3514E+02
$\alpha_4$	3.43E-04	4.84E-03	3.54E-03	1.38E-02	5.60E-05	1.1471E+00	2.3575E+02
$\alpha_5$	5.44E-05	2.99E-03	1.76E-03	1.01E-02	0.00E+00	7.0833E-01	2.3619E+02
$\alpha_6$	8.77E-07	1.55E-03	5.07E-04	6.63E-03	0.00E+00	3.6696E-01	2.3653E+02
$\alpha_7$	6.87E-14	5.19E-04	9.34E-06	2.96E-03	0.00E+00	1.2297E-01	2.3677E+02
$\alpha_8$	1.29E-42	1.40E-04	1.99E-12	5.91E-04	0.00E+00	3.3124E-02	2.3686E+02

**ALPHA FACTOR and MGL PARAMETERS**

<b>Alpha Factor</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>	<b>CCCG=7</b>	<b>CCCG=8</b>
$\alpha_1$	0.9854700	0.9707210	0.9556340	0.9402440	0.9245270	0.9084560	0.8920460
$\alpha_2$	1.45E-02	2.92E-02	4.41E-02	5.93E-02	7.47E-02	9.05E-02	1.06E-01
$\alpha_3$		6.92E-05	2.28E-04	4.28E-04	7.12E-04	1.06E-03	1.47E-03
$\alpha_4$			0.00E+00	0.00E+00	1.21E-05	3.15E-05	5.60E-05
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	9.85E-01	9.71E-01	9.56E-01	9.40E-01	9.25E-01	9.08E-01	8.92E-01
Beta	1.45E-02	2.93E-02	4.44E-02	5.98E-02	7.55E-02	9.15E-02	1.08E-01
Gamma		2.36E-03	5.15E-03	7.17E-03	9.60E-03	1.19E-02	1.41E-02
Delta			0.00E+00	0.00E+00	1.67E-02	2.88E-02	3.68E-02
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	2.18	3.28	4.37	5.46	6.55	7.64	8.73
N <sub>1</sub>	0.7025	0.9272	1.0688	1.1281	1.1061	1.0036	0.8214
N <sub>2</sub>	0.0425	0.1266	0.2512	0.4157	0.6190	0.8606	1.1396
N <sub>3</sub>		0.0003	0.0013	0.0030	0.0059	0.0101	0.0157
N <sub>4</sub>			0.0000	0.0000	0.0001	0.0003	0.0006
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

### 1.13.2.2 ACP 4160 AND 6.9 CIRCUIT BREAKERS FAIL TO CLOSE SPAR: CRB-OO

System :

Plant ac power

Component :

Circuit Breaker

Failure Mode :

Fail to close (reset) on demand

Component Group :

4160 - 6900 Volt

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 57.80

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9744490	0.9936550	0.9974540	0.9999870	1.0000000	6.8046E+01	4.3452E-01
$\alpha_2$	1.13E-05	6.35E-03	2.54E-03	2.56E-02	0.00E+00	4.3452E-01	6.8046E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9641770	0.9875540	0.9909930	0.9991860	1.0000000	8.7355E+01	1.1009E+00
$\alpha_2$	2.96E-04	9.42E-03	6.07E-03	3.00E-02	0.00E+00	8.3366E-01	8.7622E+01
$\alpha_3$	1.05E-07	3.02E-03	6.05E-04	1.43E-02	0.00E+00	2.6722E-01	8.8189E+01

**CCCG = 4**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9577330	0.9824650	0.9854070	0.9971430	1.0000000	1.0394E+02	1.8551E+00
$\alpha_2$	9.54E-04	1.16E-02	8.71E-03	3.22E-02	0.00E+00	1.2281E+00	1.0457E+02
$\alpha_3$	4.28E-06	3.82E-03	1.41E-03	1.58E-02	0.00E+00	4.0431E-01	1.0539E+02
$\alpha_4$	9.05E-09	2.10E-03	2.87E-04	1.05E-02	0.00E+00	2.2267E-01	1.0557E+02

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9553590	0.9775350	0.9795240	0.9929100	1.0000000	1.5396E+02	3.5382E+00
$\alpha_2$	2.58E-03	1.34E-02	1.14E-02	3.11E-02	0.00E+00	2.1142E+00	1.5538E+02
$\alpha_3$	3.02E-04	6.21E-03	4.28E-03	1.87E-02	0.00E+00	9.7738E-01	1.5652E+02
$\alpha_4$	1.56E-06	2.38E-03	7.99E-04	1.01E-02	0.00E+00	3.7439E-01	1.5712E+02
$\alpha_5$	3.78E-21	4.59E-04	2.59E-07	2.65E-03	0.00E+00	7.2277E-02	1.5743E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9548460	0.9760990	0.9778540	0.9913660	1.0000000	1.7474E+02	4.2787E+00
$\alpha_2$	2.56E-03	1.25E-02	1.07E-02	2.85E-02	0.00E+00	2.2392E+00	1.7678E+02
$\alpha_3$	4.48E-04	6.38E-03	4.66E-03	1.82E-02	0.00E+00	1.1418E+00	1.7788E+02
$\alpha_4$	2.95E-05	3.31E-03	1.73E-03	1.19E-02	0.00E+00	5.9222E-01	1.7843E+02
$\alpha_5$	5.18E-09	1.24E-03	1.68E-04	6.22E-03	0.00E+00	2.2220E-01	1.7880E+02
$\alpha_6$	7.87E-19	4.65E-04	8.13E-07	2.71E-03	0.00E+00	8.3237E-02	1.7894E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9555930	0.9740430	0.9753090	0.9881790	1.0000000	2.4185E+02	6.4450E+00
$\alpha_2$	3.50E-03	1.24E-02	1.12E-02	2.58E-02	0.00E+00	3.0878E+00	2.4521E+02
$\alpha_3$	8.84E-04	6.57E-03	5.30E-03	1.66E-02	0.00E+00	1.6312E+00	2.4666E+02
$\alpha_4$	1.99E-04	3.98E-03	2.76E-03	1.20E-02	0.00E+00	9.8887E-01	2.4731E+02
$\alpha_5$	1.03E-05	2.10E-03	9.94E-04	7.94E-03	0.00E+00	5.2177E-01	2.4777E+02
$\alpha_6$	2.71E-10	7.50E-04	6.40E-05	3.94E-03	0.00E+00	1.8628E-01	2.4811E+02
$\alpha_7$	0.00E+00	1.17E-04	1.02E-13	4.41E-04	0.00E+00	2.9071E-02	2.4827E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9564830	0.9737280	0.9748350	0.9872040	1.0000000	2.7653E+02	7.4610E+00
$\alpha_2$	3.54E-03	1.18E-02	1.07E-02	2.39E-02	0.00E+00	3.3447E+00	2.8065E+02
$\alpha_3$	9.05E-04	6.12E-03	5.01E-03	1.51E-02	0.00E+00	1.7384E+00	2.8225E+02
$\alpha_4$	2.86E-04	4.04E-03	2.95E-03	1.15E-02	0.00E+00	1.1465E+00	2.8284E+02
$\alpha_5$	4.54E-05	2.49E-03	1.47E-03	8.44E-03	0.00E+00	7.0833E-01	2.8328E+02
$\alpha_6$	7.31E-07	1.29E-03	4.23E-04	5.53E-03	0.00E+00	3.6696E-01	2.8362E+02
$\alpha_7$	5.73E-14	4.33E-04	7.78E-06	2.46E-03	0.00E+00	1.2297E-01	2.8387E+02
$\alpha_8$	1.07E-42	1.17E-04	1.66E-12	4.93E-04	0.00E+00	3.3124E-02	2.8396E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	57.80	57.80	57.80	57.80	57.80	57.80	57.80
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

**1.13.2.3 ACP 4160 AND 6.9 CIRCUIT BREAKERS SPURIOUS OP SPAR: CRB-CO**

System : Plant ac power  
 Component : Circuit Breaker  
 Failure Mode : Spurious operation open or close  
 Component Group : 4160 - 6900 Volt  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 28.50

Total Number of Common-Cause Failure Events: 4

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8777900	0.9668230	0.9832950	0.9998050	0.9813450	1.5664E+01	5.3752E-01
$\alpha_2$	1.98E-04	3.32E-02	1.67E-02	1.22E-01	1.87E-02	5.3752E-01	1.5664E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9051920	0.9637480	0.9714020	0.9960820	0.9624690	3.7379E+01	1.4060E+00
$\alpha_2$	2.08E-03	2.93E-02	2.17E-02	8.27E-02	3.73E-02	1.1369E+00	3.7648E+01
$\alpha_3$	2.62E-07	6.94E-03	1.42E-03	3.28E-02	2.34E-04	2.6912E-01	3.8516E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9083360	0.9580830	0.9631970	0.9903280	0.9433630	5.6172E+01	2.4576E+00
$\alpha_2$	5.00E-03	3.11E-02	2.59E-02	7.49E-02	5.59E-02	1.8229E+00	5.6807E+01
$\alpha_3$	8.97E-06	7.03E-03	2.66E-03	2.88E-02	7.24E-04	4.1201E-01	5.8218E+01
$\alpha_4$	1.64E-08	3.80E-03	5.20E-04	1.90E-02	0.00E+00	2.2267E-01	5.8407E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9256130	0.9598300	0.9625220	0.9848350	0.9240950	1.0823E+02	4.5295E+00
$\alpha_2$	7.76E-03	2.74E-02	2.46E-02	5.64E-02	7.44E-02	3.0863E+00	1.0967E+02
$\alpha_3$	4.53E-04	8.84E-03	6.15E-03	2.64E-02	1.47E-03	9.9658E-01	1.1176E+02
$\alpha_4$	2.18E-06	3.32E-03	1.12E-03	1.41E-02	0.00E+00	3.7439E-01	1.1239E+02
$\alpha_5$	5.29E-21	6.41E-04	3.62E-07	3.71E-03	0.00E+00	7.2277E-02	1.1269E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9264760	0.9579300	0.9601480	0.9817960	0.9045340	1.3085E+02	5.7466E+00
$\alpha_2$	8.73E-03	2.69E-02	2.46E-02	5.28E-02	9.30E-02	3.6687E+00	1.3293E+02
$\alpha_3$	6.53E-04	8.64E-03	6.39E-03	2.43E-02	2.49E-03	1.1801E+00	1.3542E+02
$\alpha_4$	3.88E-05	4.34E-03	2.27E-03	1.56E-02	6.50E-06	5.9232E-01	1.3600E+02
$\alpha_5$	6.80E-09	1.63E-03	2.21E-04	8.15E-03	0.00E+00	2.2220E-01	1.3637E+02
$\alpha_6$	1.03E-18	6.09E-04	1.07E-06	3.56E-03	0.00E+00	8.3237E-02	1.3651E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9370230	0.9612170	0.9626860	0.9803880	0.9078380	2.0009E+02	8.0731E+00
$\alpha_2$	7.91E-03	2.14E-02	1.99E-02	4.00E-02	7.70E-02	4.4489E+00	2.0371E+02
$\alpha_3$	1.52E-03	9.12E-03	7.60E-03	2.19E-02	1.51E-02	1.8980E+00	2.0627E+02
$\alpha_4$	2.38E-04	4.75E-03	3.29E-03	1.43E-02	1.13E-05	9.8907E-01	2.0717E+02
$\alpha_5$	1.23E-05	2.51E-03	1.19E-03	9.47E-03	0.00E+00	5.2177E-01	2.0764E+02
$\alpha_6$	3.23E-10	8.95E-04	7.64E-05	4.70E-03	0.00E+00	1.8628E-01	2.0798E+02
$\alpha_7$	0.00E+00	1.40E-04	1.22E-13	5.26E-04	0.00E+00	2.9071E-02	2.0813E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9405450	0.9623650	0.9636140	0.9799260	0.9095910	2.3686E+02	9.2629E+00
$\alpha_2$	7.26E-03	1.90E-02	1.77E-02	3.52E-02	6.70E-02	4.6796E+00	2.4144E+02
$\alpha_3$	1.73E-03	8.80E-03	7.51E-03	2.03E-02	2.14E-02	2.1650E+00	2.4396E+02
$\alpha_4$	3.67E-04	4.82E-03	3.57E-03	1.36E-02	2.03E-03	1.1869E+00	2.4494E+02
$\alpha_5$	5.24E-05	2.88E-03	1.69E-03	9.74E-03	0.00E+00	7.0833E-01	2.4541E+02
$\alpha_6$	8.44E-07	1.49E-03	4.88E-04	6.38E-03	0.00E+00	3.6696E-01	2.4576E+02
$\alpha_7$	6.62E-14	5.00E-04	8.98E-06	2.84E-03	0.00E+00	1.2297E-01	2.4600E+02
$\alpha_8$	1.24E-42	1.35E-04	1.92E-12	5.69E-04	0.00E+00	3.3124E-02	2.4609E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.9813450	0.9624690	0.9433630	0.9240950	0.9045340	0.9078380	0.9095910
$\alpha_2$	1.87E-02	3.73E-02	5.59E-02	7.44E-02	9.30E-02	7.70E-02	6.70E-02
$\alpha_3$		2.34E-04	7.24E-04	1.47E-03	2.49E-03	1.51E-02	2.14E-02
$\alpha_4$			0.00E+00	0.00E+00	6.50E-06	1.13E-05	2.03E-03
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	9.81E-01	9.62E-01	9.43E-01	9.24E-01	9.05E-01	9.08E-01	9.10E-01
<b>Beta</b>	1.87E-02	3.75E-02	5.66E-02	7.59E-02	9.55E-02	9.22E-02	9.04E-02
<b>Gamma</b>		6.23E-03	1.28E-02	1.94E-02	2.62E-02	1.64E-01	2.59E-01
<b>Delta</b>			0.00E+00	0.00E+00	2.60E-03	7.49E-04	8.65E-02
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	4.22	6.33	8.44	10.56	12.67	14.78	16.89
<b>N<sub>1</sub></b>	1.1982	1.4941	1.5955	1.5084	1.2382	1.2576	1.2387
<b>N<sub>2</sub></b>	0.1030	0.3032	0.5948	0.9721	1.4295	1.3611	1.3349
<b>N<sub>3</sub></b>		0.0019	0.0077	0.0192	0.0383	0.2668	0.4266
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0001	0.0002	0.0404
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0000
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

**Batteries**

DC POWER BATTERY NO OUTPUT SPAR:BAT-LP

## 1.14 DC Power System - Batteries, Chargers, and Breakers

### 1.14.1 Batteries

#### 1.14.1.1 DC POWER BATTERY NO OUTPUT SPAR:BAT-LP

System :	dc power
Component :	Battery
Failure Mode :	No voltage/amperage output
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 21.70

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

**CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9461090	0.9865810	0.9945600	0.9999730	1.0000000	3.1946E+01	4.3452E-01
$\alpha_2$	2.42E-05	1.34E-02	5.44E-03	5.39E-02	0.00E+00	4.3452E-01	3.1946E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9397490	0.9789730	0.9847000	0.9986200	1.0000000	5.1255E+01	1.1009E+00
$\alpha_2$	5.04E-04	1.59E-02	1.03E-02	5.05E-02	0.00E+00	8.3366E-01	5.1522E+01
$\alpha_3$	1.79E-07	5.10E-03	1.03E-03	2.42E-02	0.00E+00	2.6722E-01	5.2089E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9361090	0.9733810	0.9777740	0.9956300	1.0000000	6.7836E+01	1.8551E+00
$\alpha_2$	1.46E-03	1.76E-02	1.33E-02	4.87E-02	0.00E+00	1.2281E+00	6.8463E+01
$\alpha_3$	6.53E-06	5.80E-03	2.15E-03	2.40E-02	0.00E+00	4.0431E-01	6.9287E+01
$\alpha_4$	1.38E-08	3.20E-03	4.37E-04	1.60E-02	0.00E+00	2.2267E-01	6.9468E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9422200	0.9708540	0.9734060	0.9907670	1.0000000	1.1786E+02	3.5382E+00
$\alpha_2$	3.35E-03	1.74E-02	1.48E-02	4.03E-02	0.00E+00	2.1142E+00	1.1928E+02
$\alpha_3$	3.93E-04	8.05E-03	5.56E-03	2.42E-02	0.00E+00	9.7738E-01	1.2042E+02
$\alpha_4$	2.03E-06	3.08E-03	1.04E-03	1.31E-02	0.00E+00	3.7439E-01	1.2102E+02
$\alpha_5$	4.91E-21	5.95E-04	3.37E-07	3.45E-03	0.00E+00	7.2277E-02	1.2133E+02

**Batteries**

DC POWER BATTERY NO OUTPUT SPAR:BAT-LP

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9435640	0.9700620	0.9722320	0.9891510	1.0000000	1.3864E+02	4.2787E+00
$\alpha_2$	3.22E-03	1.57E-02	1.35E-02	3.56E-02	0.00E+00	2.2392E+00	1.4068E+02
$\alpha_3$	5.62E-04	7.99E-03	5.84E-03	2.28E-02	0.00E+00	1.1418E+00	1.4178E+02
$\alpha_4$	3.70E-05	4.14E-03	2.17E-03	1.50E-02	0.00E+00	5.9222E-01	1.4233E+02
$\alpha_5$	6.50E-09	1.55E-03	2.11E-04	7.79E-03	0.00E+00	2.2220E-01	1.4270E+02
$\alpha_6$	9.86E-19	5.82E-04	1.02E-06	3.40E-03	0.00E+00	8.3237E-02	1.4284E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00
$\alpha_6$					0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	1.00E+00	1.00E+00	1.00E+00	1.00E+00	1.00E+00
Beta	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00
Mu					0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	21.70	21.70	21.70	21.70	21.70
$N_1$	0.0000	0.0000	0.0000	0.0000	0.0000
$N_2$	0.0000	0.0000	0.0000	0.0000	0.0000
$N_3$		0.0000	0.0000	0.0000	0.0000
$N_4$			0.0000	0.0000	0.0000
$N_5$				0.0000	0.0000
$N_6$					0.0000

## 1.14.2 Battery Chargers

### 1.14.2.1 DC POWER BATTERY CHARGER LOSS OF FUNCTION SPAR: BCH-FC

System :	dc power
Component :	Battery Charger
Failure Mode :	High voltage/ amperage output No voltage/amperage output
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 232.70

Total Number of Common-Cause Failure Events: 9

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9694650	0.9875220	0.9897130	0.9980780	0.9898020	1.4103E+02	1.7820E+00
$\alpha_2$	1.92E-03	1.25E-02	1.03E-02	3.05E-02	1.02E-02	1.7820E+00	1.4103E+02

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9713700	0.9861030	0.9875110	0.9960300	0.9895540	2.2304E+02	3.1433E+00
$\alpha_2$	2.30E-03	1.05E-02	9.10E-03	2.35E-02	7.89E-03	2.3761E+00	2.2381E+02
$\alpha_3$	8.14E-05	3.39E-03	2.09E-03	1.12E-02	2.56E-03	7.6722E-01	2.2542E+02

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9752120	0.9872080	0.9882490	0.9956540	0.9919820	3.0405E+02	3.9398E+00
$\alpha_2$	1.24E-03	6.70E-03	5.66E-03	1.57E-02	3.21E-03	2.0626E+00	3.0593E+02
$\alpha_3$	4.80E-04	4.56E-03	3.54E-03	1.21E-02	3.85E-03	1.4045E+00	3.0659E+02
$\alpha_4$	4.45E-06	1.53E-03	6.64E-04	6.01E-03	9.62E-04	4.7267E-01	3.0752E+02

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9763460	0.9866250	0.9873850	0.9943130	0.9934190	4.1850E+02	5.6735E+00
$\alpha_2$	1.49E-03	6.18E-03	5.42E-03	1.35E-02	1.56E-03	2.6212E+00	4.2155E+02
$\alpha_3$	7.07E-04	4.37E-03	3.62E-03	1.06E-02	2.71E-03	1.8556E+00	4.2232E+02
$\alpha_4$	1.21E-04	2.36E-03	1.64E-03	7.05E-03	1.93E-03	9.9939E-01	4.2317E+02
$\alpha_5$	3.91E-10	4.65E-04	4.66E-05	2.41E-03	3.85E-04	1.9728E-01	4.2398E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9782290	0.9873080	0.9879420	0.9942350	0.9943530	5.0368E+02	6.4749E+00
$\alpha_2$	1.23E-03	5.13E-03	4.50E-03	1.12E-02	9.66E-04	2.6151E+00	5.0754E+02
$\alpha_3$	5.28E-04	3.48E-03	2.85E-03	8.56E-03	1.63E-03	1.7745E+00	5.0838E+02
$\alpha_4$	2.55E-04	2.63E-03	2.02E-03	7.11E-03	1.93E-03	1.3424E+00	5.0881E+02
$\alpha_5$	1.08E-05	1.17E-03	6.15E-04	4.22E-03	9.64E-04	5.9720E-01	5.0956E+02
$\alpha_6$	1.46E-12	2.86E-04	1.06E-05	1.58E-03	1.61E-04	1.4574E-01	5.1001E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9898020	0.9895540	0.9919820	0.9934190	0.9943530
$\alpha_2$	1.02E-02	7.89E-03	3.21E-03	1.56E-03	9.66E-04
$\alpha_3$		2.56E-03	3.85E-03	2.71E-03	1.63E-03
$\alpha_4$			9.62E-04	1.93E-03	1.93E-03
$\alpha_5$				3.85E-04	9.64E-04
$\alpha_6$					1.61E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.90E-01	9.90E-01	9.92E-01	9.93E-01	9.94E-01
Beta	1.02E-02	1.04E-02	8.02E-03	6.58E-03	5.65E-03
Gamma		2.45E-01	6.00E-01	7.63E-01	8.29E-01
Delta			2.00E-01	4.61E-01	6.52E-01
Epsilon				1.67E-01	3.68E-01
Mu					1.43E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	126.81	190.22	253.62	317.03	380.44
$N_1$	3.9717	3.2651	4.2972	5.3083	6.2967
$N_2$	1.3475	1.5424	0.8345	0.5070	0.3759
$N_3$		0.5000	1.0002	0.8782	0.6327
$N_4$			0.2500	0.6250	0.7502
$N_5$				0.1250	0.3750
$N_6$					0.0625

**1.14.2.2 DC POWER BATTERY CHARGER NO OUTPUT SPAR:BCH-LP**

System :	dc power
Component :	Battery Charger
Failure Mode :	No voltage/amperage output
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 200.00

Total Number of Common-Cause Failure Events: 9

**Battery** Chargers

DC POWER BATTERY CHARGER NO OUTPUT SPAR:BCH-LP

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9651390	0.9857430	0.9882380	0.9978060	0.9882120	1.2321E+02	1.7820E+00
$\alpha_2$	2.20E-03	1.43E-02	1.18E-02	3.49E-02	1.18E-02	1.7820E+00	1.2321E+02

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9675610	0.9842400	0.9858320	0.9954930	0.9879000	1.9631E+02	3.1433E+00
$\alpha_2$	2.61E-03	1.19E-02	1.03E-02	2.67E-02	9.14E-03	2.3761E+00	1.9708E+02
$\alpha_3$	9.24E-05	3.85E-03	2.37E-03	1.26E-02	2.96E-03	7.6722E-01	1.9869E+02

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9719850	0.9855340	0.9867090	0.9950800	0.9907080	2.6841E+02	3.9398E+00
$\alpha_2$	1.40E-03	7.57E-03	6.41E-03	1.77E-02	3.72E-03	2.0626E+00	2.7029E+02
$\alpha_3$	5.43E-04	5.16E-03	4.01E-03	1.37E-02	4.46E-03	1.4045E+00	2.7095E+02
$\alpha_4$	5.04E-06	1.74E-03	7.52E-04	6.80E-03	1.11E-03	4.7267E-01	2.7188E+02

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9735880	0.9850550	0.9858970	0.9936420	0.9923720	3.7395E+02	5.6735E+00
$\alpha_2$	1.67E-03	6.90E-03	6.06E-03	1.50E-02	1.81E-03	2.6212E+00	3.7700E+02
$\alpha_3$	7.90E-04	4.89E-03	4.05E-03	1.18E-02	3.14E-03	1.8556E+00	3.7777E+02
$\alpha_4$	1.35E-04	2.63E-03	1.83E-03	7.88E-03	2.23E-03	9.9939E-01	3.7862E+02
$\alpha_5$	4.37E-10	5.20E-04	5.20E-05	2.69E-03	4.47E-04	1.9728E-01	3.7943E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9756870	0.9858220	0.9865230	0.9935530	0.9934530	4.5022E+02	6.4749E+00
$\alpha_2$	1.38E-03	5.73E-03	5.02E-03	1.25E-02	1.12E-03	2.6151E+00	4.5408E+02
$\alpha_3$	5.90E-04	3.89E-03	3.19E-03	9.56E-03	1.89E-03	1.7745E+00	4.5492E+02
$\alpha_4$	2.85E-04	2.94E-03	2.25E-03	7.94E-03	2.24E-03	1.3424E+00	4.5535E+02
$\alpha_5$	1.21E-05	1.31E-03	6.87E-04	4.71E-03	1.12E-03	5.9720E-01	4.5610E+02
$\alpha_6$	1.63E-12	3.19E-04	1.19E-05	1.77E-03	1.86E-04	1.4574E-01	4.5655E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9882120	0.9879000	0.9907080	0.9923720	0.9934530
$\alpha_2$	1.18E-02	9.14E-03	3.72E-03	1.81E-03	1.12E-03
$\alpha_3$		2.96E-03	4.46E-03	3.14E-03	1.89E-03
$\alpha_4$			1.11E-03	2.23E-03	2.24E-03
$\alpha_5$				4.47E-04	1.12E-03
$\alpha_6$					1.86E-04

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.88E-01	9.88E-01	9.91E-01	9.92E-01	9.93E-01
Beta	1.18E-02	1.21E-02	9.29E-03	7.63E-03	6.55E-03
Gamma		2.45E-01	6.00E-01	7.63E-01	8.29E-01
Delta			2.00E-01	4.61E-01	6.52E-01
Epsilon				1.67E-01	3.68E-01
Mu					1.43E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	108.99	163.49	217.98	272.48	326.98
N <sub>1</sub>	3.9717	3.2651	4.2972	5.3083	6.2967
N <sub>2</sub>	1.3475	1.5424	0.8345	0.5070	0.3759
N <sub>3</sub>		0.5000	1.0002	0.8782	0.6327
N <sub>4</sub>			0.2500	0.6250	0.7502
N <sub>5</sub>				0.1250	0.3750
N <sub>6</sub>					0.0625

### 1.14.3 DC Power Distribution Circuit Breakers

#### 1.14.3.1 DC POWER BREAKER FAIL TO OPEN

System : dc power  
 Component : Circuit Breaker  
 Failure Mode : Fail to open on demand  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 1.50

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8581890	0.9643270	0.9850590	0.9999350	1.0000000	1.1746E+01	4.3452E-01
$\alpha_2$	6.69E-05	3.57E-02	1.49E-02	1.42E-01	0.00E+00	4.3452E-01	1.1746E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9025780	0.9657640	0.9748880	0.9977200	1.0000000	3.1055E+01	1.1009E+00
$\alpha_2$	8.29E-04	2.59E-02	1.69E-02	8.18E-02	0.00E+00	8.3366E-01	3.1322E+01
$\alpha_3$	2.93E-07	8.31E-03	1.69E-03	3.94E-02	0.00E+00	2.6722E-01	3.1889E+01

**CCCG = 4**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9104790	0.9625170	0.9685780	0.9938040	1.0000000	4.7636E+01	1.8551E+00
$\alpha_2$	2.06E-03	2.48E-02	1.87E-02	6.83E-02	0.00E+00	1.2281E+00	4.8263E+01
$\alpha_3$	9.23E-06	8.17E-03	3.04E-03	3.37E-02	0.00E+00	4.0431E-01	4.9087E+01
$\alpha_4$	1.95E-08	4.50E-03	6.18E-04	2.25E-02	0.00E+00	2.2267E-01	4.9268E+01

**CCCG = 5**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9308380	0.9650370	0.9680620	0.9888920	1.0000000	9.7661E+01	3.5382E+00
$\alpha_2$	4.03E-03	2.09E-02	1.78E-02	4.83E-02	0.00E+00	2.1142E+00	9.9085E+01
$\alpha_3$	4.72E-04	9.66E-03	6.68E-03	2.90E-02	0.00E+00	9.7738E-01	1.0022E+02
$\alpha_4$	2.43E-06	3.70E-03	1.25E-03	1.57E-02	0.00E+00	3.7439E-01	1.0082E+02
$\alpha_5$	5.90E-21	7.14E-04	4.04E-07	4.14E-03	0.00E+00	7.2277E-02	1.0113E+02

**CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9343810	0.9651340	0.9676320	0.9873370	1.0000000	1.1844E+02	4.2787E+00
$\alpha_2$	3.75E-03	1.82E-02	1.57E-02	4.15E-02	0.00E+00	2.2392E+00	1.2048E+02
$\alpha_3$	6.56E-04	9.30E-03	6.81E-03	2.65E-02	0.00E+00	1.1418E+00	1.2158E+02
$\alpha_4$	4.32E-05	4.83E-03	2.53E-03	1.74E-02	0.00E+00	5.9222E-01	1.2213E+02
$\alpha_5$	7.57E-09	1.81E-03	2.46E-04	9.07E-03	0.00E+00	2.2220E-01	1.2250E+02
$\alpha_6$	1.15E-18	6.78E-04	1.19E-06	3.96E-03	0.00E+00	8.3237E-02	1.2264E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9426990	0.9664310	0.9680420	0.9846650	1.0000000	1.8555E+02	6.4450E+00
$\alpha_2$	4.53E-03	1.61E-02	1.44E-02	3.33E-02	0.00E+00	3.0878E+00	1.8891E+02
$\alpha_3$	1.15E-03	8.50E-03	6.86E-03	2.14E-02	0.00E+00	1.6312E+00	1.9036E+02
$\alpha_4$	2.58E-04	5.15E-03	3.57E-03	1.55E-02	0.00E+00	9.8887E-01	1.9101E+02
$\alpha_5$	1.34E-05	2.72E-03	1.29E-03	1.03E-02	0.00E+00	5.2177E-01	1.9147E+02
$\alpha_6$	3.50E-10	9.70E-04	8.29E-05	5.09E-03	0.00E+00	1.8628E-01	1.9181E+02
$\alpha_7$	0.00E+00	1.51E-04	1.33E-13	5.70E-04	0.00E+00	2.9071E-02	1.9197E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9458180	0.9672320	0.9685940	0.9840060	1.0000000	2.2023E+02	7.4610E+00
$\alpha_2$	4.42E-03	1.47E-02	1.33E-02	2.97E-02	0.00E+00	3.3447E+00	2.2435E+02
$\alpha_3$	1.13E-03	7.63E-03	6.25E-03	1.89E-02	0.00E+00	1.7384E+00	2.2595E+02
$\alpha_4$	3.57E-04	5.04E-03	3.68E-03	1.43E-02	0.00E+00	1.1465E+00	2.2654E+02
$\alpha_5$	5.66E-05	3.11E-03	1.83E-03	1.05E-02	0.00E+00	7.0833E-01	2.2698E+02
$\alpha_6$	9.12E-07	1.61E-03	5.28E-04	6.89E-03	0.00E+00	3.6696E-01	2.2732E+02
$\alpha_7$	7.15E-14	5.40E-04	9.71E-06	3.07E-03	0.00E+00	1.2297E-01	2.2757E+02
$\alpha_8$	1.34E-42	1.45E-04	2.07E-12	6.15E-04	0.00E+00	3.3124E-02	2.2766E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
1-Beta	1.00E+00						
Beta	0.00E+00						
Gamma		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Delta			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Epsilon				0.00E+00	0.00E+00	0.00E+00	0.00E+00
Mu					0.00E+00	0.00E+00	0.00E+00
Upsilon						0.00E+00	0.00E+00
Sigma							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	1.50	1.50	1.50	1.50	1.50	1.50	1.50
N <sub>1</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>2</sub>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>3</sub>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>4</sub>			0.0000	0.0000	0.0000	0.0000	0.0000
N <sub>5</sub>				0.0000	0.0000	0.0000	0.0000
N <sub>6</sub>					0.0000	0.0000	0.0000
N <sub>7</sub>						0.0000	0.0000
N <sub>8</sub>							0.0000

**1.14.3.2 DC POWER BREAKER FAIL TO CLOSE**

System : dc power  
 Component : Circuit Breaker  
 Failure Mode : Fail to close (reset) on demand  
 Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 9.00

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9116630	0.9779210	0.9909360	0.9999560	1.0000000	1.9246E+01	4.3452E-01
$\alpha_2$	4.05E-05	2.21E-02	9.06E-03	8.83E-02	0.00E+00	4.3452E-01	1.9246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9207320	0.9722390	0.9797180	0.9981670	1.0000000	3.8555E+01	1.1009E+00
$\alpha_2$	6.69E-04	2.10E-02	1.37E-02	6.65E-02	0.00E+00	8.3366E-01	3.8822E+01
$\alpha_3$	2.37E-07	6.74E-03	1.36E-03	3.20E-02	0.00E+00	2.6722E-01	3.9389E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9220800	0.9674500	0.9727570	0.9946390	1.0000000	5.5136E+01	1.8551E+00
$\alpha_2$	1.79E-03	2.15E-02	1.63E-02	5.94E-02	0.00E+00	1.2281E+00	5.5763E+01
$\alpha_3$	8.00E-06	7.09E-03	2.63E-03	2.93E-02	0.00E+00	4.0431E-01	5.6587E+01
$\alpha_4$	1.69E-08	3.91E-03	5.36E-04	1.96E-02	0.00E+00	2.2267E-01	5.6768E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9355510	0.9674490	0.9702750	0.9896710	1.0000000	1.0516E+02	3.5382E+00
$\alpha_2$	3.75E-03	1.95E-02	1.66E-02	4.50E-02	0.00E+00	2.1142E+00	1.0658E+02
$\alpha_3$	4.39E-04	8.99E-03	6.21E-03	2.70E-02	0.00E+00	9.7738E-01	1.0772E+02
$\alpha_4$	2.26E-06	3.44E-03	1.16E-03	1.46E-02	0.00E+00	3.7439E-01	1.0832E+02
$\alpha_5$	5.49E-21	6.65E-04	3.76E-07	3.85E-03	0.00E+00	7.2277E-02	1.0863E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9381170	0.9671430	0.9695070	0.9880770	1.0000000	1.2594E+02	4.2787E+00
$\alpha_2$	3.53E-03	1.72E-02	1.48E-02	3.91E-02	0.00E+00	2.2392E+00	1.2798E+02
$\alpha_3$	6.17E-04	8.77E-03	6.41E-03	2.50E-02	0.00E+00	1.1418E+00	1.2908E+02
$\alpha_4$	4.07E-05	4.55E-03	2.38E-03	1.64E-02	0.00E+00	5.9222E-01	1.2963E+02
$\alpha_5$	7.13E-09	1.71E-03	2.31E-04	8.55E-03	0.00E+00	2.2220E-01	1.3000E+02
$\alpha_6$	1.08E-18	6.39E-04	1.12E-06	3.73E-03	0.00E+00	8.3237E-02	1.3014E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9448370	0.9676930	0.9692440	0.9852520	1.0000000	1.9305E+02	6.4450E+00
$\alpha_2$	4.36E-03	1.55E-02	1.39E-02	3.20E-02	0.00E+00	3.0878E+00	1.9641E+02
$\alpha_3$	1.10E-03	8.18E-03	6.60E-03	2.06E-02	0.00E+00	1.6312E+00	1.9786E+02
$\alpha_4$	2.48E-04	4.96E-03	3.43E-03	1.49E-02	0.00E+00	9.8887E-01	1.9851E+02
$\alpha_5$	1.29E-05	2.62E-03	1.24E-03	9.88E-03	0.00E+00	5.2177E-01	1.9897E+02
$\alpha_6$	3.37E-10	9.34E-04	7.97E-05	4.90E-03	0.00E+00	1.8628E-01	1.9931E+02
$\alpha_7$	0.00E+00	1.46E-04	1.28E-13	5.49E-04	0.00E+00	2.9071E-02	1.9947E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9475310	0.9682770	0.9695950	0.9845210	1.0000000	2.2773E+02	7.4610E+00
$\alpha_2$	4.28E-03	1.42E-02	1.29E-02	2.88E-02	0.00E+00	3.3447E+00	2.3185E+02
$\alpha_3$	1.09E-03	7.39E-03	6.05E-03	1.83E-02	0.00E+00	1.7384E+00	2.3345E+02
$\alpha_4$	3.45E-04	4.87E-03	3.56E-03	1.39E-02	0.00E+00	1.1465E+00	2.3404E+02
$\alpha_5$	5.48E-05	3.01E-03	1.77E-03	1.02E-02	0.00E+00	7.0833E-01	2.3448E+02
$\alpha_6$	8.83E-07	1.56E-03	5.11E-04	6.67E-03	0.00E+00	3.6696E-01	2.3482E+02
$\alpha_7$	6.92E-14	5.23E-04	9.40E-06	2.98E-03	0.00E+00	1.2297E-01	2.3507E+02
$\alpha_8$	1.30E-42	1.41E-04	2.01E-12	5.95E-04	0.00E+00	3.3124E-02	2.3516E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	1.00E+00						
<b>Beta</b>	0.00E+00						
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	9.00	9.00	9.00	9.00	9.00	9.00	9.00
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0000
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

**1.14.3.3 DC POWER BREAKER SPURIOUS ACTUATION**

**System :** dc power  
**Component :** Circuit Breaker  
**Failure Mode :** Spurious operation open or close  
**Start Date :** 1997/01/01  
**Data Version :** 2009/12/31

Total Number of Independent Failure Events: 13.00

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9264700	0.9816510	0.9925140	0.9999640	1.0000000	2.3246E+01	4.3452E-01
$\alpha_2$	3.34E-05	1.83E-02	7.49E-03	7.35E-02	0.00E+00	4.3452E-01	2.3246E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9278990	0.9747830	0.9816050	0.9983330	1.0000000	4.2555E+01	1.1009E+00
$\alpha_2$	6.06E-04	1.91E-02	1.24E-02	6.04E-02	0.00E+00	8.3366E-01	4.2822E+01
$\alpha_3$	2.15E-07	6.12E-03	1.24E-03	2.90E-02	0.00E+00	2.6722E-01	4.3389E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9271180	0.9695840	0.9745680	0.9949930	1.0000000	5.9136E+01	1.8551E+00
$\alpha_2$	1.67E-03	2.01E-02	1.52E-02	5.56E-02	0.00E+00	1.2281E+00	5.9763E+01
$\alpha_3$	7.47E-06	6.63E-03	2.46E-03	2.74E-02	0.00E+00	4.0431E-01	6.0587E+01
$\alpha_4$	1.58E-08	3.65E-03	5.00E-04	1.83E-02	0.00E+00	2.2267E-01	6.0768E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9378120	0.9686040	0.9713360	0.9900430	1.0000000	1.0916E+02	3.5382E+00
$\alpha_2$	3.61E-03	1.88E-02	1.60E-02	4.34E-02	0.00E+00	2.1142E+00	1.1058E+02
$\alpha_3$	4.23E-04	8.67E-03	5.99E-03	2.61E-02	0.00E+00	9.7738E-01	1.1172E+02
$\alpha_4$	2.18E-06	3.32E-03	1.12E-03	1.41E-02	0.00E+00	3.7439E-01	1.1232E+02
$\alpha_5$	5.29E-21	6.41E-04	3.63E-07	3.71E-03	0.00E+00	7.2277E-02	1.1263E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9399410	0.9681220	0.9704190	0.9884370	1.0000000	1.2994E+02	4.2787E+00
$\alpha_2$	3.43E-03	1.67E-02	1.43E-02	3.79E-02	0.00E+00	2.2392E+00	1.3198E+02
$\alpha_3$	5.99E-04	8.51E-03	6.22E-03	2.42E-02	0.00E+00	1.1418E+00	1.3308E+02
$\alpha_4$	3.95E-05	4.41E-03	2.31E-03	1.59E-02	0.00E+00	5.9222E-01	1.3363E+02
$\alpha_5$	6.92E-09	1.66E-03	2.24E-04	8.29E-03	0.00E+00	2.2220E-01	1.3400E+02
$\alpha_6$	1.05E-18	6.20E-04	1.08E-06	3.62E-03	0.00E+00	8.3237E-02	1.3414E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9459110	0.9683280	0.9698500	0.9855410	1.0000000	1.9705E+02	6.4450E+00
$\alpha_2$	4.27E-03	1.52E-02	1.36E-02	3.14E-02	0.00E+00	3.0878E+00	2.0041E+02
$\alpha_3$	1.08E-03	8.02E-03	6.47E-03	2.02E-02	0.00E+00	1.6312E+00	2.0186E+02
$\alpha_4$	2.44E-04	4.86E-03	3.36E-03	1.46E-02	0.00E+00	9.8887E-01	2.0251E+02
$\alpha_5$	1.26E-05	2.56E-03	1.21E-03	9.69E-03	0.00E+00	5.2177E-01	2.0297E+02
$\alpha_6$	3.30E-10	9.15E-04	7.82E-05	4.80E-03	0.00E+00	1.8628E-01	2.0331E+02
$\alpha_7$	0.00E+00	1.43E-04	1.25E-13	5.38E-04	0.00E+00	2.9071E-02	2.0347E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9483960	0.9688070	0.9701040	0.9847820	1.0000000	2.3173E+02	7.4610E+00
$\alpha_2$	4.21E-03	1.40E-02	1.27E-02	2.83E-02	0.00E+00	3.3447E+00	2.3585E+02
$\alpha_3$	1.08E-03	7.27E-03	5.95E-03	1.80E-02	0.00E+00	1.7384E+00	2.3745E+02
$\alpha_4$	3.39E-04	4.79E-03	3.50E-03	1.37E-02	0.00E+00	1.1465E+00	2.3804E+02
$\alpha_5$	5.39E-05	2.96E-03	1.74E-03	1.00E-02	0.00E+00	7.0833E-01	2.3848E+02
$\alpha_6$	8.68E-07	1.53E-03	5.02E-04	6.56E-03	0.00E+00	3.6696E-01	2.3882E+02
$\alpha_7$	6.81E-14	5.14E-04	9.25E-06	2.93E-03	0.00E+00	1.2297E-01	2.3907E+02
$\alpha_8$	1.28E-42	1.38E-04	1.97E-12	5.85E-04	0.00E+00	3.3124E-02	2.3916E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	1.00E+00						
<b>Beta</b>	0.00E+00						
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
Adj. Ind. Events	13.00	13.00	13.00	13.00	13.00	13.00	13.00
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0000
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

## 1.15 Reactor Protection System, Reactor Trip Breakers

### 1.15.1 Reactor Trip Breakers

#### 1.15.1.1 REACTOR TRIP BREAKERS FAIL TO OPEN

System :	Reactor protection
Component :	Circuit Breaker
Failure Mode :	Fail to open on demand
Component Group :	Reactor Trip Breaker
Start Date :	1997/01/01
Data Version :	2009/12/31

Total Number of Independent Failure Events: 3.50

Total Number of Common-Cause Failure Events: 0

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8778910	0.9693580	0.9872590	0.9999390	1.0000000	1.3746E+01	4.3452E-01
$\alpha_2$	5.70E-05	3.06E-02	1.27E-02	1.22E-01	0.00E+00	4.3452E-01	1.3746E+01

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9081850	0.9677690	0.9763880	0.9978580	1.0000000	3.3055E+01	1.1009E+00
$\alpha_2$	7.80E-04	2.44E-02	1.59E-02	7.70E-02	0.00E+00	8.3366E-01	3.3322E+01
$\alpha_3$	2.75E-07	7.82E-03	1.59E-03	3.71E-02	0.00E+00	2.6722E-01	3.3889E+01

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9138980	0.9639730	0.9698110	0.9940510	1.0000000	4.9636E+01	1.8551E+00
$\alpha_2$	1.98E-03	2.39E-02	1.80E-02	6.57E-02	0.00E+00	1.2281E+00	5.0263E+01
$\alpha_3$	8.87E-06	7.85E-03	2.92E-03	3.24E-02	0.00E+00	4.0431E-01	5.1087E+01
$\alpha_4$	1.87E-08	4.32E-03	5.93E-04	2.17E-02	0.00E+00	2.2267E-01	5.1268E+01

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9321610	0.9657140	0.9686860	0.9891110	1.0000000	9.9661E+01	3.5382E+00
$\alpha_2$	3.95E-03	2.05E-02	1.75E-02	4.73E-02	0.00E+00	2.1142E+00	1.0109E+02
$\alpha_3$	4.63E-04	9.47E-03	6.55E-03	2.85E-02	0.00E+00	9.7738E-01	1.0222E+02
$\alpha_4$	2.39E-06	3.63E-03	1.22E-03	1.54E-02	0.00E+00	3.7439E-01	1.0282E+02
$\alpha_5$	5.78E-21	7.00E-04	3.96E-07	4.06E-03	0.00E+00	7.2277E-02	1.0313E+02

**Reactor Trip Breakers****REACTOR TRIP BREAKERS FAIL TO OPEN****CCCG = 6**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9354210	0.9656940	0.9681580	0.9875430	1.0000000	1.2044E+02	4.2787E+00
$\alpha_2$	3.69E-03	1.80E-02	1.54E-02	4.08E-02	0.00E+00	2.2392E+00	1.2248E+02
$\alpha_3$	6.45E-04	9.16E-03	6.70E-03	2.61E-02	0.00E+00	1.1418E+00	1.2358E+02
$\alpha_4$	4.25E-05	4.75E-03	2.49E-03	1.71E-02	0.00E+00	5.9222E-01	1.2413E+02
$\alpha_5$	7.45E-09	1.78E-03	2.42E-04	8.93E-03	0.00E+00	2.2220E-01	1.2450E+02
$\alpha_6$	1.13E-18	6.67E-04	1.17E-06	3.90E-03	0.00E+00	8.3237E-02	1.2464E+02

**CCCG = 7**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9432840	0.9667780	0.9683730	0.9848250	1.0000000	1.8755E+02	6.4450E+00
$\alpha_2$	4.49E-03	1.59E-02	1.43E-02	3.29E-02	0.00E+00	3.0878E+00	1.9091E+02
$\alpha_3$	1.13E-03	8.41E-03	6.79E-03	2.12E-02	0.00E+00	1.6312E+00	1.9236E+02
$\alpha_4$	2.55E-04	5.10E-03	3.53E-03	1.53E-02	0.00E+00	9.8887E-01	1.9301E+02
$\alpha_5$	1.32E-05	2.69E-03	1.27E-03	1.02E-02	0.00E+00	5.2177E-01	1.9347E+02
$\alpha_6$	3.47E-10	9.60E-04	8.20E-05	5.04E-03	0.00E+00	1.8628E-01	1.9381E+02
$\alpha_7$	0.00E+00	1.50E-04	1.31E-13	5.64E-04	0.00E+00	2.9071E-02	1.9397E+02

**CCCG = 8**

<b>Alpha Factor</b>	<b>5th%</b>	<b>Mean</b>	<b>Median</b>	<b>95th%</b>	<b>MLE</b>	<b>a</b>	<b>b</b>
$\alpha_1$	0.9462860	0.9675170	0.9688690	0.9841460	1.0000000	2.2223E+02	7.4610E+00
$\alpha_2$	4.38E-03	1.46E-02	1.32E-02	2.95E-02	0.00E+00	3.3447E+00	2.2635E+02
$\alpha_3$	1.12E-03	7.57E-03	6.19E-03	1.87E-02	0.00E+00	1.7384E+00	2.2795E+02
$\alpha_4$	3.53E-04	4.99E-03	3.65E-03	1.42E-02	0.00E+00	1.1465E+00	2.2854E+02
$\alpha_5$	5.61E-05	3.08E-03	1.81E-03	1.04E-02	0.00E+00	7.0833E-01	2.2898E+02
$\alpha_6$	9.04E-07	1.60E-03	5.23E-04	6.83E-03	0.00E+00	3.6696E-01	2.2932E+02
$\alpha_7$	7.09E-14	5.35E-04	9.63E-06	3.05E-03	0.00E+00	1.2297E-01	2.2957E+02
$\alpha_8$	1.33E-42	1.44E-04	2.06E-12	6.10E-04	0.00E+00	3.3124E-02	2.2966E+02

**ALPHA FACTOR and MGL PARAMETERS**

<b>Alpha Factor</b>	<b>CCCG=2</b>	<b>CCCG=3</b>	<b>CCCG=4</b>	<b>CCCG=5</b>	<b>CCCG=6</b>	<b>CCCG=7</b>	<b>CCCG=8</b>
$\alpha_1$	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000	1.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

**Reactor Trip Breakers****REACTOR TRIP BREAKERS FAIL TO OPEN**

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	1.00E+00						
<b>Beta</b>	0.00E+00						
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>Adj. Ind. Events</b>	3.50	3.50	3.50	3.50	3.50	3.50	3.50
<b>N<sub>1</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>2</sub></b>	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>3</sub></b>		0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>4</sub></b>			0.0000	0.0000	0.0000	0.0000	0.0000
<b>N<sub>5</sub></b>				0.0000	0.0000	0.0000	0.0000
<b>N<sub>6</sub></b>					0.0000	0.0000	0.0000
<b>N<sub>7</sub></b>						0.0000	0.0000
<b>N<sub>8</sub></b>							0.0000

## **2 No Data (Prior Only)**

**No Data**The section labeled No Data (Prior Only) shows the prior used in the CCF database. This is the result of calculating an application without any data, which is the same as calculating an application with all the events in the CCF database. These CCF parameters may be used for those cases where there is no reasonable set of data to approximate the intended event.

## 2.1 Generic Distributions

### 2.1.1 Generic Demand CCF Distribution

#### 2.1.1.1 ALL CCF DEMAND BASED EVENTS 1997 TO CURRENT SPAR: CCF-DEM

Failure Mode :

Fail to close (reseat) on demand

Fail to open on demand

Fail to start

Fail to Operate (Open/Close)

Fail to stop

Start Date :

1997/01/01

Data Version :

2009/12/31

Total Number of Independent Failure Events: 2446.50

Total Number of Common-Cause Failure Events: 97

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9634050	0.9726920	0.9730300	0.9808300	0.9728470	9.1215E+02	2.5608E+01
$\alpha_2$	1.92E-02	2.73E-02	2.70E-02	3.66E-02	2.72E-02	2.5608E+01	9.1215E+02

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9656500	0.9731230	0.9733470	0.9798310	0.9733270	1.3609E+03	3.7587E+01
$\alpha_2$	1.12E-02	1.63E-02	1.61E-02	2.22E-02	1.61E-02	2.2803E+01	1.3757E+03
$\alpha_3$	6.51E-03	1.06E-02	1.03E-02	1.54E-02	1.06E-02	1.4784E+01	1.3837E+03

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9663450	0.9728260	0.9729930	0.9787330	0.9731310	1.8052E+03	5.0425E+01
$\alpha_2$	1.12E-02	1.56E-02	1.54E-02	2.06E-02	1.53E-02	2.8905E+01	1.8267E+03
$\alpha_3$	3.63E-03	6.33E-03	6.15E-03	9.62E-03	6.27E-03	1.1737E+01	1.8439E+03
$\alpha_4$	2.84E-03	5.27E-03	5.10E-03	8.31E-03	5.29E-03	9.7833E+00	1.8458E+03

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9696730	0.9751830	0.9753210	0.9802270	0.9756580	2.2837E+03	5.8116E+01
$\alpha_2$	8.25E-03	1.16E-02	1.15E-02	1.55E-02	1.12E-02	2.7259E+01	2.3146E+03
$\alpha_3$	4.07E-03	6.55E-03	6.41E-03	9.51E-03	6.40E-03	1.5335E+01	2.3265E+03
$\alpha_4$	1.75E-03	3.49E-03	3.35E-03	5.70E-03	3.47E-03	8.1629E+00	2.3337E+03
$\alpha_5$	1.51E-03	3.14E-03	3.00E-03	5.25E-03	3.25E-03	7.3588E+00	2.3345E+03

## Generic Demand CCF Distribution

ALL CCF DEMAND BASED EVENTS 1997 TO CURRENT SPAR: CCF-DEM

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9724050	0.9772250	0.9773410	0.9816580	0.9777920	2.7361E+03	6.3768E+01
$\alpha_2$	6.22E-03	8.93E-03	8.81E-03	1.20E-02	8.50E-03	2.5000E+01	2.7749E+03
$\alpha_3$	3.92E-03	6.13E-03	6.01E-03	8.74E-03	5.98E-03	1.7153E+01	2.7827E+03
$\alpha_4$	1.94E-03	3.57E-03	3.45E-03	5.60E-03	3.51E-03	9.9848E+00	2.7899E+03
$\alpha_5$	7.95E-04	1.93E-03	1.81E-03	3.46E-03	1.93E-03	5.4037E+00	2.7945E+03
$\alpha_6$	9.88E-04	2.22E-03	2.11E-03	3.86E-03	2.29E-03	6.2261E+00	2.7936E+03

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9728470	0.9733270	0.9731310	0.9756580	0.9777920
$\alpha_2$	2.72E-02	1.61E-02	1.53E-02	1.12E-02	8.50E-03
$\alpha_3$		1.06E-02	6.27E-03	6.40E-03	5.98E-03
$\alpha_4$			5.29E-03	3.47E-03	3.51E-03
$\alpha_5$				3.25E-03	1.93E-03
$\alpha_6$					2.29E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.73E-01	9.73E-01	9.73E-01	9.76E-01	9.78E-01
Beta	2.72E-02	2.67E-02	2.69E-02	2.43E-02	2.22E-02
Gamma		3.98E-01	4.30E-01	5.39E-01	6.17E-01
Delta			4.58E-01	5.12E-01	5.64E-01
Epsilon				4.83E-01	5.47E-01
Mu					5.42E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	859.93	1289.89	1719.86	2149.82	2579.79
$N_1$	41.9722	41.4894	39.2067	37.7493	39.4055
$N_2$	25.1731	21.9689	27.6768	25.1446	22.7604
$N_3$		14.5168	11.3326	14.3577	16.0113
$N_4$			9.5606	7.7885	9.3926
$N_5$				7.2865	5.1815
$N_6$					6.1429

## 2.1.2 Generic Rate CCF Distribution

### 2.1.2.1 ALL CCF RATE BASED EVENTS 1997 TO CURRENT SPAR: CCF-RATE

Failure Mode :

Spurious operation open or close  
 Fail to run  
 Filter media allows the pass through of debris  
 High dP across filter  
 Fail to control flow  
 High voltage/ amperage output  
 Loss of heat transfer capabilities in heat exchangers  
 No voltage/amperage output  
 No flow/plugged

Start Date : 1997/01/01  
 Data Version : 2009/12/31

Total Number of Independent Failure Events: 1857.60

Total Number of Common-Cause Failure Events: 67

#### ALPHA FACTOR DISTRIBUTIONS

##### CCCG = 2

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9641020	0.9733720	0.9737170	0.9814740	0.9735380	8.9523E+02	2.4490E+01
$\alpha_2$	1.85E-02	2.66E-02	2.63E-02	3.59E-02	2.65E-02	2.4490E+01	8.9523E+02

##### CCCG = 3

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9668950	0.9742880	0.9745210	0.9808970	0.9745220	1.3372E+03	3.5289E+01
$\alpha_2$	1.00E-02	1.50E-02	1.47E-02	2.07E-02	1.47E-02	2.0532E+01	1.3520E+03
$\alpha_3$	6.61E-03	1.08E-02	1.05E-02	1.57E-02	1.08E-02	1.4757E+01	1.3577E+03

##### CCCG = 4

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9702030	0.9763400	0.9765110	0.9818840	0.9767450	1.7802E+03	4.3139E+01
$\alpha_2$	7.13E-03	1.08E-02	1.06E-02	1.50E-02	1.04E-02	1.9652E+01	1.8037E+03
$\alpha_3$	5.26E-03	8.45E-03	8.27E-03	1.23E-02	8.45E-03	1.5406E+01	1.8079E+03
$\alpha_4$	2.22E-03	4.43E-03	4.25E-03	7.26E-03	4.43E-03	8.0813E+00	1.8153E+03

##### CCCG = 5

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9736030	0.9787670	0.9789070	0.9834530	0.9794110	2.2573E+03	4.8969E+01
$\alpha_2$	4.92E-03	7.64E-03	7.50E-03	1.08E-02	7.02E-03	1.7615E+01	2.2887E+03
$\alpha_3$	4.25E-03	6.81E-03	6.66E-03	9.84E-03	6.67E-03	1.5698E+01	2.2906E+03
$\alpha_4$	2.74E-03	4.85E-03	4.71E-03	7.45E-03	4.90E-03	1.1185E+01	2.2951E+03
$\alpha_5$	7.14E-04	1.94E-03	1.80E-03	3.65E-03	1.99E-03	4.4708E+00	2.3018E+03

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9762820	0.9807670	0.9808860	0.9848620	0.9815060	2.7062E+03	5.3068E+01
$\alpha_2$	3.50E-03	5.62E-03	5.50E-03	8.15E-03	5.03E-03	1.5513E+01	2.7438E+03
$\alpha_3$	3.30E-03	5.37E-03	5.25E-03	7.84E-03	5.18E-03	1.4806E+01	2.7445E+03
$\alpha_4$	2.71E-03	4.61E-03	4.49E-03	6.92E-03	4.60E-03	1.2730E+01	2.7465E+03
$\alpha_5$	1.24E-03	2.61E-03	2.49E-03	4.39E-03	2.65E-03	7.2117E+00	2.7521E+03
$\alpha_6$	2.61E-04	1.02E-03	9.00E-04	2.18E-03	1.03E-03	2.8070E+00	2.7565E+03

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
$\alpha_1$	0.9735380	0.9745220	0.9767450	0.9794110	0.9815060
$\alpha_2$	2.65E-02	1.47E-02	1.04E-02	7.02E-03	5.03E-03
$\alpha_3$		1.08E-02	8.45E-03	6.67E-03	5.18E-03
$\alpha_4$			4.43E-03	4.90E-03	4.60E-03
$\alpha_5$				1.99E-03	2.65E-03
$\alpha_6$					1.03E-03

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
1-Beta	9.74E-01	9.75E-01	9.77E-01	9.79E-01	9.82E-01
Beta	2.65E-02	2.55E-02	2.33E-02	2.06E-02	1.85E-02
Gamma		4.24E-01	5.54E-01	6.59E-01	7.28E-01
Delta			3.44E-01	5.08E-01	6.15E-01
Epsilon				2.89E-01	4.45E-01
Mu					2.80E-01

Avg. Impact Vector	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6
Adj. Ind. Events	856.04	1284.06	1712.07	2140.09	2568.11
$N_1$	28.9417	23.5646	21.9561	21.0143	21.1847
$N_2$	24.0553	19.6980	18.4243	15.5003	13.2741
$N_3$		14.4893	15.0019	14.7205	13.6645
$N_4$			7.8586	10.8102	12.1379
$N_5$				4.3985	6.9895
$N_6$					2.7238

**2.1.3 CCF Prior Distribution****2.1.3.1 No Data (Prior Only)**

Data Version :

2007/12/31

Total Number of Independent Failure Events: 0

Total Number of Common-Cause Failure Events: 0

**ALPHA FACTOR DISTRIBUTIONS****CCCG = 2**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.8993200	0.9742690	0.9887700	0.9999290	----	1.7418E+01	4.6002E-01
$\alpha_2$	6.65E-05	2.57E-02	1.12E-02	1.00E-01	----	4.6002E-01	1.7418E+01

**CCCG = 3**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9306240	0.9755060	0.9819700	0.9982830	----	4.5105E+01	1.1325E+00
$\alpha_2$	6.61E-04	1.87E-02	1.23E-02	5.84E-02	----	8.6476E-01	4.5372E+01
$\alpha_3$	2.07E-07	5.79E-03	1.17E-03	2.74E-02	----	2.6776E-01	4.5969E+01

**CCCG = 4**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9380870	0.9740820	0.9782970	0.9956540	----	7.0868E+01	1.8856E+00
$\alpha_2$	1.43E-03	1.70E-02	1.28E-02	4.69E-02	----	1.2400E+00	7.1513E+01
$\alpha_3$	9.66E-06	5.89E-03	2.32E-03	2.38E-02	----	4.2870E-01	7.2324E+01
$\alpha_4$	9.21E-09	2.98E-03	3.83E-04	1.50E-02	----	2.1695E-01	7.2536E+01

**CCCG = 5**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9521790	0.9760740	0.9782400	0.9925770	----	1.4106E+02	3.4576E+00
$\alpha_2$	2.59E-03	1.41E-02	1.19E-02	3.30E-02	----	2.0400E+00	1.4247E+02
$\alpha_3$	3.01E-04	6.59E-03	4.50E-03	2.00E-02	----	9.5369E-01	1.4356E+02
$\alpha_4$	2.21E-06	2.67E-03	9.37E-04	1.12E-02	----	3.8684E-01	1.4413E+02
$\alpha_5$	5.61E-20	5.33E-04	5.18E-07	3.10E-03	----	7.7129E-02	1.4444E+02

**CCCG = 6**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9553700	0.9762820	0.9779970	0.9913440	----	1.7893E+02	4.3470E+00
$\alpha_2$	2.60E-03	1.24E-02	1.07E-02	2.81E-02	----	2.2804E+00	1.8099E+02
$\alpha_3$	4.16E-04	6.13E-03	4.45E-03	1.75E-02	----	1.1245E+00	1.8215E+02
$\alpha_4$	3.82E-05	3.40E-03	1.85E-03	1.20E-02	----	6.2471E-01	1.8265E+02
$\alpha_5$	1.60E-08	1.32E-03	2.18E-04	6.46E-03	----	2.4272E-01	1.8303E+02
$\alpha_6$	1.26E-20	4.07E-04	3.05E-07	2.36E-03	----	7.4722E-02	1.8320E+02

**CCCG = 7**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9603690	0.9769760	0.9781320	0.9896440	----	2.6720E+02	6.2971E+00
$\alpha_2$	3.14E-03	1.12E-02	1.00E-02	2.33E-02	----	3.0721E+00	2.7042E+02
$\alpha_3$	6.66E-04	5.55E-03	4.40E-03	1.43E-02	----	1.5182E+00	2.7197E+02
$\alpha_4$	1.58E-04	3.48E-03	2.37E-03	1.06E-02	----	9.5310E-01	2.7254E+02
$\alpha_5$	1.00E-05	1.93E-03	9.22E-04	7.26E-03	----	5.2795E-01	2.7296E+02
$\alpha_6$	4.58E-10	7.08E-04	6.75E-05	3.68E-03	----	1.9373E-01	2.7330E+02
$\alpha_7$	5.03E-44	1.17E-04	8.41E-13	4.81E-04	----	3.2027E-02	2.7346E+02

**CCCG = 8**

Alpha Factor	5th%	Mean	Median	95th%	MLE	a	b
$\alpha_1$	0.9622170	0.9773660	0.9783580	0.9891370	----	3.1221E+02	7.2302E+00
$\alpha_2$	3.13E-03	1.04E-02	9.45E-03	2.12E-02	----	3.3414E+00	3.1609E+02
$\alpha_3$	6.67E-04	5.04E-03	4.06E-03	1.28E-02	----	1.6130E+00	3.1782E+02
$\alpha_4$	1.86E-04	3.26E-03	2.30E-03	9.62E-03	----	1.0438E+00	3.1839E+02
$\alpha_5$	3.88E-05	2.20E-03	1.28E-03	7.47E-03	----	7.0280E-01	3.1873E+02
$\alpha_6$	5.77E-07	1.13E-03	3.63E-04	4.86E-03	----	3.6184E-01	3.1907E+02
$\alpha_7$	1.19E-13	3.98E-04	8.44E-06	2.25E-03	----	1.2739E-01	3.1931E+02
$\alpha_8$	5.47E-36	1.25E-04	5.43E-11	6.01E-04	----	4.0005E-02	3.1940E+02

**ALPHA FACTOR and MGL PARAMETERS**

Alpha Factor	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
$\alpha_1$	0.0000000	0.0000000	0.0000000	0.0000000	0.0000000	0.0000000	0.0000000
$\alpha_2$	0.00E+00						
$\alpha_3$		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_4$			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_5$				0.00E+00	0.00E+00	0.00E+00	0.00E+00
$\alpha_6$					0.00E+00	0.00E+00	0.00E+00
$\alpha_7$						0.00E+00	0.00E+00
$\alpha_8$							0.00E+00

MGL Parameter	CCCG=2	CCCG=3	CCCG=4	CCCG=5	CCCG=6	CCCG=7	CCCG=8
<b>1-Beta</b>	1.00E+00						
<b>Beta</b>	0.00E+00						
<b>Gamma</b>		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Delta</b>			0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Epsilon</b>				0.00E+00	0.00E+00	0.00E+00	0.00E+00
<b>Mu</b>					0.00E+00	0.00E+00	0.00E+00
<b>Upsilon</b>						0.00E+00	0.00E+00
<b>Sigma</b>							0.00E+00

## 3 Glossary

### **Application**

A particular set of CCF events selected from the CCF database for use in a specific study.

### **Average Impact Vector**

An average over the impact vectors for different hypotheses regarding the number of components failed in an event.

### **Available**

The component is available if it is capable of performing its function according to a specified success criterion.

### **Basic Event**

An event in a reliability logic model that represents the state in which a component or group of components is unavailable and does not require further development in terms of contributing causes.

### **Common Cause Event**

A dependent failure in which two or more component fault states exist simultaneously, or within a short time interval, and are a direct result of a shared cause.

### **Common Cause Basic Event**

In system modeling, a basic event that represents the unavailability of a specific set of components because of shared causes that are not explicitly represented in the system logic model as other basic events.

### **Common Cause Component Group**

A group of (usually similar [in mission, manufacturer, maintenance, environment, etc.]) components that are considered to have a high potential for failure due to the same cause or causes.

### **Common Cause Failure Model**

The basis for quantifying the frequency of common cause events. Examples include the beta factor, alpha factor, and basic parameter, and the binomial failure rate models.

### **Complete Common Cause Failure**

A CCF in which all redundant components are failed simultaneously as a direct result of a shared cause; i.e., the component degradation value equals 1.0 for all components, and both the timing factor and the shared cause factor are equal to 1.0.

### **Component**

An element of plant hardware designed to provide a particular function.

### **Component Boundary**

The component boundary encompasses the set of piece parts that are considered to form the component.

### **Component Degradation Value (p)**

The assessed probability ( $0.0 = p = 1.0$ ) that a functionally or physically degraded component would fail to complete the mission.

### **Component State**

Component state defines the component status in regard to its intended function. Two general categories of component states are defined as available and unavailable.

### **Timing Factor (q)**

The probability ( $0.0 = q = 1.0$ ) that two or more component failures (or degraded states) separated in time represent a CCF. This can be viewed as an indication of the strength-of-coupling in synchronizing failure times.

**Unavailable**

The component is unavailable if the component is unable to perform its intended function according to a stated success criterion. Two subsets of unavailable states are failure and functionally unavailable.

**Exposed Population**

The set of components within the plant that are potentially affected by the CCF under consideration.

**Failure**

The component is not capable of performing its specified operation according to a success criterion.

**Functionally Unavailable**

The component is capable of operation, but the function normally provided by the component is unavailable due to lack of proper input, lack of support function from a source outside the component (i.e., motive power, actuation signal), maintenance, testing, the improper interference of a person, etc.

**Potentially Unavailable**

The component is capable of performing its function according to a success criterion, but an incipient or degraded condition exists. (N.B., potentially unavailable is not synonymous with hypothetical.)

**Defense**

Any operational, maintenance, and design measures taken to diminish the frequency and/or consequences of CCFs.

**Degraded**

The component is in such a state that it exhibits reduced performance but insufficient degradation to declare the component unavailable according to the specified success criterion.

**Impact Vector**

An assessment of the impact an event would have on a common cause component group. The impact is usually measured as the number of failed components out of a set of similar components in the common cause component group.

**Incipient**

The component is in a condition that, if left unremedied, could ultimately lead to a degraded or unavailable state.

**Reliability Logic Model**

A logical representation of the combinations of component states that could lead to system failure. A fault tree is an example of a system logic model.

**Root Cause**

The most basic reason for a component failure, which, if corrected, could prevent recurrence. The identified root cause may vary depending on the particular defensive strategy adopted against the failure mechanism.

**Shared Cause Factor/Mechanism**

A set of causes and factors characterizing why and how a failure is systematically induced in several components.

**Failure Mechanism**

The history describing the events and influences leading to a given failure.

**Failure Mode**

A description of component failure in terms of the component function that was actually or potentially unavailable.

**Failure Mode Applicability**

The analyst's probability that the specified component failure mode for a given event is appropriate to the particular application.

**Mapping**

The impact vector of an event must be "mapped up" or "mapped down" when the exposed population of the target plant is higher or lower than that of the original plant that experienced the CCF. The end result of mapping an impact vector is an adjusted impact vector applicable to the target plant.

**Mapping Up Factor**

A factor used to adjust the impact vector of an event when the exposed population of the target plan is higher than that of the original plant that experienced the CCF.

**Potential Common Cause Failure**

Any common cause event in which at least one component degradation value is less than 1.0.

**Proximate Cause**

A characterization of the condition that is readily identified as leading to failure of the component. It might alternatively be characterized as a symptom.

**Shared-Cause Factor (c)**

A number that reflects the analyst's uncertainty ( $0.0 = c = 1.0$ ) about the existence of coupling among the failures of two or more components, i.e., whether a shared cause of failure can be clearly identified.

**Shock**

A shock is an event that occurs at a random point in time and acts on the system; i.e., all the components in the system simultaneously. There are two kinds of shocks distinguished by the potential impact of the shock event, i.e., lethal and non-lethal.

**System**

The entity that encompasses an interacting collection of components to provide a particular function or functions.